

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F6/DFS/MS/School/2015/WZ/1481

Dated: 14/08/15

FIRE SAFETY CERTIFICATE

Certified that the **J.N. Modern Public School** Located at **WZ-1220, Rani Bagh, Delhi – 110034**, comprised of Ground + 02 Upper Floors was issued FSC vide Letter No. **F6/MS/DFS/MS/2011/247 Dated 10-02-2011**. The premises was re inspected by the officer concerned of this department on 04-08-2015 in the presence of **Smt. Bhatiya(Principal)** and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance DOE Circular 262 – 362 Dated 17-01-2005 and that the premises is fit for occupancy class “Educational” Group B with effect from 14/08/15 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ... 14/08/15 ... at New Delhi by.

  
(Smt. Bhatiya Singh)  
Chief Fire Officer  
PH 011-23414250

Copy to:

The Principal, WZ-1220, Rani Bagh, Delhi – 110034

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

## INSPECTION REPORT

Name & address of the building: **J.N. Modern Public School, WZ-1220, Rani Bagh, Delhi – 110034.**

Type of Occupancy : **Educational ( Ground + 2Upper Floor)**

1. Type of Case : **Renewal**

2. Details of previous NOC : **F6/MS/DFS/MS/2011/247 Dated 10-02-2011**

3. Fire Safety directives Letter No. : **262-362 Dated-17-01-2005**

Area of School- 161sqm Covered Area-140sqm Class rooms-10 Student in School-253
--

4. Date of inspection : **04 -08-2015**

5. Name of the Inspecting Officer : **Udaivir Singh,ADO (WP)**

6. Name and designation of Officer

from the building side : **Smt. Anita Bhatiya (President)**

7. Year of Construction : **1981**

8. Applicant's letter No. : **Nil Dated 29-06-2015**

S No	Minimum standards on fire prevention and fire safety U/R 33	Cr.No <sup>262</sup> - <sup>362</sup> dated <sup>17/01/2005</sup> Jw.	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	<ul style="list-style-type: none"> <li>Accessible</li> <li>Accessible</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>Provided(For small fire unit)</li> <li>Provided(On Road)</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>MR(Being old case)</li> <li>MR</li> <li>NA</li> </ul>
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>Upper floors</li> <li>Basements</li> </ul>	<ul style="list-style-type: none"> <li>1</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>Provided</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>MR</li> <li>NA</li> </ul>
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>Upper floors</li> <li>Basements</li> </ul>	<ul style="list-style-type: none"> <li>1x1.5mtrs</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>Provided 1x70cm &amp; 1x75cm</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>MR(Being old case)</li> <li>NA</li> </ul>
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Pressurization</li> </ul>	<ul style="list-style-type: none"> <li>NA</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>NA</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>NA</li> <li>NA</li> </ul>
	d. No of continuous staircase to terrace	1	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	100cm	Old Case	MR(Being old case)

*All the class Room*

3.	Compartmentation			
	<ul style="list-style-type: none"> <li>• Fire check door</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Sealing of electrical shafts</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Fire Rating of shaft door</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Water Curtain</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Fire Dampers</li> </ul>	NA	NA	NA
4.	Smoke managements Syst.			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Upper floors</li> </ul>	NA	NA	NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>• Total numbers</li> </ul>	06 nos.	Provided	MR
	<ul style="list-style-type: none"> <li>• Types</li> </ul>	ABC &	Provided	MR
	<ul style="list-style-type: none"> <li>• IS marking</li> </ul>	CO <sub>2</sub> ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> </ul>	1	Provided	MR
	<ul style="list-style-type: none"> <li>• Length of hose reel</li> </ul>	30m	Provided	MR
	<ul style="list-style-type: none"> <li>• Nozzle diameter</li> </ul>	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Location of Main Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Location of Repeater Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Alternate source of power</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Hooters' Location</li> </ul>	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Upper Floor</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Sprinkler above false ceiling</li> </ul>	NA	NA	NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> </ul>	1	Provided	MR
	<ul style="list-style-type: none"> <li>• Number of hyd/floor</li> </ul>	1	Provided	MR
	<ul style="list-style-type: none"> <li>• Hose Box</li> </ul>	1	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Hose Box</li> </ul>	NA	NA	NA

13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> <li>• Ground Level</li> <li>• Discharge of main pump</li> <li>➤ Head of main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>Auto Starting/Manual stopping</li> <li>➤ Pump House Access</li> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power supply</li> <li>➤ Auto starting of pump</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		220lpm	Provided	MR
		40Mtr	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water Storage for firefighting:			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		5000Ltr	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> <li>➤ Pressurization of Lift Shaft</li> <li>➤ Pressurization of lift lobby</li> <li>➤ Communication in lift Car</li> <li>➤ Fireman's Grounding Switch</li> <li>➤ Lift Signage</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	<ul style="list-style-type: none"> <li>➤ Total area</li> <li>➤ Location</li> </ul>	NA	NA	NA
		NA	NA	NA

H/15

19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans			
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Note:-General requirements for schools as per Director of Education circular dated 01/03/2011.

1. Escape route ..... Clear.....
2. LPG cylinders in laboratories NA
3. Electric wiring ...Conduit Wiring..... MCB and ELCB .....  
Electric circuit .....
4. Electric meter board .....Not under the staircase.....
5. Basement use as per BBL 1983 ... NA
6. Emergency telephone no. board ...Displayed.....
7. Generator set .....NA.....

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide Letter No. F6/DFS/MS/2011/247 Dated- 10-02-2011renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

~~Signature~~ 5/8/15

Signature of the Inspecting Officer  
Officer

Signature of the Inspecting

Name Uday Vir Singh

Name

Designation ADO/wp

Designation