

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/MS/DFS/EH/2014/52/1508

Dated: 18/08/15

**FIRE SAFETY CERTIFICATE**

Certified that the B-Bar(a Unit of BB Hospitality Ventures Pvt. Ltd.) located at Level 4, Atrium, Select City Walk Mall, A-3 District Centre Saket, Saket, New Delhi-110017, comprised of 3 tier basement, ground + six upper floors but the restaurant is running at 4<sup>th</sup> level owned/occupied by B-Bar(a Unit of BB Hospitality Ventures Pvt. Ltd.).The premises was re- inspected by the officer concerned of this department on 13/08/15 in the presence of Mr. Manoj Sharma and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class Group – D, Assembly Building with effect from 18/08/15 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued 18/08/15 at New Delhi by.

  
(Dr. G.C.Misra)  
Chief Fire Officer  
Tel: 011-23414333

Copy to:-

- (1) Dy. Health Officer/ South Zone  
Aurbindo Marg, Green Park  
New Delhi
- (2) Authorized Signatory  
B-Bar(a Unit of BB Hospitality Ventures Pvt. Ltd.)  
Level 4, Atrium, Select City Walk Mall,  
A-3 District Centre Saket, Saket, New Delhi-110017,



Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of NBC
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

## INSPECTION REPORT

1. Name & address of the building:- B-Bar(a Unit of BB Hospitality Ventures Pvt. Ltd.) Level 4, Atrium, Select City Walk Mall, A-3 District Centre Saket, Saket, New Delhi-110017
  2. Type of occupancy:- Assembly Building, Group – D, Restaurant
  3. Type of case:-Renewal
  4. Details of previous NOC:-F6/DFS/MS/2012/EH/2693 dated: 24/07/2012
  5. Fire safety directives No.- Nil
  6. Date of inspection:-13/08/15
  7. Name of the inspecting officer:- D.B.Mukherjee, A.D.O.(BCP)
  8. Name & designation of officer From the building side:- Mr. Manoj Sharma
  9. Year of construction:- 2007.
  10. Applicant's letter No:-Nil dated 13/07/15
- Building is comprised of 3Tier Basement, Ground + 6 Upper Floors. Restaurant is running at level 4.

Sl.No	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement NBC	Provided at site	Remarks MR/NMR
<b>1.</b>	<b>Access to Building</b>			
	1) Road width	Required	Provided	MR
	2) Gate width	N/A	N/A	N/A
	3)Width of internal road	06	Provided	MR
<b>2.</b>	<b>Number, Width Type &amp; Arrangement of Exits</b> <span style="float: right;"><b>Provided and maintained by Mall</b></span>			
	A. Number of staircases			
	1. Upper floors	02	Two nos. provided near Restaurant	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.5m	1.5 m each	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	Required	Provided by mall	MR
	2. Pressurization	Required	Provided by mall	MR
	D. No. of continuous staircase to terrace	Two	Provided by mall	MR
	E. Width of corridor	Required	Provided by mall	MR
	F. Door size	02 m	02m Provided	MR
<b>3.</b>	<b>Compartmentation</b> <span style="float: right;"><b>Provided and maintained by Mall</b></span>			
	1) Fire check door	Required	Provided by Mall	MR
	2) Sealing of electrical shafts	Required	Provided by Mall	MR
	3) Fire rating of shaft door	Required	Provided by Mall	MR
	4) Water curtain	Required	Provided by Mall	MR
	5) Fire Dampers	Required	Provided by Mall	MR
<b>4.</b>	<b>Smoke Management System</b> <span style="float: right;"><b>Provided and maintained by Mall</b></span>			
	1) Basements	30 a/c per hour	N/A	N/A
	2) Upper floors	12 a/c per hour	Provided by Mall	MR
<b>5.</b>	<b>Fire Extinguishers</b> <span style="float: right;"><b>Provided and maintained by Mall</b></span>			
	1) Total numbers	ISI Marked	28 Nos.	MR
	2) Types		ABC, Co2 ,Foam	MR
	3) ISI marking		Yes	MR

<b>6.</b>	<b>First-Aid Hose Reel</b>	<b>Provided and maintained by Mall</b>		
	1) Total number of each floor	02	Provided	MR
	2) Length of hose reel hose	30m	Provided	MR
	3) Nozzle diameter	5mm	Provided	MR
<b>7.</b>	<b>Automatic Fire Detection &amp; Alarming System</b>	<b>Provided and maintained by Mall</b>		
	1) Type of detectors	Smoke/Beam	Provided	MR
	2) Location of main panel	Required	Provided by Mall	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Provided by Mall	MR
	5) Hooter's Location	Required	Provided by Mall	MR
<b>8.</b>	<b>MOEFA</b>	<b>Provided and maintained by Mall</b>		
<b>9.</b>	<b>Public Address System</b>	<b>Provided and maintained by Mall</b>		
<b>10.</b>	<b>Automatic Sprinkler System</b>	<b>Provided and maintained by Mall</b>		
	1) Basement	Required	Provided by Mall	MR
	2) Upper floors	Required	Provided by Mall	MR
	3) Sprinkler above false ceiling	Required	Provided by Mall	MR
<b>11.</b>	<b>Internal Hydrants</b>	<b>Provided and maintained by Mall</b>		
	1) Size of riser/down-comer	Required	Provided by Mall	MR
	2) Number of hydrants per floor	Required	Provided by Mall	MR
	3) Hose box	Required	Provided by Mall	MR
<b>12.</b>	<b>Yard Hydrants</b>			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
<b>13.</b>	<b>Pumping Arrangement</b>	<b>Provided and maintained by Mall</b>		
	1) Ground level			
	a) Discharge of main pump	4500 lpm	Provided by Mall	MR
	b) Head of main pump	88m	Provided by Mall	MR
	c) Number of main pump	02	Provided by Mall	MR
	d) Jockey pump out put	180 lpm	Provided by Mall	MR
	e) Jockey pump head	02	Provided by Mall	MR
	f) Stand by pump output	4500 lpm	Provided by Mall	MR
	g) Stand by pump head	88m	Provided by Mall	MR
	h) Auto starting/Manual stopping	Required	Provided by Mall	MR
	2) Terrace level			
	a) Discharge of pump	180 lpm	Provided by Mall	MR
	b) Head of pump	88m	Provided by Mall	MR
	c) Power supply	Required	Provided by Mall	MR
	d) Auto starting of pump	Required	Provided by Mall	MR
<b>14.</b>	<b>Captive Water Storage for Fire Fighting</b>	<b>Provided and maintained by Mall</b>		
	1) Under ground tank capacity	500 KL	Provided by Mall	MR
	a) Draw-off connection	Required	Provided by Mall	MR
	b) Fire service inlet	Required	Provided by Mall	MR
	c) Access to tank	Required	Provided by Mall	MR
	d) Over head tank capacity	30KL	Provided by Mall	MR
<b>15.</b>	<b>Exit Signage.</b>	<b>Provided and maintained by Mall</b>		
<b>16.</b>	<b>Provision of Lifts.</b>	<b>Provided and maintained by Mall</b>		
	a) Pressurization of lift shaft	Required	Provided by Mall	MR
	b) Pressurization of lift lobby	Required	Provided by Mall	MR
	c) Communication in lift car	Required	Provided by Mall	MR
	d) Fireman's switch	Required	Provided by Mall	MR
	e) Lift signage	Required	Provided by Mall	MR

17.	<b>Stand by Power Supply</b>	<b>Provided and maintained by Mall</b>		
18.	<b>Refuge Area</b>	<b>Provided and maintained by Mall</b>		
	Total area	958.78 m2	Provided by Mall	MR
	location	4 <sup>th</sup> & 6th Floor	Provided by Mall	MR
19.	<b>Fire Control Room</b>	<b>Provided and maintained by Mall</b>		
	a) Detector system panel	Required	Provided by Mall	MR
	b) Flow switch panel	Required	Provided by Mall	MR
	c) PA system panel	Required	Provided by Mall	MR
	d) Battery backup	Required	Provided by Mall	MR
	e) Building floor plan	Required	Provided by Mall	MR
20.	<b>Special Fire Protection System for Protection of special Risk, if any: Provided and maintained by Mall</b>			
	1. Co2 flooding system for LT HT Panel.      2. FM 200 for Server Cabin.			

The fire protection system provided in the restaurant building were checked and found functional at the time of inspection.

The FSC of the mall has been renewed in the year 2015.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F6/DFS/MS/2012/EH/2693 dated: 24/07/2012, renewal under rules 35 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly DFA is put up please.

*[Handwritten Signature]*  
14/8/2015

Signature of the inspecting officer

Name :- D.B. Mukherjee.

Designation :- Assistant Divisional Officer.