

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/MS/DFS/EH/SZ/2015/ 1492

Dated: 17/08/15

FIRE SAFETY CERTIFICATE

Certified that the Mc Donald's Restaurant (M/S Connaught Plaza Restaurant Private Limited) located at H-12A, Kalkaji, New Delhi-110019, comprised of ground + two upper & Barsati floors owned/occupied by M/s Connaught Plaza Restaurant Private Limited. The restaurant is running at ground & first floor was granted FSC by this department vide letter No.F6/MS/DFS/MS/2012/EH/3459 dated: 21/09/2012. The premises was re-inspected by the officer concerned of this department on 10/08/15 in the presence of Mr. Kawalvir Singh and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class Group – D Assembly Building (Restaurant) with effect from--17/08/15---for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued ~~17/08/15~~ at New Delhi by.


(Dr. G. C. Misra)
Chief Fire Officer
Tel: 011-23414333

9c Eja
ADD(BEP)

Copy to ;

Mr. Dharmendra Nath Thakur
13/A, Jor Bagh Market,
New Delhi-110003

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building:- Mc Donald's Restaurant (M/s Connaught Plaza Restaurant Private Limited) located at H-12A, Kalkaji, New Delhi-110019
2. Type of occupancy:- Assembly, Group - D, Restaurant
3. Type of case:- Renewal
4. Details of previous NOC:- F6/MS/DFS/MS/2012/EH/3459 Dated 21/09/2012
5. Fire safety directives No.- Nil
6. Date of inspection:- 11/08/2015
7. Name of the inspecting officer:- D.B. Mukherjee, A.D.O. (BCP)
8. Name & designation of officer from the building side:- Mr. Kawalvir Singh
9. Year of construction:- 2004.
10. Applicant's letter no:- Nil Dated 26/05/2015
11. Composition of Building: Ground + Two Upper & Barsati Floors.
Restaurant is running at Ground & First Floor only.

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement NBC	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	4.5 mtr	Approachable	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	2 Nos	2 Nos	MR
	2. Basements	2 Nos	2 Nos	MR
	B. Width of staircase			
	1. Upper floors	1.50m	1.50m & 1m	MR (Old Case)
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01 No.	Provided	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	2 mtrs	2 mtrs	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	12 a/c per hour	Exhaust Fan	MR
5.	Fire Extinguishers			
	1) Total numbers		08 Nos.	MR
	2) Types	ISI Marked	ABC, Co2	MR
	3) ISI marking		Yes	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01 Nos	Provided at each floor	MR
	2) Length of hose reel hose	30 m	Provided	MR
	3) Nozzle diameter	5 mm	Provided	MR

7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Smoke	Provided	MR
	2) Location of main panel	Ground Floor	Provided	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	Required	Provided	MR
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level	N/A	N/A	N/A
	a) Discharge of pump	450 LPM & 180 LPM	Provided	MR
	b) Head of pump	35 mtrs	35mtrs & 35 mtrs	MR
	c) Power supply	MR	MR	MR
	d) Auto starting of pump	MR	MR	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	10,000ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area			
	Total area	N/A	N/A	N/A
	location	N/A	N/A	N/A

2/7

19.	Fire Control Room			
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/2012/EH/3459 dated 21/09/2012, renewal under rules 35 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly DFA is put up please.

[Handwritten Signature]
12/8/15

Signature of the inspecting officer

Name :- D.B. Mukherjee.

Designation :- Assistant Divisional Officer(BCP)