

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F.6/DFS/MS/2015/*school/w2/1517*

Dated: *20/08* /2015


FIRE SAFETY CERTIFICATE

Certified that M/s Vidya Inn (A unit of Vidya Techno Mech Pvt. Ltd.) located on first second and third floor of a premises comprised of basement, stilt, ground and three upper floors of Plot No 8, C-3, Block Ashok Vihar Phase - II, Delhi with 11 rooms each on first & second floor and 04 room on third floor owner and occupied by M/S Vidya Inn, have complied with the fire prevention and fire safety arrangements requirements in accordance with rule 33 of the Delhi fire service Rules, 2010 and verified by the officer concerned of Fire Service on 22/06/2015 in the presence of Mr. Surabh Signal and that the building /premises is fit for Residential (Guest House) occupancy with effect from 20/08/2015 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Following fire safety directives must be adhered to:-

1. The means of escape shall be kept free of any obstruction all the time & remain accessible to occupants for easy escape in case of any emergency.
2. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
3. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
6. Basement shall be used as per NBC Part-IV.
7. This certificate cannot be treated in any case for regularizations of unauthorized construction.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
9. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on *20/08/15* at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250

Copy to

1. M/S Vidya Inn (A unit of Vidya Techno Mech Pvt. Ltd.) plot no 8, c-3, block Ashok Vihar Phase-II, Delhi.
2. Dy. Health Officer, Civil Line Zone, MCD Public Health Department, 16, Rajpur Road, Delhi 110054

INSPECTION REPORT

1. Name & address of the building : M/s Vidya Inn (Aunit of Vidya Techno Mech Pvt. Ltd.) located at Plot no.8, C-3, Block Ashok Vihar Phase-II, Delhi
2. Type of Occupancy : Residential (Guest House) **(Basement+Stilt+G + 03 upper Floors)**
3. Type of Case : New ✓
4. Details of previous NOC : Nil ✓
5. Fire Safety directives letter No. : NBC ✓
6. Date of inspection : 22-06-2015 ✓
7. Name of the Inspecting Officers : Sunil Chawdhary DO (M.N.) ✓
8. Name and designation of officers
 From the building side : Mr. Surabh Singal ✓
9. Year of Construction : 2014 ✓
10. Applicant's letter No. : DHO/CLZ/2014/894 dated 24/07/2014 ✓

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	18 mtr	24 mtr ✓	M/R ✓
	• Gate width	4.5 mtr	Provided ✓	M/R ✓
	• Width of internal road	N.R.	N.R. ✓	N.R.
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02 Provided ✓	M.R. ✓
	• Basement	02	02 Provided ✓	M.R.
	b. Width of staircases			
	• Upper Floors	2 x 1.5 mtr	2 x 1.8 mtr ✓	M.R. ✓
	• Basement	2 x 1.5 mtr	1.8 & 2 mtr ✓	M.R. ✓
	c. Protection of exits			
	• Fire check door	Required	Provided ✓	M.R.
	• Pressurization	N.R.	N.R.	N.R.
	d. No. of continuous staircases to terrace	01	02 Provided ✓	M.R.
	e. Width of Corridor	1.5 mtr	Provided ✓	M.R.
	f. Door size	1 mtr	Provided ✓	M.R. ✓
3.	Compartmentation.			
	• Fire check door	Required	Provided ✓	M.R. ✓
	• Sealing of electrical shafts	N.A.	N.A.	N.A.
	• Fire Rating of shaft door	N.A.	N.A.	N.A.
	• Water Curtain	N.A.	N.A.	N.A.
	• Fire Dampers	N.R.	N.R.	N.R.
4.	Smoke Management System.			
	• Basements	Required	Provided ✓	M.R. ✓
	• Upper floors	N.A.	Provided -	N.A.
5.	Fire Extinguishers			
	• Total numbers	24 nos.	33 provided ✓	M.R.
	• Types	ABC, & CO ₂ Type	Provided ✓	M.R.
	• IS marking	ISI marked	Provided ✓	M.R.
6.	First Aid Hose Reel			

	<ul style="list-style-type: none"> Length of hose reel hose Nozzle diameter 	30 m required 5 mm	provided provided	M.R. M.R.
7.	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's Location 	N.A. N.A. N.A. N.A. N.A.	N.A. N.A. N.A. N.A. N.A.	N.A. N.A. N.A. N.A. N.A.
8.	MOEFA	Required	Provided	M.R.
9.	Public Address System	Required	Provided	M.R.
10.	Automatic Sprinkler system			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	Required N.R. N.R.	Provided N.R. N.R.	M.R. N.R. N.R.
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N.A. N.A. N.A.	N.A. N.A. N.A.	N.A. N.A. N.A.
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N.R. N.R.	N.R. N.R.	N.R. N.R.
13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump	N.A.	N.A.	N.A.
	➤ Head of Main pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey Pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting/Manual stopping	N.A.	N.A.	N.A.
	➤ Pump Hose Access	N.A.	N.A.	N.A.
	Terrace level			
	➤ Discharge of pump	900 LPM	Provided	M.R.
	➤ Head of the pump	40 mtr	Provided	M.R.
	➤ Power supply	Required	Provided	M.R.
	➤ Auto Starting of pump	Required	Provided	M.R.
14.	Captive Water Storage for fire fighting.			
	Underground tank capacity	N.A.	N.A.	N.A.
	➤ Draw -off connection	N.A.	N.A.	N.A.
	➤ Fire service inlet	N.A.	N.A.	N.A.
	➤ Access to tank	N.A.	N.A.	N.A.
	➤ Overhead Tank Capacity	10,000 ltrs	20,000 ltrs	M.R.
15	Exit Signage.	required	Provided	M.R.
16	Provision of Lifts			

	• Communication In lift Car	N.A.	Provided	N.A.
	• Fireman's Grounding Switch	N.A.	Provided	N.A.
	• Lift Signage	N.A.	Provided	N.A.
17.	Standby power supply	Required	Provided	M.R
18.	Refuge Area			
	➤ Total Area	N.R.	N.R.	N.R.
	➤ Location	N.R.	N.R.	N.R.
19.	Fire Control Room			
	➤ Detector System Panel	N.R.	Provided	N.R.
	➤ Flow Switch Panel	N.R.	N.R.	N.R.
	➤ PA system Panel	N.R.	N.R.	N.R.
	➤ Batter backup	N.R.	N.R.	N.R.
	➤ Building Floor plans	N.R.	N.R.	N.R.
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R.	N.R.	N.R.

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/.

Signature of the Inspection Officer

Name Sunil Chawdhary

Designation DO (W)

Signature of the Inspection Officer

Name

Designation