

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/dfs/ms/2015/w2/1519

Dated: 21/08/2015

FIRE SAFETY CERTIFICATE

Certified that Pradeep Memorial, Comprehensive College of Education, Pratap Vihar, Kirari Extn, Nangloi, Delhi-110086 comprised of Ground + Three upper floors, owned / occupied by Pradeep Memorial, Comprehensive College of Education was issued fire safety certificate by this department vide letter no. F.6/DFS/MS/ 2010/2865 dated 01/10/2010. The premises was re-inspected by the officer concerned of this department on dated 29/07/2015 in the presence of Sh. Dhanraj Singh (Chairman) and observed that all the fire safety and fire prevention arrangements as provided in the premises is found in good working condition and there is no additional construction. The premises have therefore deemed complied with requirements under Rule 33 of Delhi Fire Service Rules, 2010 and building / premise is fit for occupancy Sub Group B-2 of Group B Education Building with effect from 21/08/2015 for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rule, 2010.

1. Means of escape shall not be kept locked or bolted from outside and shall be easily open able by guests in an event of emergency.
2. All employees shall be acquainted with the use and maintenance of all the fire fighting installation/equipments.
3. The fire suppression / protection arrangements provided in the guest house are to minimize losses, if maintained in good working condition. These systems cannot give any guarantee that there will be no fire or losses in the event of one.
4. Any loss of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the licensee.
5. This report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, Six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on....21/08/15.....at New Delhi.


(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250


Copy to:

1. The Chairman, Pradeep Memorial, Comprehensive Collage of Education, Pratap Vihar, Kirari Extn, Nangloi, Delhi-110086.

INSPECTION REPORTTwo blocks Interconnected
Gr. + Three upper floors

1. Name & address of the building : Pradeep Memorial, Comprehensive Collage of Education,
Pratap Vihar, Kirari Extn, Nangloi, Delhi-110086
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : Letter No. F.6/DFS/MS/ 2010/2865 dated 01/10/2010
5. Fire Safety directives letter No : NBC
6. Date of inspection : 29/07/2015
7. Name of the Inspecting Officers : ADO (BW)
8. Name and designation of officers
from the building side : Sh. Dhanraj Singh (Chairman)
9. Year of Construction : 2001
10. Applicant's letter No. : PMC/1024/2015 dated 09/06/2015

Plot Area:10000 sq mtr Covered Area:4863 sq mtr No. of Students:350 NO. of Class Rooms:
20 + 10 room for other purpose and 6 labs

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	4.50 mtr	6.00 mtr	MR
	• Width of internal road	6.00 mtr	6.00 mtr	MR
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	—	—	—
	• Upper Floors	02	03	MR
	• Basements	—	—	—
	b. Width of staircases	—	—	—
	• Upper Floors	1.50 mtr	1.40, 1.65 mtr 2.50 mtr ramp	MR
	• Basements	—	—	—
	c. Protection of exits	—	—	—
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	—	—	—
		02	P	MR
	g. Width of Corridor	—	—	—
	h. Door Size	Old Case	Old Case	Old Case

3	Compartmentation.	—	—	—
	• Fire check door	—	—	—
	• Sealing of electrical shafts	—	—	—
	• Fire Rating of shaft door	—	—	—
	• Water Curtain	—	—	—
	• Fire Dampers	—	—	—
4	Smoke Management System.			
	• Basements	30 a/c per hour	—	—
	• Upper floors	12 a/c per hour	—	—
5	Fire Extinguishers			
	• Total numbers	24 ABC	25	MR ✓
	• Types	ISI marked	ABC	MR
	• IS marking		Yes	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	One in each Blk	P	MR ✓
	• Length of hose reel hose	30 m	P	MR
	• Nozzle diameter	5 mm	P	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	—	—	—
	• Location of Main Panel	—	—	—
	• Location of Repeater Panel	—	—	—
	• Alternate source of power	—	—	—
	• Hooters' Location	—	—	—
8	MOEFA	—	—	—
9	Public Address System.	—	—	—
10	Automatic Sprinkler System.			
	• Basement	—	—	—
	• Upper Floor	—	—	—
	• Sprinkler above false ceiling	—	—	—
11	Internal Hydrants			
	• Size of riser/down-comer	100 mm	P	MR
	• Number of hydrants per floor	R	One at each floor One in each blk	MR ✓
	• Hose Box	R	One at each floor One in each blk	MR

12	Yard Hydrants.			
	• Total number of hydrants	—	—	—
	• Hose Box	—	—	—
13	Pumping Arrangements.			
	• Ground Level	—	—	—
	➤ Discharge of main Pump	—	—	—
	➤ Head of Main pump	—	—	—
	➤ Number of main pumps	—	—	—
	➤ Jockey Pump out put	2 X 180 LPM	P	MR ✓
	➤ Jockey pump head	40 M	P	MR
	➤ Standby Pump out put	—	—	—
	➤ Standby Pump Head	—	—	—
	➤ Auto Starting/ Manual stopping	—	—	—
	➤ Pump House Access	—	—	—
	• Terrace level	—	—	—
	➤ Discharge of pump	2 X 450 LPM	P	MR ✓
	➤ Head of the pump	40 M	P	MR
	➤ Power Supply	—	—	—
	➤ Auto Starting of pump	—	—	—
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	25,000 ltrs	P	MR
	➤ Draw-off connection	—	—	—
	➤ Fire service inlet	—	—	—
	➤ Access to tank	—	—	—
	• Overhead Tank capacity	2 X 5000 ltrs	2 X 5000 ltrs	MR
15	Exit Signage.	R	P	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	—	—	—
	• Pressurization of Lift lobby	—	—	—
	• Communication In lift Car	—	—	—
	• Fireman's Grounding Switch	—	—	—
	• Lift Signage	—	—	—
17	Standby power supply	R	P	MR

18	Refuge Area.			
	➤ Total Area	—	—	—
	➤ Location	—	—	—
19	Fire Control Room			
	• Detector System Panel	—	—	—
	• Flow Switch Panel	—	—	—
	• PA System Panel	—	—	—
	• Batter backup	—	—	—
	• Building Floor Plans	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	—	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide Letter No. F.6/DFS/MS/ 2010/2865 dated 01/10/2010. Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Note: Shortcoming issue by letter no. F.6/DFS/MS/2014/2320 dated 01/10/2014 have been removed.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Name

Designation

Designation

DO (NW)
 Singh
 11/8/15

Signature
 5/8/15
 400 (A10)



540/dfs/CSY
 12/8/15