

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub -rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/dfs/ms/school/2015/w2/1545

Dated: 26/8/15

FIRE SAFETY CERTIFICATE

Certified that the Beni pershad Jaipuria Public school Located at YP Block , Behind DDA Market , Pitampura Delhi , comprised of Ground + two upper floors, owned / occupied by Beni pershad Jaipuria Public school have complied with the fire prevention and fire safety requirements in accordance with the Circular No F16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011/ issued by Director of Education and verified by the officer concerned of Fire Service on 04-08-2015 in presence of Smt. Anjali (Principal) and that the building / premises is fit for the occupancy class "Educational" Group B Sub Division B - 1 with effect from 26/8/15 for a period of three years subject to compliance of the conditions mentioned below:-

Issued on 26/8/15.....at New Delhi by :-


Santokh Singh
Chief Fire Officer
Delhi Fire Service

OLC

Copy to

The Principal, Beni pershad Jaipuria Public School, YP Block, Behind DDA Market, Pitampura Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'F' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. Basement shall be used strictly as per building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: **Beni pershad Jaipuria Public School**
 Located at **YP Block, Behind DDA Market, Pitampura Delhi.**

2. Type of Occupancy : Educational (Ground + 2 Upper Floor)

3. Type of Case : New

4. Details of previous NOC : Letter No. Nil

5. Fire Safety directives Letter No. : 3298-3398 dated 01-03-2011

Plot Area - 799.15M ²
Covered Area -532.83 M ²
No. or Class Rooms-12
No. of Student- 175

6. Date of inspection : 04-08-2015

7. Name of the Inspecting Officer : DO/W& ADO (WP)

8. Name and designation of Officer

from the building side :Smt. Anjali (Headmistress)

9. Year of Construction : 2003

10. Applicant's letter No. : Nil Dated 14-07-2015

S No	Minimum standards on fire prevention and fire safety U/R 33	Cr.No.3298-3398 dated 01-03-2011	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • • Width of internal road 	Accessible	Provided	MR
		Accessible	Provided	MR
		NA	NA	NA
		NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	1	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1x1.50 mtr	2x140cm	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NR	NR	NR
	• Pressurization	NR	NR	NR
	d. No of continuous staircase to terrace			
	e. Width Of Corridor	NA	NA	NA
	f. Door Size(Class room)	1mtr	1X1 mtr(less than 45 student in all class room)	MR

3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door 	NA	NA	NA
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	NA	NA	NA
	<ul style="list-style-type: none"> • Water Curtain 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Dampers 	NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements 	NR	NR	NR
	<ul style="list-style-type: none"> • Upper floors 	NR	NR	NR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	4 nos.	5 Provided	MR
	<ul style="list-style-type: none"> • Types 	ABC & CO ₂	Provided ✓	MR
	<ul style="list-style-type: none"> • IS marking 	ISI marked	Provided ✓	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor 	one	Provided ✓	MR
	<ul style="list-style-type: none"> • Length of hose reel hose 	30m	Provided ✓	MR
	<ul style="list-style-type: none"> • Nozzle diameter 	5mm	Provided ✓	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors 	NA	NA	NA
	<ul style="list-style-type: none"> • Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> • Hooters' Location 	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements 	NA	NA	NA
	<ul style="list-style-type: none"> • Upper Floor 	NA	NA	NA
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	NA	NA	NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	NA	NA	NA
	<ul style="list-style-type: none"> • Number of hydrants per floor 	NA	NA	NA
	<ul style="list-style-type: none"> • Hose Box 	NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> • Hose Box 	NA	NA	NA

13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		450 lpm	Provided	MR
		40Mtr	Provided	MR
		NA	NA	NA
		Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		10,000Ltr	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 	NA	NA	NA
		NA	NA	NA
19.	Fire control room			
	<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Battery backup ➤ Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
-----	--	----	----	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers.....NIL.

Signature of the Inspecting Officer

Udai Vir Singh
13/8/15

Signature of the Inspecting Officer

Sh. Sumil Chaudhary
13/8/15

Name

Udai Vir Singh

Name

Sh. Sumil Chaudhary

Designation

ADO/WP

Designation

DO/W

0