

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2015 / *School/w2/1542*

Dated: *26/08/2015*

FIRE SAFETY CERTIFICATE

Certified that the Little Star Convent School located at Parasram Enclave, Burari, Delhi comprised of Ground and first floors was granted FSC by this department vide letter No F 6 / DFS / MS / 2012/school/2782 dated 27.07.2012. The premises was re-inspected by the officer concerned of this department on 22.07.2015 in the presence of Sh. S.K.Tyagi/ Manager and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy Group B Educational with effect from *..26/08/15* for a period of three years, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

8. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
9. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
10. The trained fire fighting staff should be available round the clock.
11. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
12. This certificate cannot be treated in any case for regularizations of unauthorized construction.
13. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
14. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on *..26/08/15* at New Delhi


(SANTOKH SINGH)
Chief Fire Officer
Ph:-011-23414250

Copy to : -

3. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 54.
4. The Manager, Little Star Convent School, Parasram Enclave, Burari, Delhi – 110084.

M/11

INSPECTION REPORT

1. Name & address of the building : Little Star Convent School, Parasram Enclave, Burari, Delhi-110084
2. Type of Occupancy : Educational
3. Type of Case : Old case (addition of 07 class rooms at ground & first floor)
4. Details of previous NOC : F.6/DFS/MS/2012/School/2782 dated 27/07/2012
5. Fire Safety directives letter No : Director of Education Circular dated 01.03.2011
6. Date of inspection : 13/05/2015
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers from the building side : Mr S. K.Tyagi (Manager)
9. Year of Construction : 2002/ 2013 (Add/alt)
10. Applicant's letter No. : Nil dated 10/07/2015

Plot Area-1584 sqm Covered Area:1218.64 sq.m, Ground & first floor, class rooms -19 nos

	Minimum Standards on fire prevention and fire safety U/R 33	Circular of Director of Education	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6m	6m	MR ✓
	• Gate width	NA	4.5m	NA
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	03	MR ✓
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m	1.50m, 1.08m x 2	MR ✓
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	1 m	1 m in each class room (less than 45 students)	MR ✓
	f. Door Size			

N/12

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	NA	NA
		12 a/c per hour	Natural Ventilated	MR
5	Fire Extinguishers			
-	<ul style="list-style-type: none"> • Total numbers • Types • ISI marking 	08nos	12 nos	MR
		ABC/CO2	ABC—8, Co2-4	MR
		ISI Marked	Yes	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	NA	01no	NA
		NA	30m	NA
		NA	5mm	NA
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			

	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 			
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		NA	225lpm	NA
		NA	40m	NA
		N/A	P	N/A
		N/A	P	N/A
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	2,500ltrs	NA
15	Exit Signage.	N/A	N/A	N/A
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby 	N/A	N/A	N/A
		N/A	N/A	N/A


2/14

	<ul style="list-style-type: none"> • Communication In lift Car 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fireman's Grounding Switch 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Lift Signage 	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Flow Switch Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • PA System Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Batter backup 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Building Floor Plans 	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A


As per the FSC issued vide this department letter of even no. 2782 dated 27.07.2012 the school premise was comprised of two blocks i.e (ground floor block & ground & first floor block with 12 nos of class room & 01 office). Now at the time of inspection it has observed that the party has added total 07 class rooms (03 nos at ground floor and 04 nos at first floor of the building) and the both of the block have been merged in a single block provided with 03 nos of staircases with width of 1.50m, 1.08m & 1-08m respectively.

The fire protection systems provided in the building were tested/ checked randomly and found in working condition.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, fire safety certificate is recommended.


 Signature of the Inspecting Officer
 Name :- Rajesh Kumar

Designation:- ADO/RN


 20/11/2014