

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.**

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593

No. F.6/DFS/MS/School/2015/ 52/1548

Dated: 27/08/15

FIRE SAFETY CERTIFICATE

Certified that the building of **Pragati Public School** located at Sector-13, Phase-II, Dwarka, New Delhi-110078 having two blocks. Each block is comprised of ground floor plus three upper floors was issued NOC by this department vide letter No.F.6/DFS/MS/School/2012/2214 dated 20.06.2012. The School building was re-inspected by the officer concerned of this department on 13.08.2015 in the presence of Mrs. Geeta Kapoor (Principal) and found that the school management have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class Educational w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....27/08/15.....at New Delhi.



(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph:- 011-23414333

Copy to:-

1. The Principal,
Pragati Public School, Sec-13,
Ph-II, Dwarka, New Delhi-110078.
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi – 110 054.



Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/ occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Pragati Public School, Sec-13, Phase-II, Dwarka, New Delhi-78,
2. Type of Occupancy : Educational (School)
3. Type of Case : Renewal
4. Details of Previous NOC : F.6/DFS/MS/School/2012/2214 dated 20.06.2012
5. Fire Safety directives letter No : NA
6. Date of inspection : 13/08/2015
7. Name of Inspecting Officer : D.O S.K. Tomar
8. Name and designation of officers
From the building side : Mrs. Geeta Kapoor (Principal)
9. Year of Construction : Before 2005
10. Applicant's letter No. : PPS/2015-16/4543 dated 15.07.2015

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site special area	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible -- ---	18 mtr 5.50 mtr each 4.50 mtr	MR MR (02 Gates) MR
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	Three NA	Three, 01 ramp NA	MR No Basement
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	150 cms each NA	177 cms each, ramp width 182 cms NA	MR No Basement
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	NA NA	NA NA	NA NA
	d. No. of continuous staircases to terrace			
		---	One	MR
	e. Width of Corridor			
		---	165, 182 cms	MR
	f. Door Size			
		1.0 Mtr.	110cm X 202 cm	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 ACPH 12 ACPH	NA Natural Ventilation	No Basement MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	06 at each floor ABC ISI marked	Provided Provided Provided	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	Four 30 m 5 mm	Provided Provided Provided	MR MR MR

INSPECTION REPORT

1. Name & address of the building : Pragati Public School, Sec-13, Phase-II, Dwarka, New Delhi-78,
2. Type of Occupancy : Educational (School)
3. Type of Case : Renewal
4. Details of Previous NOC : F.6/DFS/MS/School/2012/2214 dated 20.06.2012
5. Fire Safety directives letter No : NA
6. Date of inspection : 13/08/2015
7. Name of Inspecting Officer : D.O S.K. Tomar
8. Name and designation of officers
From the building side : Mrs. Geeta Kapoor (Principal)
9. Year of Construction : Before 2005
10. Applicant's letter No. : PPS/2015-16/4543 dated 15.07.2015

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site special area	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible -- ---	18 mtr 5.50 mtr each 4.50 mtr	MR MR (02 Gates) MR
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	Three NA	Three, 01 ramp NA	MR No Basement
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	150 cms each NA	177 cms each, ramp width 182 cms NA	MR No Basement
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	NA NA	NA NA	NA NA
	d. No. of continuous staircases to terrace	---	One	MR
	e. Width of Corridor	---	165, 182 cms	MR
	f. Door Size	1.0 Mtr.	110cm X 202 cm	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 ACPH 12 ACPH	NA Natural Ventilation	No Basement MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	06 at each floor ABC ISI marked	Provided Provided Provided	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	Four 30 m 5 mm	Provided Provided Provided	MR MR MR

7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
8.	MOEFA	NA	Provided	MR
9.	Public Address System	NA	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basement 	NA NA	NA NA	No Basement NA
	<ul style="list-style-type: none"> • Ground Floor • Sprinkler above false ceiling 	NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	NA NA NA	NA NA NA	NA NA NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	NA NA	One One	MR MR
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/Manual Stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	NA NA NA NA NA NA NA NA NA NA 450 LPM 30 M Required NA	NA NA NA NA NA NA NA NA NA NA 450 LPM 30 M Provided NA	NA NA NA NA NA NA NA NA NA NA MR MR MR NA
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity <ul style="list-style-type: none"> ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA NA NA NA 10000 ltr Required	NA NA Provided NA 15000 ltr. Provided	NA NA MR NA MR MR
15.	Exit Signage.			
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	NA NA NA NA NA	NA NA NA NA NA	No Lift -do- -do- -do- -do-

17.	Standby power supply	Required	D.G Set of 75 KVA	MR
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F.6/DFS/MS/School/2012/2214 dated 20.06.2015 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.


18/8/15

Signature of Inspecting Officer

Name:- S.K. Tomar

Designation:- Divisional Officer


Signature of Inspecting Officer

Name

Designation


Dy.CFO (South)