

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

No. F6/DFSS/MS/school/2015/1402/1575

Dated: 01/09/15

FIRE SAFETY CERTIFICATE

Certified that the Adarsh Vidya Niketan Public School, 25, Shiv Mandir Gali, Maujpur, Delhi-53, comprised of ground plus one upper floor was granted NOC by this department vide Letter No-F.6/MS/DFSS/2008/407 dated 15.02.2008. School building was re-inspected by the officer concerned of this department on 25.08.2015 in the presence of Headmaster of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular No. 262-362 dated 17.01.2005 issued by the Director of Education and found that the building having GF+FF is fit for occupancy Group B "Educational Building" with effect from ..01/09/15.. renewed for a period of three years, subject to conditions printed overleaf.

Issued on.....01/09/15.....at New Delhi by

(Dr. G.C. Misra)

Chief Fire Officer

Ph -011- 23414333

O/C Star

To,

The Principal

Adarsh Vidya Niketan Public School, 25, Shiv Mandir Gali, Maujpur, Delhi-53

Copy to:-

The Director of Education,

East Delhi Municipal Corporation,

419, Udyog Sadan, Patparganj Industrial Area, Delhi-92

### CONDITIONS:

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

### INSPECTION REPORT

1. Name & address of the building : Adarsh Vidya Niketan Public School, 25, Shiv Mandir Gali Maujpur, Delhi-53.
2. Building is comprised of : G+1
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/MS/DFSS/2008/407 dated 15.02.2008
6. Fire Safety direction letter No : Old requirements  
(Circular No. 262-362 dated 17.01.2005)
7. Date of Inspection : 25.08.2015
8. Name of the Inspecting Officers: : Suresh Singh (ADO)
9. Name of the designation of Officer  
from the building side : Headmaster
10. Year of Construction : 1991
11. Applicant's letter No : Dated 22.07.2015

S.No	Minimum Standards on fire safety requirements as per circular no. 262-362 dated 17.01.2005	Old Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	5 m	MR/Old Case
	Gate width	N.A.	N.A.	N.A.
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	Upper Floor	1 no.	2 no.	MR
	Basement	N.A.	N.A.	N.A.
	B. Width of Staircases			
	Upper Floor	1.5 m	1.25 m, 0.95 m	MR
	Basement	N.A.	N.A.	N.A.
	c. Protection of exits			
	Fire check door	N.A.	N.A.	N.A.
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	1 no.	1 no.	MR
	g. Width of Corridor	1.5 m	1.5 m	MR
	h. Door Size	1 m	1 m	MR
3	Compartmentation			
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	N.A.	N.A.	N.A.
	Upper floor	N.A.	N.A.	N.A.



5.	Fire Extinguisher			
	Total numbers	04 no.	06 no.	MR
	types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	01 no.	01 no.	MR
	Length of hose reel hose	30 m	30 m	MR
	Nozzle diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters's location	N.A.	N.A.	N.A.
8	MOEFA	N.A.	NA	NA
9	Public address System.	N.A.	NA	NA
10	Automatic Sprinkler System.			
	basement	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	N.A.	N.A.	N.A.
	Number of hydrants per floor	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	• Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	• Terrace Level			
	➤ Discharge of pump	220 LPM	220 LPM	MR
	➤ Head of the Pump	40 m	40 m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR

2/4

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	2500 Liters	2500 Liters	MR
15	Exit Signage.			
		N.A.	N.A.	N.A.
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply			
		N.A.	N.A.	N.A.
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:			
		N.A.	N.A.	N.A.

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules the NOC issued vide letter no. F.6/MS/DFSS/2008/407 dated 15.02.2008 under the circular No. 262-362 dated 17.01.2005 It is recommended to grant Fire Safety Certificate.

*Singh*  
25.8.15

Signature of the Inspecting Officer

Name Suresh Singh

Designation ADO (Shah)

DO (EAST)

*Submitted for approval please.*

*Mingh*