

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS : DELHI FIRE SERVICE: NEW DELHI-110001

No. FC/DFS/MS/2015/1598

Dated: 04/09/15


FIRE SAFETY CERTIFICATE

Certified that the Moments Bar & Lounge ( A unit of Aemaan Enterprises) situated at F-101, 102, 103,104 First Floor North Square Mall, Netaji Subhash Palace, Pitam Pura, New Delhi was inspected by the officer concerned of this department on 18.08.2015 in the presence of Mr. **Manoj** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have therefore, deemed complied with Rule 33 of the Delhi Fire Service Rule 2010 and thus the building / premises is fit for occupancy **Class - D (Assembly)** with effect from 04/09/15 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules,2010.

Following fire safety directives must be adhered to:-

- 1) All the means of escape shall be kept free of all type of obstruction all the time.
- 2) All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
- 3) All the fire fighting equipment shall be maintained in perfect working condition all the time and lapse rendering non-functional of fire safety measures, management shall be responsible.
- 4) Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
- 5) Basement shall be used as per NBC.
- 6) This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
- 8) "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

Issued on.....04/09/15.....at New Delhi by

  
(Santokh Singh)  
Chief Fire Officer  
Delhi Fire Service

Tel . -011-23424250

Copy to:

1. Moments Bar & Lounge ( A unit of Aemaan Enterprises) situated at F-101,102,103,104 First Floor North Square Mall, Netaji Subhash Palace, Pitam Pura, New Delhi.
2. Dy. Health Officer ,North Delhi M.C.D. Civil Line,Zone New Delhi.
3. Joint Commissioner of Police, Licensing, 1st Floor P.S. Defence Colony New Delhi.

M/S

**INSPECTION REPORT**

1. Name & address of the building : Moments Bar & Lounge(A unit of Armaan Enterprises), North Square Mall, F-101,102,103,104, First floor Netaji Subhash Place, Pitampura, Delhi-110034
  2. Type of Occupancy : Class D (Assembly)
  3. Type of Case : New
  4. Details of previous NOC : N.A.
  5. Fire Safety directives letter No. : NBC Part-IV
  6. Date of inspection : 18-08-2015
  7. Name of the Inspecting Officers : Sunil Chawdhary DO (M.N.)
  8. Name and designation of officers : Mr. Manoj
- From the building side :
9. Year of Construction : 2004-05 (mall)
  10. Applicant's letter No. : No. 13277-83/Jt. C.P/Lic. (Amst.) dated 03/08/2015

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>	<b>Common with Mall</b>		
	• Road width	24 mtrs.	provided ✓	M/R
	• Gate width	06 mtrs	06 mtrs ✓	M/R
	• Width of internal road	06 mtrs.	06 mtrs ✓	M/R
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	06	06 ✓	M/R
	• Basement	7 + one ramp	07 + 01 ramp ✓	M/R
	b. Width of staircases			
	• Upper Floors	1.5 mtr each	Provided ✓	M.R.
	• Basement	1.5 mtr each	Provided ✓	M.R.
	c. Protection of exits			
	• Fire check door			
	• Pressurization	Required	Provided ✓	M.R.
	d. No. of continuous staircases to terrace	Required	Provided ✓	M/R
	e. Width of Corridor	Required.	Provided.	M.R.
	f. Door size	N.A 1x2mtr, 1x1.25 mtr	N.A Provided ✓	N.A M.R Restaurant. ✓
3.	<b>Compartmentation.</b>			
	• Fire check door	Required	Provided	M.R.
	• Sealing of electrical shafts	Required	Provided	M.R.
	• Fire Rating of shaft door	Required	Provided	M.R.
	• Water Curtain	N.A	N.A	N.A.
	• Fire Dampers	Required	Provided	M.R.
4.	<b>Smoke Management System.</b>	<b>Common with Mall</b>		
	• Basements	30 a/c per hour.	Provided.	M.R.

	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	02 ABC & CO <sub>2</sub> & WCO <sub>2</sub> ISI marked	03 Provided Provided Provided	M.R. M.R. M.R.
6.	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	04 for Mall, 01 near restaurant 36 m 5 mm	Provided Provided Provided	M.R. M.R. M.R.
7.	<b>Automatic fire detection and alarming system. Common with Mall</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooter's Location</li> </ul>	Smoke & Heat. Required Required Required Required	Provided Provided Provided Provided Provided	M.R. M.R. M.R. M.R. M.R..
8.	<b>MOEFA</b>	Required	Provided	M.R.
9.	<b>Public Address System</b>	Required	Provided	M.R.
10.	<b>Automatic Sprinkler system</b>	Common with Mall		
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	Required. Required Required	N R. Provided Provided	N R. M.R. M.R.
11.	<b>Internal Hydrants</b>	<b>Common with Mall</b>		
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	150 mm 04 Required	provided provided provided	M.R. M.R. M.R.
12.	<b>Yard Hydrants.</b>	<b>Common with Mall</b>		
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	Required. Required.	Provided Provided	M.R. M.R.
13.	<b>Pumping Arrangements.</b>	<b>Common with Mall</b>		
	<b>Ground Level</b>			
	➤ Discharge of main pump	2850 LPM	Provided	M.R.
	➤ Head of Main pump	70 m	Provided	M.R.
	➤ Number of main pumps	02	Provided	M.R.
	➤ Jockey Pump out put	180 LPM	Provided	M.R.
	➤ Jockey pump head	70 m	Provided	M.R.
	➤ Standby pump out put	2850 LPM	Provided	M.R.
	➤ Standby pump Head	70m	Provided	M.R.
	➤ Auto Starting/Manual stopping	Required	Provided & functional	N.R.
	➤ Pump Hose Access	Required	Provided	M.R.
	<b>Terrace level</b>			
	➤ Discharge of pump	450 LPM	Provided	M.R.

	<ul style="list-style-type: none"> <li>➤ Power supply</li> <li>➤ Auto Starting of pump</li> </ul>	Required	Provided	M.R.
<b>14.</b>	<b>Captive Water Storage for fire fighting.: Common with mall</b>			
	<b>Underground tank capacity</b>	1,00,000 ltr	Required.	M.R.
	<ul style="list-style-type: none"> <li>➤ Draw -off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>➤ Overhead Tank Capacity</li> </ul>	Required.	Required.	M.R.
		Required.	Required.	M.R.
		Required.	Required.	M.R.
		30,000 Ltrs.	Provided	M.R..
<b>15</b>	<b>Exit Signage.</b>	required	Provided	M.R.
<b>16.</b>	<b>Provision of Lifts</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	Required	Provided	M.R.
		Required	Provided	M.R.
		Required	Provided	M.R.
		Required	Provided	M.R.
		Required	Provided	M.R.
<b>17.</b>	<b>Standby power supply</b>	Required	Provided	M.R
<b>18.</b>	<b>Refuge Area</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	N.A	N.A	N.A.
		N.A	N.A	N.A.
<b>19.</b>	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>➤ Detector System Panel</li> <li>➤ Flow Switch Panel</li> <li>➤ PA system Panel</li> <li>➤ Batter backup</li> <li>➤ Building Floor plans</li> </ul>	Required.	Provided	M.R.
		Required.	Provided	M.R.
		Required.	Provided	M.R.
		Required.	Provided	M.R.
		Required.	Provided	M.R.
<b>20.</b>	Special Fire Protection Systems for Protection of special Risks, if any:	Co2 flooding system for HT & LT panel Required.	Provided	M.R.

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

C.Fd 1960  
24/01/15



Signature of the Inspection Officer

Signature of the Inspection Officer