

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/2015/MD2/1627

Dated: 08/09/15

FIRE SAFETY CERTIFICATE

Certified that the Ahlcon Public School at Mayur Vihar Phase -1, Delhi -91, owned/occupied by Ahlcon Public School, comprised of basement, ground plus three upper floors was granted fire safety certificate vide letter no.F6/DFS/MS/School/2012/3947 dated 23.10.12. The School building was inspected by the officer concerned of this department on 07.08.15 in the presence of Sh.P.K.Bhatnagar (Manager) of school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of condition under rule 38 and that the B+GF+FS+SF+TF of building is fit for occupancy Group B "Educational Building" with effect from ...08/09/15... for a period of three years, subject to conditions printed overleaf.

Issued on ...08/09/15... at New Delhi by



(Dr.G.C.Misra)
Chief Fire Officer
Ph.011-23414333

To,
The Manager
Ahlcon Public School
Mayur Vihar Phase -1, Delhi -91

Copy to:-
The Dy. Director of Education
D-Block, Anand Vihar, Delhi.

Copy

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. Basement shall be used as per BBL.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"

1. Name & address of the building : Ahlcon Public School ,Mayur Vihar Phase-1, Delhi -91.
2. Building is comprised of : B,G +2, upper floor.
3. Type of Occupancy : Educational
4. Type of Case : Renewal ✓
5. Details of Previous FSC : F.6/DFS/MS/School/2012/3947 dated 23.10.12
6. Fire Safety direction letter No : NBC Part IV
7. Date of Inspection : 07.08.15
8. Name of the Inspecting officers : DO Virendra Singh
9. Name and designation of Officer:
from the building side : Sh.P.K.Bhattnagar (Manager).
10. Year of Construction : 1988-1991
11. Applicant's letter No : Nil dated 02.07.2015

NO.	Minimum Standards on fire prevention and fire safety U/R33	NBC Part iv	Provided at Site	Remarks
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	06 Mtrs.	15 Mtrs.	MR
		4.5 M	4.5 M	MR
		N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	04 (Four) Nos+1Ramp	05 Nos+1Ramp	MR
	B. Width of Staircases			
	<ul style="list-style-type: none"> • Upper Floor 	05 Nos	05 Nos.	MR
		1.5 M	2 nos of 1.70 M, 2 nos of 02 M, 1 no. of 86 CM & 1 Ramp 1.5 m	MR
	<ul style="list-style-type: none"> • Basement 	1.5 M	3 nos. of 1.70 m & 2 nos. of 02m	MR
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A	N/A	N/A
		N/A	N/A	N/A
	d. No. of continuous staircases to terrace	2 nos.	3 Nos.	MR
	e. Width of Corridor	1.5 M	1.70 M	MR
	f. Door Size	1.0 Mtrs	1.0 Mtrs	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basement • Upper floor 	Required	Provided	MR
		Required	Provided	MR
5.	Fire Extinguisher			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	30 Nos.	35 Nos.	MR
		ABC & Co2	ABC & Co2	MR
		ISI marked	ISI marked	MR

N/10

6	First-aid-Hose Reels.			
	Total numbers of each floor	3 nos.	3 nos.	MR
	• Length of hose reel hose	30 M	30 M	MR
	• Nozzle diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	2x 450 LPM	450& 900 LPM	MR
	➤ Head of the Pump	40 M	40 M	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Auto	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	15,000 Ltrs.	20,000 Ltrs.	MR

		Required	Provided	MR
15	Exit Signage.			
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The fire safety certificate issued vide letter no. F.6/DFS/MS/School/2012/3947 dated 23.10.12 is recommended.

Submitted please.

Virendra Singh
 Signature of the Inspecting Officer
 Name:-Virendra Singh
 Designation:-DO (ED)

~~DCFO(NDZ)~~