

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI – 110001**

No. F.6/DFS/MS/SZ/ *Cinema/2015/1675*

Dated: *14/09/15*

FIRE SAFETY CERTIFICATE

Certified that Satyam Cineplexes Mall Area (Superior Films Pvt.Ltd), located at Plot No-45, Nehru Place, New Delhi 110019, comprised of basements ground plus two upper floors was Own /Occupied by Superior Films Pvt.Ltd. was granted NOC by this department vide letter No. F6/MS/DFS/Cinema/06/3204 dated: 30/10/2006 was re-inspected by the officers concerned of this department on 07/09/2015 in the presence of Mr. Jitender Pasricha and observed that fire safety norms as required under Rule 33 of Delhi Fire Service Rules, 2010 are deemed complied and that the building / premises is fit for occupancy (Mixed Occupancy-Marcantile & Assembly) with effect from *14/09/15* for a period of **03** years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010.

Issued on*14.09.15*..... at New Delhi by


(Dr. G. C. Misra)
Chief Fire Officer
Tel: 011-23414333

7C *by* *100 (REP)*

Copy to: -

Mr. Subash Chachra (Director)
Superiors Film Pvt. Ltd.
Plot No -45, Nehru Place,
New Delhi-110019

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building:- Superior Films Pvt.LTD(Satyam Cineplexes) Mall Area,Plot No-45, Nehru Place,New Delhi 110019
2. Type of occupancy:- Mixed Occupancy (Mercantile & Assembly)
3. Type of case: -Renewal
4. Details of previous NOC: - F6/MS/DFS/Cinema/06/3204 dated :30/10/2006
5. Fire safety directives No.- F.6/MS/DFS/BP/2003/2638 dated 27/10/2003
6. Date of inspection:- 07/09/2015
7. Name of the inspecting officer:- Atul Garg DCFO (SZ) ,D.B.Mukherjee, A.D.O.(BCP)
8. Name & designation of officer From the building side: - Mr. Jitender Pasricha
9. Year of construction:- 2006
- 10.Applicant's letter No:- Nil dated: 29/07/2015

Building is comprised of Basement, Ground + 02 Upper Floors.

Sl. No	Minimum Standards on fire Prevention and fire safety U/R 33	BBL/NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	18mtr	Provided	MR
	2) Gate width	Required	Approchabel By Road	MR
	3)Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	05nos	G to F Floor 02no G to Terrace 01no G to Audi Block 02 no	MR
	2. Basements	03nos	Provided 03 nos.	MR
	B. Width of staircase			
	1. Upper floors	2mtr	G to F Floor 2m & 2.70m G to Terrace 2m G to Audi Block 2m & 2m	MR
	2. Basements	2mtr	2 m each	MR
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	Required	Provided	MR
	D. No. of continuous staircase to terrace	01nos	01 nos.	MR
	E. Width of corridor	Old Case	Provided	MR
	F. Door size	Old Case	Provided	MR
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	Required	Provided	MR
	4) Water curtain	Required	Provided	MR
	5) Fire Dampers	Required	Provided	MR
4.	Smoke Management System			
	1) Basements	30 a/c per hour	Exhaust Fan	MR
	2) Upper floors	12 a/c per hour	Natural	MR
5.	Fire Extinguishers			
	1) Total numbers	ISI Marked	50 Nos. Provided	MR
	2) Types		ABC, Co2	MR
	3) ISI marking		Yes	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	B01no,G to 2 nd Floor 2no	B0 1no,G to 2 nd Floor 2no	MR
	2) Length of hose reel hose	30 m	Yes	MR
	3) Nozzle diameter	5 mm	Yes	MR

7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Smoke & Heat	Provided	MR
	2) Location of main panel	Required	Provided in basement	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	Required	Provided at each floor	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	Required	Provided	MR
	3) Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 MM	Provided	MR
	2) Number of hydrants per floor	B 01no,G to F Floor 2no	B 01no,G to F Floor 2no	MR
	3) Hose box	01Nos	Provided	MR
12.	Yard Hydrants			
	1) Total number of hydrants	Required	Provided	MR
	2) Hose box	Required	Provided	MR
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	2850 Lpm	4740Lpm	MR
	b) Head of main pump	60m	60m	MR
	c) Number of main pump	01no	Provided	MR
	d) Jockey pump out put	180Lpm	180 Lpm	MR
	e) Jockey pump head	60mtr	60mtr	MR
	f) Stand by pump output	2850LPM	3000 Lpm	MR
	g) Stand by pump head	60mtr	60mtr	MR
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.Captive Water Storage for Fire Fighting				
	1) Under ground tank capacity	1,00,000ltr	Provided	MR
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	50,000 Ltrs.	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided DG Set	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A

19.	Fire Control Room			
	a) Detector system panel	Required	Provided	MR
	b) Flow switch panel	Required	Provided	MR
	c) PA system panel	Required	Provided	MR
	d) Battery backup	Required	Provided	MR
20.	Special Fire Protection System for Protection of special Risk, if any:		Provided	MR
				N/A

The fire protection system provided in the building were tested and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F6/MS/DFS/Cinema/06/3204 dated: 30/10/2006, renewal under rules 35 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly DFA is put up for perusal and signature pl.

Signature of the inspecting officer

Atul Garg
8/9/15

Name :- Atul Garg
Designation:- DY.CFO(SZ)

Signature of the inspecting officer

D.B. Mukherjee
8/9/15

Name: - D.B.Mukherjee.
Designation:- A D O (BCP)