

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2015 / 1696

Dated: 16 / 9 / 2015

FIRE SAFETY CERTIFICATE

Certified that the Mount Sinai Public School located at Street no 30, B- Block, Sant Nagar, Delhi-110084 comprised of Ground floor only have complied with the fire prevention and fire safety requirements in accordance with circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and verified by the officer concerned of Fire Service on 24.08.2015 in the presence of Mrs Bimla Devi, Principal and the building/ premise is fit for occupancy class Group "B" Educational with effect from 16/09/15..... for a period of three years, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
8. The number of students in the class rooms shall not be more than 45 as there are single exit door in class room.

Issued on ...16/9/15..... at New Delhi


16/9
Santokh Singh
Chief Fire Officer
Ph:-011-23414250

Copy to : -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 54.
2. The Principal, Mount Sinai Public School, Street no 30, B Block, Sant Nagar, Delhi.

N/S

INSPECTION REPORT

1. Name & address of the building : Mount Sinai Public School, Street no 30, B Block, Sant Nagar,, Delhi-84.
 2. Type of Occupancy : Educational (Ground Floor only)
 3. Type of Case : New Case
 4. Details of previous NOC : Nil
 5. Fire Safety directives letter No : Director of Education Circular dated 01.03.2011
 6. Date of inspection : 24/08/2015
 7. Name of the Inspecting Officers : ADO (RN)
 8. Name and designation of officers from the building side : Ms Bimla Devi, Principal
 9. Year of Construction : 2002
 10. Applicant's letter No. : Nil
- Plot Area-500 yards Covered Area:350 Yards, Class rooms -07 nos No. of Student - 230

	Minimum Standards on fire prevention and fire safety U/R 33	Circular of Director of Education	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible	6.0m ✓	MR
		NA	NA	NA
		NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
f. Door Size	1 m	1 m	MR ✓	
3	Compartmentation.			

	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	NA	NA	NA
		NA	NA	NA
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • ISI marking 	02nos	05 nos	MR
		ABC/Co2	ABC—3, CO2—02	MR
		ISI Marked	Yes	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	NA	NA	NA

N/8

	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	Inverter	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

Note:- General requirements as per director of Education letter dated 01.03.2015

- | | |
|---|--------------------------------|
| 1. Escape route—clear | 2. LPG cylinder in Lab---NA |
| 2. Electric wiring—concealed | 4. ELCB/MCB—provided |
| 5. Electric meter board—not under staircase | 6. Emergency Tel Nos—Displayed |
| 7. Generator set ----- No | 8. Basement use as per BBL--NA |

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection. The party has complied shortcomings/ observations issued by this department letter of even no. 1125 dated 23.05.2015.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, fire safety certificate is recommended.

D. J. K. S.
Rajesh

RK
04/9/2015
Signature of the Inspecting Officer
Name: - Rajesh Kumar
Designation: - ADO/RN