

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/Hospital/2015/1704

Dated: 17/08/2015

FIRE SAFETY CERTIFICATE

Certified that Bhagwati Hospital located at CS/OCF-6, Sec- 13, Rohini, Delhi-110085 comprised of Basement + Ground + Three upper floors owned and occupied by (A Unit of Sarvodaya Health Foundation, Delhi was issued NOC vide this office letter No F6/DFS/MS/2012/Hospital/2876 dated 07/08/2012. The premises was re-inspected by the officer concerned of this department on 27/07/2015 in the presence of Mr. Naresh Pamnani and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premises have therefore, deemed complied with the requirement under Rule 33 of the Delhi Fire Service rule 2010 and the building / premise is fit for occupancy class institutional (Hospital) with effect from 17/08/2015 for a period of three years in accordance with rule 36 unless renewed under rules 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi fire Service Rules, 2010.

1. Means of escape shall not be kept locked or bolted from outside and shall be easily open able by guests in an event of emergency.
2. All employees shall be acquainted with the use and maintenance of all the fire fighting installation/equipments.
3. The fire suppression / protection arrangements provided in the guest house are to minimize losses, if maintained in good working condition. These systems cannot give any guarantee that there will be no fire or losses in the event of one.
4. Any loss of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the licensee.
5. Basement shall be used as per NBC.
6. This report may not in any way be treated as regularization of unauthorized construction, if any.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on...17/08/15.....at New Delhi.


(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250

Copy to:

1. The, Dr_Naresh Pamnani, Medical Superintendent, Bhagwati Hospital CS/OCF-6, Sec- 13, Rohini, Delhi-110085

INSPECTION REPORT**(Basement + Ground + 03 floors)**

1. Name & address of the building : Bhagwati Hospital CS/OCF-6, Sec- 13, Rohini, Delhi.
2. Type of Occupancy : **Institutional**
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2012/Hospital/2876 dt 07/08/2012
5. Fire Safety directives letter No : F6/DFS/MS/BP/99/Hospital/1377 dated 25/10/1999
6. Date of inspection : 27/07/2015
7. Name of the Inspecting Officers : DO (NW)
8. Name and designation of officers
from the building side : Mr. Naresh Pamnani
9. Year of Construction : 2003
10. Applicant's letter No. : Nil dated 29/06/2015

| | Minimum Standards on fire prevention and fire safety U/R 33 | F6/DFS/MS/BP/99 /Hospital/1377 dated 05/10/1999 | Provided at site | Remarks MR/NMR |
|---|--|---|--------------------------|-----------------------|
| 1 | Access to building | (old case) | | |
| | • Road width | 06 mtr | 18 mtr | M/R |
| | • Gate width | 05 mtr | Provided | M/R |
| | • Width of internal road | N/A | N/A | N/A |
| 2 | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | --- | --- | --- |
| | • Upper Floors | 02 no's S/C | 02 no's S/C | M/R |
| | • Basements | 01 no's + 01 ramp | 01 no's + 01 ramp | M/R |
| | b. Width of staircases | | | |
| | • Upper Floors | 2 mtr each | 2 mtr & 1.10 mtr | M/R (old case) |
| | • Basements | 02 mtr each & 01 ramp | 1.48 mtr & ramp 2.60 mtr | M/R (old case) |
| | c. Protection of exits | | | |
| | • Fire check door | R | Provided | M/R |
| | • Pressurization | N/A | N/A | N/A |
| | e. No. of continuous staircases to terrace | 02 | 02 | M/R |
| | g. Width of Corridor | 2.00 mtr | 2.00 mtr | M/R |
| | h. Door Size | old case | old case | old case |
| 3 | Compartmentation. | | | |

| | | | | |
|----|---|---------------------|--------------------------------------|------------|
| | <ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers | R | P in basement | M/R |
| | | R | P | M/R |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| 4 | Smoke Management System. | N.R | | |
| | <ul style="list-style-type: none"> • Basements • Upper floors | 30 a/c per hour | Exhaust fan provided | M/R |
| | | 12 a/c per hour | N/A | N/A |
| 5 | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> • Total numbers • Types • IS marking | 52 | Provided | M/R |
| | | ISI marked | Wco2, Co2, CO2 AFFF & ABC type | M/R |
| | | | Yes | M/R |
| 6 | First-Aid Hose Reels. | | | |
| | <ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter | 01 no's | P | M/R |
| | | 30 m | P | M/R |
| | | 5 mm | P | M/R |
| 7 | Automatic fire detection and alarming system. | | | |
| | <ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location | Smoke detector | P | M/R |
| | | G.F | P | M/R |
| | | --- | --- | --- |
| | | R | P | M/R |
| | | Strategic locations | P | M/R |
| 8 | MOEFA | R | P & F | M/R |
| 9 | Public Address System. | R | P & F | M/R |
| 10 | Automatic Sprinkler System. | | | |
| | <ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling | R | P | M/R |
| | | N.R | — | — |
| | | N.R | — | — |
| 11 | Internal Hydrants | | | |
| | <ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box | N.R | — | — |
| | | N.R | — | — |
| | | N.R | — | — |
| 12 | Yard Hydrants. | | | |

| | | | | |
|----|---|-------------|----------------|-----|
| | <ul style="list-style-type: none"> Total number of hydrants | N.R | — | — |
| | <ul style="list-style-type: none"> Hose Box | N.R | — | — |
| 13 | Pumping Arrangements. | | | |
| | <ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump | | | |
| | | — | — | — |
| | | — | — | — |
| | | — | — | — |
| | | 180 LPM | P | M/R |
| | | 40 M | P | M/R |
| | | — | — | — |
| | | — | — | — |
| | | — | — | — |
| | | — | — | — |
| | | 450 LPM | P | M/R |
| | | 40 m | P | M/R |
| | | R | P | M/R |
| | | R | P | M/R |
| 14 | Captive Water Storage for fire fighting. | | | |
| | <ul style="list-style-type: none"> Underground tank capacity | 25,000 ltrs | 25,000 ltr | M/R |
| | <ul style="list-style-type: none"> ➤ Draw-off connection | N.R | — | — |
| | <ul style="list-style-type: none"> ➤ Fire service inlet | N.R | — | — |
| | <ul style="list-style-type: none"> ➤ Access to tank | N.R | — | — |
| | <ul style="list-style-type: none"> Overhead Tank capacity | 1,2500 ltr | 1,2500 ltr | M/R |
| 15 | Exit Signage. | R | P | M/R |
| 16 | Provision of Lifts. | | | |
| | <ul style="list-style-type: none"> Pressurization of Lift Shaft | N.R | — | — |
| | <ul style="list-style-type: none"> Pressurization of Lift lobby | N.R | — | — |
| | <ul style="list-style-type: none"> Communication In lift Car | R | Alarm Provided | M/R |
| | <ul style="list-style-type: none"> Fireman's Grounding Switch | R | P | M/R |
| | <ul style="list-style-type: none"> Lift Signage | R | P | M/R |
| 17 | Standby power supply | R | P | M/R |

| | | | | |
|----|--|-----|-----|-----|
| 18 | Refuge Area. | | | |
| | ➤ Total Area | N/A | N/A | N/A |
| | ➤ Location | N/A | N/A | N/A |
| 19 | Fire Control Room | | | |
| | • Detector System Panel | R | P | M/R |
| | • Flow Switch Panel | R | P | M/R |
| | • PA System Panel | R | P | M/R |
| | • Batter backup | R | P | M/R |
| | • Building Floor Plans | R | P | M/R |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any: | | N.A | |

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. **F6/DFS/MS/2012/Hospital/2876 dated 07/08/2012** is recommended for renewal under rule 35 of the Delhi Fire Service rules 2010.

Signature of the Inspecting Officer

Name

Designation

Deep (W2)

Signature of the Inspecting Officer

Name

Designation

Deep
4/9/15
DO (NW)