

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO.F6/DFS/MS/SZ/Industrial/ 2015/ *52/1672*

Dated: *14/09/15*

FIRE SAFETY CERTIFICATE

Certified that Plot No B- 6/8, Okhla Industrial Area Ph-II, New Delhi-110020, building is comprised of Basement, Ground + 02 and half Upper floors was granted FSC by this department vide letter No.F6/DFS/MS/2010/2009 dated 07/07/10. The premises was re- inspected by the officer concerned of this department in the presence of Mr. S.D.Bajaj on 03/09/15 and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Industrial Building, with effect from-----
~~14/09/15~~ for a period of three years in accordance with rule 36 unless renewed under rule 38 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued *14/09/15* at New Delhi by.


(Dr. G. C. Misra)
Chief Fire Officer
Tel: 011-23414333

Copy to:-

(1) Smt.Rashmi Bajaj,
B6/8, Okhla Indl. Area Ph-II,
New Delhi-110020

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of NBC
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in

217

INSPECTION REPORT

1. Name & address of the building:-Plot No. B 6/8, Okhla Industrial Area ,Ph-II,New Delhi-110020
 2. Type of occupancy:- Group – Industrial
 3. Type of case:- Renewal
 4. Details of previous NOC:- F6/DFS/MS/2010/2009 dated-07/07/2010
 5. Fire safety directives No.- F6/DFS/MS/BP/2006/2946 dated 03/10/2006
 6. Date of inspection:-03/09/2015
 7. Name of the inspecting officer:- D.B.Mukherjee, A.D.O.(BCP)
 8. Name & designation of officer From the building side:- Mr. S.D.Bajaj
 9. Year of construction:- 2006
 - 10.Applicant's letter no:- Nil Dated: 28/08/2015
- (Building is comprised of Basement, Ground + Two and Half upper floors.)

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement BBL/NBC	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	09 m	Provided	MR
	2) Gate width	N/A	N/A	N/A
	3)Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 no	02 nos	MR
	2. Basements	02 no	02 nos	MR
	B. Width of staircase			
	1. Upper floors	1.50 m	Provided	MR
	2. Basements	1.50 m	Provided	MR
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	Required	02 Nos	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	N/A	N/A	N/A
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 a/c per hour	Provided Exhaust fan	MR
	2) Upper floors	12 a/c per hour	Provided Exhaust Fan	MR
5.	Fire Extinguishers			
	1) Total numbers	ISI Marked	25 Nos.	MR
	2) Types		ABC, Co2	MR
	3) ISI marking		Yes	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	Required	Provided	MR
	2) Length of hose reel hose	30 m	Provided	MR
	3) Nozzle diameter	5 mm	Provided	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A

✓

	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Provided DG Set	MR
	5) Hooter's Location	Every Floor	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	Required	Provided	MR
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 mm	Provided	MR
	2) Number of hydrants per floor	01	Provided	MR
	3) Hose box	01	Provided	MR
12.	Yard Hydrants			
	1) Total number of hydrants	Required	Provided 04 nos.	MR
	2) Hose box	Required	Provided	MR
13.	Pumping Arrangement			
	1) Ground level	Required	Provided 02 nos.	MR
	a) Discharge of main pump	2280Lpm	Provided	MR
	b) Head of main pump			
	c) Number of main pump	Required	Provided 01no.	MR
	d) Jockey pump out put			
	e) Jockey pump head			
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	900 LPM	Provided	MR
	b) Head of pump	Required	25m	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	75,000ltr	Provided	MR
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	20,000 ltrs.	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area			
	Total area	N/A	N/A	N/A
	location	N/A	N/A	N/A


2019

19.	Fire Control Room			
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the building were checked and found functional at the time of inspection. Shortcomings issued vide letter no. F6/DFS/MS/2014/2909 dt.: 19/12/2014 has been rectified.

In view of the compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F6/DFS/2010/2009 dated 07/07/2010, renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Accordingly DFA is put up for signature please.



Signature of the inspecting officer

Name :- D.B. Mukherjee.

Designation :- Assistant Divisional Officer(BCP).