

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**  
Fax: 23412593, E-mail: [cfohq.dlfire@nic.in](mailto:cfohq.dlfire@nic.in), Tel:- 011-23414333

NO.F6/DFS/MS/Industrial/2015/ 52/1748

Dated: 28/09/15

**FIRE SAFETY CERTIFICATE**

Certified that **Plot No. D-104, Okhla Industrial Area Phase-1, New Delhi** comprised of basement, ground and two upper floors was granted fire safety certificate by this department vide letter No. F.6/DFS/MS/2011/1942 dated 11.08.2011. The building was re-inspected by the officer concerned of this department on 16-09-2015 in presence of Mr. Omprakash Mobi, Admin Officer and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules- 2010 and that the premises / building is fit for occupancy class- Industrial building with effect from 28/09/15 for a period of **3(three)** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi fire service Rules,2010.

Issued on 28/09/15 at New Delhi by.



(Dr. G.C. MISRA)  
CHIEF FIRE OFFICER

Copy to: -

1. Shri Satish Chander Jain, Plot No. D-104, Okhla Industrial Area Phase-1, New Delhi.
2. The Executive Engineer (Bldg.)-I, SDMC, 8<sup>th</sup> floor, Civic Centre, Minto Road, New Delhi-110002.

**Conditions for the validity of fire safety certificate**

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

**INSPECTION REPORT**

1. Name & address of the building : Plot No. D-104, Okhla Industrial Area Phase-1, New Delhi
2. Type of Occupancy : Industrial
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/2011/942 dated 11.08.2011
5. Fire Safety directives letter No : F.6/DFS/MS/BP/2009/3511 dated 20.11.2009
6. Date of inspection : 16.09.2015
7. Name of the Inspecting Officers : M.K Chattopadhyay, ADO (M. Road)
8. Name and designation of officers  
from the building side : Mr. Omprakash Mobi, Admin.Officer
9. Year of Construction : 2009-2010
10. Applicant's letter No. : nil dated 08-08-2015

Plot No. D-104, Okhla Industrial Area Phase-1 is comprised of basement, ground & two upper floors.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	06 mts	Provided	MR
	• Gate width	4.5 mts	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	-	-	-
	• Upper Floors	02 Nos.	Provided (04)	MR
	• Basements	02 Nos.	Provided	MR
	b. Width of staircases	-	-	-
	• Upper Floors	1.50 mts each	Provided	MR
	• Basements	1.50 mts each	Provided	MR
	c. Protection of exits	-	-	-
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	02	provided	MR
	g. Width of Corridor	1.25 mts	provided	MR
	h. Door Size	1.25 mts	provided	MR

3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Sealing of electrical shafts</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Fire Rating of shaft door</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Water Curtain</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Fire Dampers</li> </ul>	N/A	N/A	N/A
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	30 a/c per hour	Exhaust fan provided	MR
	<ul style="list-style-type: none"> <li>• Upper floors</li> </ul>	12 a/c per hour	Provided	MR
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> </ul>	12	Provided	MR
	<ul style="list-style-type: none"> <li>• Types</li> </ul>	ABC, CO <sub>2</sub> type	Provided	MR
	<ul style="list-style-type: none"> <li>• IS marking</li> </ul>	ISI marked	Provided	MR
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> </ul>	01	Provided	MR
	<ul style="list-style-type: none"> <li>• Length of hose reel hose</li> </ul>	30 m	Provided	MR
	<ul style="list-style-type: none"> <li>• Nozzle diameter</li> </ul>	5 mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> </ul>	Smoke	Provided	MR
	<ul style="list-style-type: none"> <li>• Location of Main Panel</li> </ul>	Ground floor	Provided	MR
	<ul style="list-style-type: none"> <li>• Location of Repeater Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Alternate source of power</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Hooters' Location</li> </ul>	Required at each floor	Provided	MR
8	<b>MOEFA</b>			
		Required	Provided	MR
9	<b>Public Address System.</b>			
		Required	Provided	MR
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Upper Floor</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> </ul>	100 mm	Provided	MR

	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	01	Provided	MR
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	01	Provided	MR
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	04	Provided	MR
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	04	Provided	MR
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>Ground Level</li> </ul>	----	----	----
	<ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> </ul>	2280 LPM	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Head of Main pump</li> </ul>	45 mts	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Number of main pumps</li> </ul>	01	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Jockey Pump out put</li> </ul>	180 LPM	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Jockey pump head</li> </ul>	45 mts	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Standby Pump out put</li> </ul>	2280 LPM	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Standby Pump Head</li> </ul>	45 mts	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Auto Starting/ Manual stopping</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Pump House Access</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Terrace level</li> </ul>	-	-	-
	<ul style="list-style-type: none"> <li>➤ Discharge of pump</li> </ul>	900 LPM	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Head of the pump</li> </ul>	35 mts	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Power Supply</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Auto Starting of pump</li> </ul>	Required	Provided	MR
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> </ul>	1,00,000 lts	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Draw-off connection</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Fire service inlet</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Access to tank</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Overhead Tank capacity</li> </ul>	20, 000 lts	Provided	MR
15	<b>Exit Signage.</b>			
		Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> </ul>	N/A	N/A	N/A

	<ul style="list-style-type: none"> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	N/A	N/A	N/A
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17	<b>Standby power supply</b>	Required	Provided (1100 KVA)	MR
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	• Detector System Panel	Required	Provided	MR
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	Required	Provided	MR
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any	Required	02 ABC type fire extinguisher found provided	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F.6/DFS/MS/2011/942 dated 11.08.2011, renewal under the Delhi Fire Service Act-2007 & Delhi Fire Service Act Rule-2010 is recommended.



DFA is put up for approval & signature please

DO(Sr) - Leave  
 DCFO (Sr) *[Signature]* 17/9/15

*[Signature]*  
 M.K.CHATTOPADHYAY  
 ADO (M. Road)