

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**  
**Fax: 23412593, Tel:- 011-23414000**

No. F6/DFS/MS/SZ/2015/ *10th/1757*

Dated: *29/9/15*

**FIRE SAFETY CERTIFICATE**

Certified that the Soami Service Centre ( for storage of petroleum product of BPCL Ltd.) located at Outer Ring Road-7, Soami Nagar, New Delhi-110017, comprised of ground floor only owned/occupied by Soami Service Centre was granted FSC by this department vide letter No.F6/DFS/MS/2012/551 dated 17/02/2012 . The premises was re-inspected by the officer concerned of this department on 11/09/15 in the presence of Mr. Mahavir and found that the said service station have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Group J Hazardous Building ( Filling Station) with effect from *29/9/15* for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued *29/9/15*-----at New Delhi by.

*[Signature]*  
*29/9/15*  
**(Dr. G. C. Misra)**  
**Chief Fire Officer**  
Tel: 011-23414333

*9c [Signature]*

Copy to:-

Mr. Rajat Badhwar,  
Soami Service Centre,  
Outer Ring Road-7, Soami Nagar,  
New Delhi - 110017

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [ sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

**INSPECTION REPORT**

Name & address of the building:- Soami Service centre, ( for storage of petroleum product of BPCL Ltd.),  
Outer Ring Road -7, Soami Nagar, New Delhi-110017

Type of occupancy:- Group J Hazardous Building, Filling Station

Type of case:- Renewal

Details of previous NOC:- No. F6/DFS/MS/2012/551 dated 17/02/2012

Fire safety directives No.- N/A.

Date of inspection:- 11-09-2015

Name of the inspecting officer:- D.B.Mukherjee, A.D.O.(BCP)

Name & designation of officer from the building side:- Mr. Mahavir

Year of construction:-

Applicant's letter No:- Nil dated 09/07/15

Composition of building :- ground floor only.

(Old Case)

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
<b>1.</b>	<b>Access to Building</b>			
	1) Road width	9 mtrs.	On main Road	MR
	2) Gate width	Required	Open on main road	MR
	3) Width of internal road	N/A	N/A	N/A
<b>2.</b>	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	A. Number of staircases			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	C. Protection of exits	N/A	N/A	N/A
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	Required	1mtr	MR
<b>3.</b>	<b>Compartmentation</b>			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
<b>4.</b>	<b>Smoke Management System</b>			
	1) Basements	30 a/c per hour	N/A	N/A
	2) Upper floors	12 a/c per hour	N/A	N/A
<b>5.</b>	<b>Fire Extinguishers</b>			
	1) Total numbers		6Nos.	MR
	2) Types	ISI Marked	ABC, Co2 & Foam	MR
	3) ISI marking		Yes	MR
<b>6.</b>	<b>First-Aid Hose Reel</b>			
	1) Total number of each floor	N/A	N/A	N/A
	2) Length of hose reel hose	N/A	N/A	N/A
	3) Nozzle diameter	5 mm	N/A	N/A




<b>7.</b>	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
<b>8.</b>	<b>MOEFA</b>	Required	Provided	MR
<b>9.</b>	<b>Public Address System</b>	N/A	N/A	N/A
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
<b>11.</b>	<b>Internal Hydrants</b>			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
<b>12.</b>	<b>Yard Hydrants</b>			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
<b>13.</b>	<b>Pumping Arrangement</b>			
	Ground level	N/A	N/A	N/A
	Discharge of main pump	N/A	N/A	N/A
	Head of main pump	N/A	N/A	N/A
	Number of main pump	N/A	N/A	N/A
	Jockey pump out put	N/A	N/A	N/A
	Jockey pump head	N/A	N/A	N/A
	Stand by pump output	N/A	N/A	N/A
	Stand by pump head	N/A	N/A	N/A
	Auto starting/Manual stopping	N/A	N/A	N/A
	Terrace level	N/A	N/A	N/A
	Discharge of pump	N/A	N/A	N/A
	Head of pump	N/A	N/A	N/A
	Power supply	N/A	N/A	N/A
	Auto starting of pump	N/A	N/A	N/A
<b>14.</b>	<b>Captive Water Storage for Fire Fighting</b>			
	Under ground tank capacity	N/A	N/A	N/A
	Draw-off connection	N/A	N/A	N/A
	Fire service inlet	N/A	N/A	N/A
	Access to tank	N/A	N/A	N/A
	Over head tank capacity	N/A	N/A	N/A
<b>15.</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16.</b>	<b>Provision of Lifts.</b>			
	Pressurization of lift shaft	N/A	N/A	N/A
	Pressurization of lift lobby	N/A	N/A	N/A
	Communication in lift car	N/A	N/A	N/A
	Fireman's switch	N/A	N/A	N/A
	Lift signage	N/A	N/A	N/A
<b>17.</b>	<b>Stand by Power Supply</b>	Yes	D.G. Set	MR
<b>18.</b>	<b>Refuge Area</b>			
	Total area location	N/A	N/A	N/A

19.	<b>Fire Control Room</b>	N/A	N/A	N/A
	Detector system panel	N/A	N/A	N/A
	Flow switch panel	N/A	N/A	N/A
	PA system panel	N/A	N/A	N/A
	Battery backup	N/A	N/A	N/A
	Building floor plan	N/A	N/A	N/A
20.	<b>Special Fire Protection System for Protection of special Risk, if any:</b>			MR
	Fire Buckets filled with sand, "No Smoking" boards were found displayed in Hindi & English. No loose electric wiring was seen in the premises.			

The fire protection system provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/DFS/MS/2012/551 dated 17/02/2012 renewal under rules 35 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly DFA is put up please.

  
 Signature of the inspecting officer  
 Name: D.B. Mukherjee  
 Designation: Assistant Divisional Officer (BCP)