

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/SCHOOL/2015/ 52/1793

Dated: 7/10/15

FIRE SAFETY CERTIFICATE

Certified that the M.C. Primary Girls School, Shift-I (School Code-1757086) & M.C. Primary Boys School, Shift-II (School Code-1757087) at Nilothi, New Delhi-41 running in the same premises in the morning & evening respectively is comprised of two blocks of **Ground + One upper floor** only owned / occupied by M.C. Primary School have complied with the fire prevention and fire safety requirements in accordance with Director of Education **Circular No. F6/Estate/CC/Fire/Safety/2011/3298-3398 dated 01/03/2011** and verified by the officer concerned of Fire Service on **10.09.2015** in presence of **Mr. Girish Kumar (Sr. Teacher Evening)** and that the building / premises is fit for occupancy class **Educational** with effect from **7/10/15**.....for a period of 3 (three) years subject to conditions printed below.

Issued on 7/10/15 at New Delhi by.



(SANTOKH SINGH)
CHIEF FIRE OFFICER
Phone:-23414250

Copy to :-

1. Principal, M.C. Primary Girls School (Shift-I)(School Code-1757086), Nilothi, New Delhi-41.

o/c


Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. There shall not be more than 45 students in class rooms in any case.

INSPECTION REPORT

1. Name & address of the building: **M.C. Primary Girls School (Shift-I), Nilothi, New Delhi-41.**
2. Type of Occupancy : **Educational (G+1)** ✓
3. Type of Case : **New** (Total Area-5527m²)
4. Details of previous NOC : **Nil** (Covered Area-1584m²)
5. Fire Safety directives Letter No. : **DOE Circular dated 1.03.2011** ✓
6. Date of inspection : **10/09/2015**
7. Name of the Inspecting Officer : **A. K. Jaiswal**
8. Name and designation of Officer
from the building side : **Mr. Girish Kumar (Sr. Teacher Evening)**
9. Year of Construction : **2009**
10. Applicant's letter No. : **Nil dated 06/08/2015** ✓

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE. Circ. Dated 1/03/2011 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	1 in each block	2 in 1 st block, 2 in 2 nd block	MR
	• Basements	No basement	N/A	N/A
	b. Width of staircases			
	• Upper floors	1.50 Mtr.	1.25x2 in 1 st block, 1.25x2 in 2 nd block	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	N/A	N/A	N/A
	e. Width Of Corridor	1.50 Mtr	Provided	MR
	f. Door Size	1.00 Mtr.(Class room)	Double door in each class rooms	MR ✓
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers			
4.	Smoke managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers		Provided	MR

6.	First – Aid Hose Reels			
	• Total numbers on each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater	N/A	N/A	N/A
	• Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level	N/A		
	• Discharge of main pump	N/A	N/A	
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto starting of pump	N/A	N/A	N/A
14.	Captive water Storage for fire fighting			
	• Underground tank	N/A	N/A	N/A

15	Exit Signage	N/A	N/A	N/A
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Batter backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

Note:-A) General requirements for schools as per Director of Education circular dated 01/03/2011.

1. Escape routeClear.....
2. LPG cylinders in laboratoriesNil.....
3. Electric wiring ...Conduit Wiring..... MCB and ELCB
Electric circuit
4. Electric meter boardNot under the staircase.....
5. Basement use as per BBL 1983NA.....
6. Emergency telephone no. boardDisplayed.....
7. Generator setNil.....

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Note : There are two block of G+1 storey building. Girls school (code: 1757086), & Boys School (code: 1757087) are running in the same premises in morning & evening.

Ashok Kumar Jaiswal

Signature of the inspecting Officer

Name : Ashok Kumar Jaiswal

Designation : A.D.O. (Jwala Puri)