

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2015 / *School/w2/1800*

Dated: *08/10/2015*

FIRE SAFETY CERTIFICATE

Certified that the **Vidya Jain Public school located at Sec-6, Rohini, Delhi** comprised of **Ground and 03 upper floors** owned/ occupied by **Vardhman Mahavira Educational Society** was issued Fire Safety Certificated vide this office letter no. **F-6/DFS/MS/2012/4419 dated 30.11.2012**. The premise was re-inspected by the officer concerned of this department on **15.09.2015** in the presence of **Sh. Naresh Jain (Principal)** and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition and there is no additional construction. The premise have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy under **Educational "Group B"** with effect from *...08.11.01.15.....* for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on *...08.11.01.15.....* at New Delhi

Santokh Singh
(Santokh Singh)
Chief Fire Officer
Ph.011-23414250

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi, Old Sectt. Delhi - 110054.
2. The Principal, Vidya Jain Public School, Sec-06, Rohini, Delhi - 110085.

N/18

INSPECTION REPORT

1. Name & address of the building : Vidya Jain Public School, Sec -6, Rohini Delhi-110085.
2. Type of Occupancy : Educational
3. Type of Case : Renewal (Ground plus 03 upper floors)
4. Details of previous NOC : F-6/DFS/MS/2012/4419 dated 30.11.2012
5. Fire Safety directives letter No : Director of Education Circular dated 17.01.2005
6. Date of inspection : 15/09/2015
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers
from the building side : Mr Naresh Jain (Principal)
9. Year of Construction : 2004
10. Applicant's letter No. : no. 5702 dated 12.08.2015

Plot Area-6160 sqm Covered Area:2000 sq.m, class rooms -34 nos +03 labs, students---1186 nos

	Minimum Standards on fire prevention and fire safety U/R 33	Director of Education letter dated 17.01.2005	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6m	12m	MR
	• Gate width	NA	3.5m	NA
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m	1.52m each	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	1.50m	2.54m	MR
	f. Door Size	1 m	1 m	MR

M/19

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	NA	NA
		12 a/c per hour	Natural Ventilated	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • ISI marking 	18 nos	22 nos	MR
		ABC/Co2	ABC--18/Co2--4	MR
		ISI Marked	Yes	MR
6	First-Aid Hose Reels.			
<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	01	01no	MR	
	30m	30m	MR	
	5mm	5mm	MR	
7	Automatic fire detection and alarming system.			
<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	NA	NA	NA	
	NA	NA	NA	
	NA	NA	NA	
	NA	NA	NA	
	NA	NA	NA	
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	NA	NA	NA	
	NA	NA	NA	
	NA	NA	NA	
11	Internal Hydrants			
<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	100mm	100mm	MR	
	01	01 at GF & FF, 02 at SF & TF	MR	
	01	01	MR	
12	Yard Hydrants.			

N/20

	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 			
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		450lpm	450lpm	MR
		40m	40m	MR
		R	P	MR
		R	P	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		5,000 ltrs	10,000ltrs	MR
15	Exit Signage.	R	P	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A

18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A


Note:- General requirements as per director of Education letter dated 01.03.2015

- | | |
|---|--------------------------------|
| 1. Escape route—clear | 2. LPG cylinder in Lab---NA |
| 2. Electric wiring—concealed | 4. ELCB/MCB—provided |
| 5. Electric meter board—not under staircase | 6. Emergency Tel Nos—Displayed |
| 7. Generator set ----- Yes | 8. Basement use as per BBL--NA |

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in Director of Education Circular / NBC Part 4, the FSC issued vide letter of even no 4419 dated 30.11.2012 renewal under rule 35 of the Delhi Fire Service Rules, 2010 is recommended




 Signature of the Inspecting Officer
 Name :- Rajesh Kumar
 Designation:- ADO/RN