

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

NO. PG/DFS/MS/2015/52/1889

Dated: 13/10/15

FIRE SAFETY CERTIFICATE

Certified that M/S H.C. Auxilium School, located at Poorvi Marg, Vasant Vihar, New Delhi-110057, comprised of ground plus two upper floors, owned/occupied by H.C.Auxilium School, was granted No Objection Certificate by this department vide letter No.F6/DFS/MS/09/2442, dated 07.08.2009. The premises was re-inspected by the officer concerned of this department on 06-10-2015 in the presence of the Principal of the school and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules 2010 and that the building is fit for occupancy class "Educational" with effect from ..12/10/15.... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules,2010.

Issued on.....13/10/15.....at New Delhi by



(Dr.G.C.Misra)

Chief Fire Officer

T.No.011-23414333



Copy to:-1. Director of Education, Old Secretariat, Civil Lines, Delhi-54.

2 .Principal, H.C.Auxilium School, located at Poorvi Marg, Vasant Vihar, New Delhi-57.

Conditions for the validity of fire safety certificate are as under:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. The employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All fire fighting equipments shall be maintained in perfect working condition all time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate, six month prior to its expiry.

INSPECTION REPORT

| 1 | Name & address of the building | H.C.Auxilium School, located at Poorvi Marg, Vasant Vihar, New Delhi - 110007. | | |
|--------|---|--|--------------------|------------------|
| 2 | Type of Occupancy | Educational Building "B" | | |
| 3 | Type of case | Renewal | | |
| 4 | Details of previous NOC | F6/DFS/MS/09/2442, dated 07.08.2009. | | |
| 5 | Fire safety directives letter No | No.F6/MS/DFS/2005/420, Dated 04.07.2005. | | |
| 6 | Date of inspection | 06.10.2015. | | |
| 7 | Name of the inspecting Officers : | A.D.O. Vedpal. | | |
| 8 | Name and designation of officers from the building side | Principal of the school. | | |
| 9 | Building Comprised of | G+2. | | |
| 9 | Year of construction | 2006 | | |
| 10 | Applicant's letter No. | Direction of Chief Fire Officer. | | |
| S. NO. | Minimum Standards on fire prevention and fire safety U/R 33 | Old NOC Requirement | Provided at site | Remarks MR / NMR |
| 1 | Access to building | | | |
| | 1) Road width | 6m | 9m | MR |
| | 2) Gate width | Required | 5m Provided | MR |
| | 3) Width of internal road | N/A | | N/A |
| 2 | Number, width Type & arrangement of exits | | | |
| | a. Number of staircases | | | |
| | 1. Upper floors | 03Nos. | 03Nos. | MR |
| | 2. basements | N/A | N/A | N/A |
| | b. Width of staircase | | | |
| | 1. Upper floors | 1.5m/75cm | 1.5m, 1.5m & 1.45m | MR(Old case) |
| | 2. basements | N/A | N/A | N/A |
| | c. Protection of exits | | | |
| | 1. Fire check door | N/A | N/A | N/A |
| | 2. Pressurization | N/A | N/A | N/A |
| | d. No. of continuous staircase to terrace | Required | 01no. | MR |
| | e. Width of corridor | N/A | N/A | N/A |
| | f. Door size | 1 Mtr | Provided | MR |
| 3 | Compartmentation. | | | |
| | 1. Fire check door | N/A | N/A | N/A |
| | 2. Sealing of electrical shafts | Required | Provided | MR |
| | 3. Fire Rating of shaft door | N/A | N/A | N/A |
| | 4. water curtain | N/A | N/A | N/A |
| | 5. Fire dampers | N/A | N/A | N/A |
| 4 | Smoke Management system. | | | |
| | basement | 30 a/c per hour | N/A | N/A |
| | Upper Floors | 12 a/c per hour | N/A | N/A |
| 5 | Fire Extinguishers | | | |
| | total numbers | 12nos. | 20nos. | MR |
| | Types | | ABC & Water CO2 | MR |
| | ISI marking | | ISI Mark | MR |
| 6 | First-Aid Hose Reels. | | | |
| | total numbers on each floor | 02nos. | 02nos. | MR |
| | Length of Hose reel hose | 30 m | 30m | MR |
| | Nozzle Diameter | 5 mm | 5mm | MR |

| 7 Automatic fire detection and alarming system | | | | |
|--|---|------------|-----------------|-----|
| | Type of detectors | N/A | N/A | N/A |
| | location of Main Panel | N/A | N/A | N/A |
| | location of Repeater panel | N/A | N/A | N/A |
| | Alternate source of power | N/A | N/A | N/A |
| | hooter's location | N/A | N/A | N/A |
| 8 | MOEFA | N/A | Provided | N/A |
| 9 | Public Address System. | N/A | Provided | N/A |
| 10 | Automatic Sprinkler System. | | | |
| | basement | N/A | N/A | N/A |
| | upper floors | N/A | N/A | N/A |
| | sprinkler above false ceiling | N/A | N/A | N/A |
| 11 | Internal Hydrants | | | |
| | Size of riser/down-corner | N/A | 100mm | N/A |
| | Number of Hydrants per floor | N/A | 02nos. | N/A |
| | hose Box | N/A | 02nos. | N/A |
| 12 | Yard Hydrants. | | | |
| | total number of hydrants | N/A | N/A | N/A |
| | hose box | N/A | N/A | N/A |
| 13 | Pumping arrangements | | | |
| | 1. Ground level | N/A | N/A | N/A |
| | a. Discharge of main Pump | N/A | N/A | N/A |
| | b.Head of main pump | N/A | N/A | N/A |
| | c.Number of main pumps | N/A | N/A | N/A |
| | d.jockey pump out put | N/A | N/A | N/A |
| | e.jockey pump head | N/A | N/A | N/A |
| | f. Standby Pump output | N/A | N/A | N/A |
| | g.Stanby Pump head | N/A | N/A | N/A |
| | h.Auto Starting/Manual stopping | N/A | N/A | N/A |
| | pump house access | N/A | N/A | N/A |
| | 2.Terrace level | | | |
| | a. Discharge of pump | 450LPM. | 450LPM & 180LPM | MR |
| | b. head of the pump | 40 mtr | 40m | MR |
| | c. Power supply | Required | Provided | MR |
| | d. Auto starting of pump | Required | Provided | MR |
| 14 | Captive water storage for fire fighting | | | |
| | 1. Underground tank capacity | N/A | N/A | N/A |
| | a. Draw-off connection | N/A | N/A | N/A |
| | b. fire service inlet | N/A | N/A | N/A |
| | c.Access to tank | N/A | N/A | N/A |
| | Over head tank Capacity | 10000 Ltr. | 10000Liters | MR |
| 15 | Exit Signage. | Required | Provided | MR |
| 16 | Provision of lifts. | | | |
| | a. Pressurization of lift shaft | N/A | N/A | N/A |
| | b. pressurization of lift lobby | N/A | N/A | N/A |
| | c. communication in lift car | N/A | N/A | N/A |
| | d. Fireman's grounding switch | N/A | N/A | N/A |
| | e. Lift signage | N/A | N/A | N/A |
| 17 | Standby power supply | N/A | N/A | N/A |

N/7

| | | Not Required | | |
|-----------|---|--------------|-----|-----|
| 18 | Refuge Area. | | | |
| | total area | N/A | N/A | N/A |
| | location | N/A | N/A | N/A |
| 19 | Fire control room | | | |
| | a. detector system Panel | N/A | N/A | N/A |
| | b. Flow switch Panel | N/A | N/A | N/A |
| | c. PA system Panel | N/A | N/A | N/A |
| | d. Batter backup | N/A | N/A | N/A |
| | e. Building floor plans | N/A | N/A | N/A |
| 20 | Special Fire Protection systems for protection of special risks, if any: N/A | | | |

The fire protection systems provided in the building were test checked randomly and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the NOC issued vide letter No.F.6/DFS/MS/09/2442, dated 07.08.2009 renewal under rule 35 of the Delhi Fire Service Rule 2010 is recommended.

Accordingly DFA is put up for your approval and signature please.


 7/10/15

Signature of the inspecting officer

Name: Vedpal

Designation : ADO