

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/EH/2015/ 1842

Dated : 17/10/15

FIRE SAFETY CERTIFICATE

Certified that the **Mc Donald's Restaurant** located at **17, Regal Building, Connaught Place, New Delhi** comprised of **Ground + Mezzanine floor** was granted FSC by this department vide letter No.F6/DFS/MS/EH/2012/2193 dated **19/06/2012**. The premises was re-inspected by the officer concerned of this department on **22/09/15** in the presence of **Mr. D.N. Thakur (Manager)** and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Assembly Building Group D, Ground + Mezzanine floor only** with effect from 17/10/15 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 17/10/15 at New Delhi by.


(Dr. G.C. Misra)
Chief Fire Officer
Ph-011-23414333

Copy to:-

1. Sh. P.K. Sharma,
Medical Officer of Health,
NDMC, Palika Kendre, New Delhi.
2. The Manager,
Mc Donalds Restaurant ,
17, Regal Building, Connaught Place, New Delhi

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

INSPECTION REPORT

1. Name & address of the building:- McDonalds operated by Ms Connaught Plaza Restaurant Pvt. Ltd. at 17A, Regal Building, Connaught Place, New Delhi.
2. Type of occupancy:- Group – D Assembly Building
Gr. + Mezzanine floor
3. Type of case:- Renewal
4. Details of previous FSC:- No. F6/DFS/MS/2012/EH/2193 dated 19/06/12.
5. Fire safety directives No.- N/A
6. Date of inspection:- 22/09/15
7. Name of the inspecting officer:- Sh. Manoj Kumar Sharma ADO/CC
8. Name & designation of officer
From the building side:- Sh. D.N. Thakur (Manager)
9. Year of construction:- Old Heritage.
10. Applicant's letter No:- CPRPL/FM/NOC/2015-16/224 dated 21/08/15

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Existing	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	4.5 mtr.	09 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors Mezzanine floor	02	02 at Mezz. floor	N/A
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors (Mzze.)	01 mtr.	01 mtr. (each)	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace			
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1 mtr.	1 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors Gr. floor	12 a/c per	Exhaust fan	MR

5.	Fire Extinguishers			
	1) Total numbers	06 Nos.	06 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	ISI	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number	01	01	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	5 mm	5 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors Gr.+ Mzz.	Required	Provided	MR
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM	MR
	b) Head of pump	30 mtr.	30 mtr.	MR
	c) Power supply	Required	Provided	MR
d) Auto starting of pump	Required	Provided	MR	
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank	N/A	N/A	N/A

Mr

	capacity			
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	5,000 ltrs.	5,000 Ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/DFS/MS/EH/2012/2193 dated 19/06/2012 renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.

Party has submitted an undertaking that rear side door is locked due to litigation in court judgment copy placed opposite.

Signature of the Inspecting Officer

M.K. Sharma

Name :- M.K. Sharma
Designation :- ADO (CC)

