

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110 001.**

E-mail:- [cfohq.dlfire@nic.in](mailto:cfohq.dlfire@nic.in)

Fax:- 011-23412593



No. F.6/DFS/MS/BNQT/2015/ 52 /1801

Dated: 08/10/15

**FIRE SAFETY CERTIFICATE**

Certified that the **M/s Petal Banquet (M/s Shiv Shakti Hotels Pvt. Ltd.)** located at A-21/18, Naraina Industrial Area, Phase-II, New Delhi-110028. The building is comprised of Basement, Ground floor plus two and half upper floors, using basement as storage, ground floor as Banquet Hall owned/occupied by the management of M/s Shiv Shakti Hotels Pvt. Ltd. The building was re-inspected by the officers concerned of this department on 15.09.2015 in the presence of Sh. Rohit Kalra and found that the management of M/s Shiv Shakti Hotels Pvt. Ltd. have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises (**Ground floor only**) is fit for occupancy class Group D assembly building w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....08/10/15.....at New Delhi.

  
(DR. G.C. MISRA)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE  
Ph:- 011-23414333  


Copy to:-

1. The Dy. Health Officer,  
North Delhi Municipal Corporation,  
Nigam Bhawan, D.B. Gupta Road,  
Anand Parabt, Karol Bagh, New Delhi-05.  
(Ref.No.DHO/KBZ/2014/2449 dated 26.09.2014)
2. The Manager,  
M/s Petal Banquet, A-21/18,  
Naraina Ind. Area, Ph-II, N.D-28.  
(Ref. No. Nil dated 26.08.2015)

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The basement shall be used strictly as per the provisions of the building bye laws.
7. The owner/ occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

The building is comprised of Basement, Ground Floor plus two and half upper floors.  
 Note:- The Banquet Hall is running at Ground Floor Only.

417

### INSPECTION REPORT

1. Name & address of the building : Petal Banquet, A-21/18, Naraina Industrial Area,
2. Type of Occupancy : Assembly (Banquet Hall) Ph-II, N.D-28.
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No.           —           Date           —
5. Fire Safety directives letter No :           —
6. Date of inspection : 15.09.2015
7. Name of Inspecting Officer : D.O S.K. Tomar & A.D.O P.S. Dahiya
8. Name and designation of officers  
From the building side : Sh. Rohit Kalra (Owner)
9. Year of Construction : 2005-06
10. Applicant's letter No. : NIL dated 26.08.2015

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	<p style="text-align: center;">Accessible</p> <p style="text-align: center;">—</p> <p style="text-align: center;">—</p>	<p style="text-align: center;">12 mtr</p> <p style="text-align: center;">210cms, 106cms</p> <p style="text-align: center;">—</p>	<p style="text-align: center;">MR</p> <p style="text-align: center;">MR (02 Exit)</p> <p style="text-align: center;">—</p>
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	<p style="text-align: center;">—</p> <p style="text-align: center;">Two</p>	<p style="text-align: center;">—</p> <p style="text-align: center;">Two</p>	<p style="text-align: center;">B. Hall at G. Floor only</p> <p style="text-align: center;">MR</p>
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basements</li> </ul>	<p style="text-align: center;">—</p> <p style="text-align: center;">—</p>	<p style="text-align: center;">—</p> <p style="text-align: center;">120cms, 116cms</p>	<p style="text-align: center;">B. Hall at G. Floor only</p> <p style="text-align: center;">— do —</p>
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• pressurization</li> </ul>	<p style="text-align: center;">—</p> <p style="text-align: center;">—</p>	<p style="text-align: center;">—</p> <p style="text-align: center;">—</p>	<p style="text-align: center;">—</p> <p style="text-align: center;">—</p>
	d. No. of continuous staircases to terrace			
		<p style="text-align: center;">—</p>	<p style="text-align: center;">One</p>	<p style="text-align: center;">—</p>
	e. Width of Corridor			
		<p style="text-align: center;">—</p>	<p style="text-align: center;">—</p>	<p style="text-align: center;">B. Hall at G. Floor only</p>
	f. Door Size			
		<p style="text-align: center;">—</p>	<p style="text-align: center;"><u>110 cms x 235 cms</u></p>	<p style="text-align: center;">—</p>
3.	Compartmentation			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	<p style="text-align: center;">—</p> <p style="text-align: center;">—</p> <p style="text-align: center;">—</p> <p style="text-align: center;">—</p> <p style="text-align: center;">—</p>	<p style="text-align: center;">—</p> <p style="text-align: center;">Sealed</p> <p style="text-align: center;">—</p> <p style="text-align: center;">—</p> <p style="text-align: center;">—</p>	<p style="text-align: center;">—</p> <p style="text-align: center;">MR</p> <p style="text-align: center;">—</p> <p style="text-align: center;">—</p> <p style="text-align: center;">—</p>
4.	Smoke Management System			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors / <u>Ground Floor</u></li> </ul>	<p style="text-align: center;">30 a/c per hour</p>	<p style="text-align: center;">Exhaust Fans are Provided</p> <p style="text-align: center;">— do —</p>	<p style="text-align: center;">MR</p> <p style="text-align: center;">MR</p>

N/8

		12 a/c per hour	-	-
5.	Fire Extinguishers			
	• Total numbers	08 Nos	Provided	MR
	• Types	CO <sub>2</sub> , ABC	- do -	MR
	• IS marking	ISI marked	ISI marked	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	Two	Provided	MR
	• Length of hose reel hose	30 m	- do -	MR
	• Nozzle diameter	5 mm	- do -	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	-	Smoke	MR
	• Location of Main Panel	-	-	-
	• Location of Repeater Panel	-	-	-
	• Alternate source of power	-	-	-
	• Hooters' Location	-	-	-
8.	MOEFA	Required	Provided	MR
9.	Public Address System	- do -	- do -	MR
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Upper Floor / <u>Ground Floor</u>	-	- do -	MR
	• Sprinkler above false ceiling	-	-	-
11.	Internal Hydrants			
	• Size of riser/down-comer	100 M.M	100 M.M	MR
	• Number of hydrants per floor	Two	Two	MR, G.F only
	• Hose Box	- do -	- do -	- do -
12.	Yard Hydrants			
	• Total number of hydrants	-	-	-
	• Hose Box	-	-	-
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	-	-	-
	➤ Head of Main pump	-	-	-
	➤ Number of main pumps	-	-	-
	➤ Jockey Pump out put	-	-	-
	➤ Jockey pump head	-	-	-
	➤ Standby Pump out put	-	-	-
	➤ Standby Pump Head	-	-	-
	➤ Auto Starting/Manual stopping	-	-	-
		-	-	-

N19.

A-21/18, Naraina Industrial Area,  
Phase-II, New Delhi - 110028.

	<ul style="list-style-type: none"> <li>➤ Pump House Access</li> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul>	-	-	-
		900 LPM	1850 LPM, 180 LPM	MR
		30M	55M, 30M	MR
		Required	Provided	MR
		-	-	-
14.	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	-	-	-
		-	-	-
		-	Provided	MR
		-	-	-
		15000 Ltr	15000 Ltr	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	-	-	-
		-	-	-
		-	Provided	MR, G.F. Only
		Required	-do-	MR, -do-
		-do-	-do-	MR, -do-
17.	<b>Standby power supply</b>	Required	02 D.G Set of 160KVA & 82.5KVA	MR
18.	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	-	-	-
		-	-	-
19.	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>	-	-	-
		-	-	-
		-	-	-
		-	Provided	-
		-	-	-
20.	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	-	-	-

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the above substantial compliance of the minimum standards on fire prevention and Fire Safety measures required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~


Note:- The building is comprised of Basement, Ground Floor plus two and half upper floors. The basement is served by two staircases. The banquet hall is running at Ground Floor only in above said building. Fire Safety Certificate is recommended to run the banquet Hall at Ground Floor only.

  
18/9/15

Signature of Inspecting Officer

Name S.K. Tomar

Designation Divisional Officer

  
18/9/15

Signature of Inspecting Officer

Name P.S. Dahiya

Designation Asstt. Divisional Officer