

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001
Fax: 23412593, Email: director.dfire@nic.in, Tel:- 011-23414000


NO.F6/ DFS/ MS/School/2015/52/1802

Dated: 08/10/15


FIRE SAFETY CERTIFICATE

Certified that St. Anthony's Sr. Sec School, C-6, S.D.A,(Hauz Khas), New Delhi-110016 comprised of Ground + 03 Upper floor owned/occupied by St. Anthony's Sr. Sec School was inspected by the officer concerned of this department on 23/09/2015 in the presence of Mr. Basudevan and found that the said school have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Educational (School)** with effect from the date of issue of this certificate for a period of three years, subject to compliance of the below mentioned conditions.

Issued on 08/10/15 at New Delhi by.



(Dr. G. C. Misra)
Chief Fire Officer
Tel: 011-23414333



Copy to: -

The Principal
St. Anthony's Sr. Sec School,
C-6, S.D.A, (Hauz Khas)
New Delhi-110016

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk & responsibility of the management.
3. Trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.

6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its exp form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building:- St. Anthony's Sr. Sec School,C-6, S.D.A,(Hauz Khas)
New Delhi-110016
2. Type of occupancy:- Educational (School)
3. Type of case: - New.
4. Details of previous NOC: - Nil
5. Fire safety directives No.- Nil
6. Date of inspection:- 23/08/2015
7. Name of the inspecting officer:- D.B.Mukherjee, A.D.O.(BCP)
8. Name & designation of officer From the building side: - Mr. Basudevan
9. Year of construction:- 1970
- 10.Applicant's letter No:- dated

School building is comprised of two blocks- Sr. Sec.Block, & Primary Block ,Comprised of G + two upper floors each.Nursery Block which was earlier within the school boundary has been separated. One Chapel and one Residential Block comprised of G + One and half Floors.


Sl. No	Minimum Standards on fire Prevention and fire safety U/R 33	BBL/NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	Required	Provided	MR
	2) Gate width	Required	Provided	MR
	3)Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02nos	Sr. Sec.block- 02 nos. Primary Block-01	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.50m	Sr Sec-1.75m each Primary block-1.5 m	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	Required	01 nos.	MR
	E. Width of corridor	Required	1.50 mtr	MR
	F. Door size	1mtr	Provided	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 a/c per hour	N/A	N/A
	2) Upper floors	12 a/c per hour	Natural Ventilation	MR
5.	Fire Extinguishers			
	1) Total numbers	ISI Marked	20 Nos	MR
	2) Types		ABC, Co2	MR
	3) ISI marking		Yes	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	02 nos.	Provided	MR
	2) Length of hose reel hose	30m	Provided	MR

	3) Nozzle diameter	5mm	Provided	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location			
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	900Lpm	Provided	MR
	b) Head of pump	40m	Provided	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	10,000ltr	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area			
	Total area location	N/A	N/A	N/A
19.	Fire Control Room			
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A

N/G

	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The Fire protection systems provided in school were checked and found functional. In view of the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the rules 35 of the Delhi Fire Service Rules 2010, it is recommended to issue Fire Safety Certificate to the school. Accordingly DFA is put up for sign pl.


29/9/2015

Signature of the inspecting officer
Name: - D.B. Mukherjee.
Designation:- Assistant Divisional Officer (BCP)