

**FIRE SAFETY CERTIFICATE**

Certified that M/S Abhay Enterprises Pvt. Ltd., Plot No. A-42, Okhla Industrial Area, Phase-1, New Delhi-110020, comprised of basement, ground plus one upper floor owned/occupied by M/S Abhay Enterprises Pvt. Ltd., was granted No Objection Certificate by this department vide letter No. F6/DFS/MS/2003/2869, dated 21-11-03. The premises was re-inspected by the officer concerned of this department on 09-10-2015 in the presence of Sh. Suresh Kumar (Administrative Officer) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class G "Industrial building" with effect from 16/10/2015 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on...16/10/2015 at New Delhi by.



(Dr.G.C.Misra)

Chief Fire Officer

T.No.011-23414333

Copy to:- Sh. Anil Kumar Aggarwal, Director, M/S Abhay Enterprises Pvt. Ltd., Plot No. A-42, Okhla Industrial Area, Phase-1, New Delhi-110020. <sup>o/c</sup> <sub>h</sub>

**Conditions for the validity of fire safety certificate are as under:-**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate on form J, six month prior to its expiry.

**INSPECTION REPORT**

1	Name & address of the building	M/S Abhay Enterprises Pvt. Ltd., Plot No. A-42, Okhla Industrial Area, Phase-1, New Delhi-110020.		
2	Type of Occupancy	Industrial G		
3	Building comprised of	Basement, Ground plus one upper floor.		
4	Type of case	Renewal		
5	Details of previous NOC	No.F6/DFS/MS/2003/2869, Dated 21.11.03.		
6	Fire safety directives letter No	F.6/DFS/MS/BP/2000/1427, Dated 14.07.2001		
7	Date of inspection	09.10.2015.		
8	Name of the inspecting Officers :	ADO Vedpal		
9	Name and designation of officers from the building side	Sh. Suresh Kumar (Administrative Officer)		
10	Year of construction	2003		
11	Applicant's letter No.	Nil	Dt. 28.09.2015	
<b>S. NO.</b>	<b>Minimum Standards on fire prevention and fire safety U/R 33</b>	<b>Requirement</b>	<b>Provided at site</b>	<b>Remarks / NMR</b>
<b>1</b>	<b>Access to building</b>			
	1) Road width	9 mtrs	Provided	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
<b>2</b>	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	02nos.	02nos.	MR
	2. basements	02nos.	02nos.	MR
	<b>b. Width of staircase</b>			
	1. Upper floors	1.25 mtrs(each)	1.25m (each)	MR
	2. basements	1.25 mtrs(each)	1.25m (each)	MR
	<b>c. Protection of exits</b>			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	One	Provided	MR
	<b>e. Width of corridor</b>	Not Required	Not Required	MR
	<b>f. Door size</b>	1.25m	1.25m (each)	MR
<b>3</b>	<b>Compartmentation.</b>			
	1. Fire check door	Required	Provided	MR
	2. Sealing of electrical shafts	Required	Provided	MR
	3. Fire Rating of shaft door	Not Required	Not Required	N/A
	4. water curtain	Not Required	Not Required	N/A
	5. Fire dampers	Not Required	Not Required	N/A
<b>4</b>	<b>Smoke Management system.</b>			
	basement	30 a/c per hour	Exhaust Fan Provided	MR
		12 a/c per hour		
	upper floors		Natural Ventinational	MR
<b>5</b>	<b>Fire Extinguishers</b>			
	total numbers		30 Nos	MR
	Types		ABC, Co2,	MR
	ISI marking	ISI	Yes	MR
<b>6</b>	<b>First-Aid Hose Reels.</b>			
	total numbers on each floor	01no.	02nos.	MR
	Length of Hose reel hose	30 m	30m	MR
	Nozzle Diameter	5 mm	5mm	MR

*Handwritten signature*



N/19

Automatic fire detection and alarming system			
7	Type of detectors	N/A	N/A
	location of Main Panel	N/A	N/A
	location of Repeater panel	N/A	N/A
	Alternate source of power	N/A	N/A
	hooter's location	N/A	N/A
8	<b>MOEFA</b>	Required	Provided
9	<b>Public Address System.</b>	N/A	N/A
10	<b>Automatic Sprinkler System.</b>		
	basement	Required	Provided
	upper floors	N/A	N/A
	sprinkler above false ceiling	N/A	N/A
11	<b>Internal Hydrants</b>		
	Size of riser/down-corner	N/A	N/A
	Number of Hydrants per floor	N/A	N/A
	hose Box	N/A	N/A
12	<b>Yard Hydrants.</b>		
	total number of hydrants	04nos.	04nos.
	hose box	04nos.	04nos.
13	<b>Pumping arrangements</b>		
	<b>1. Ground level</b>		
	a. Discharge of main Pump	1620 LPM	Provided
	b. Head of main pump	70 Mtr	Provided
	c. Number of main pumps	One	Provided
	d. jockey pump out put	180 LPM	Provided
	e. jockey pump head	70 Mtr	Provided
	f. Standby Pump output	1620 LPM	Provided
	g. Standby Pump head	70 Mtr	Provided
	h. Auto Starting/Manual stopping	Required	Provided (Both)
	pump house access	Required	Provided
	<b>2. Terrace level</b>		
	a. Discharge of pump	900 LPM	Provided
	b. head of the pump	40 mtr	Provided
	c. Power supply	Required	Provided
	d. Auto starting of pump	Required	Provided
14	<b>Captive water storage for fire</b>		
	1. Underground tank capacity	10,000 ltr	Provided
	a. Draw-off connection	Required	Provided
	b. fire service inlet	Required	Provided
	c. Access to tank	Required	Provided
	Over head tank Capacity	15,000 ltr	Provided
15	<b>Exit Signage.</b>	Required	Provided
16	<b>Provision of lifts.</b>		
	a. Pressurization of lift shaft	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A
	c. communication in lift car	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A
	e. Lift signage	N/A	N/A
17	<b>Standby power supply</b>	Required	Provided
18	<b>Refuge Area.</b>	Not Required	
	total area		
	location		


<b>19</b>	<b>Fire control room</b>			
	a. detector system Panel	Required	Provided	MR
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A

**20** **Special Fire Protection systems for protection of special risks, if any:**

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the NOC issued vide letter No.F.6/DFS/MS/2003/2869, dated 21.11.2003 renewal under rule 35 of the Delhi Fire Service Rule 2010 is recommended.

Accordingly DFA is put up for your approval and signature please.

  
**Signature of the inspecting officer**

**Name** Vedpal

**Designation : Assistant Divisional Officer**