

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/MS/DFS/EH/2015/ 1825

Dated: 9/10/15

FIRE SAFETY CERTIFICATE

Certified that the KFC Restaurant(Yum Restaurants (India) Pvt. Ltd.) located at 02B, Select City Mall, Saket, New Delhi-110017, comprised of basement, ground + two upper floors but the restaurant is running at ground floor owned/occupied by KFC Restaurant(Yum Restaurants (India) Pvt. Ltd.) was granted FSC by this department vide letter no. F6/DFS/MS/EH/2012/2607 dated 19/07/2015. The premises was re-inspected by the officer concerned of this department on 29/09/2015 in the presence of Mr. Harwinder and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class Group - D, Assembly Building with effect from 9.10.15... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued 9/10/15 at New Delhi by.


(Dr. G. C. Misra)
Chief Fire Officer
Tel: 011-23414333



Copy to:-

The Authorised Signatory
Show Room No5/6, Atma Ram Mansion Scindia House,
Connught Circus, Connught Place,
New Delhi-110001

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of NBC
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building:- KFC(Yum Restaurant(India) Pvt Ltd.),02B Select City Mall, Saket, New Delhi-110017
2. Type of occupancy:- Assembly Building, Group – D, Restaurant
3. Type of case:- Renewal
4. Details of previous NOC:- F6/DFS/MS/EH/2012/2607 Dated 19/07/12
5. Fire safety directives No.- Nil
6. Date of inspection:- 29/09/2015
7. Name of the inspecting officer:- D.B.Mukherjee, A.D.O.(BCP)
8. Name & designation of officer From the building side:- Mr. Harwinder
9. Year of construction:- 2007.
10. Applicant's letter No:- Nil dated 17/07/2015
11. Composition of Building :- Basement, Ground + Two Upper Floors.
Restaurant is running at ground floor.

Sl.No	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement NBC	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	10 mtrs	Provided	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	Required	1.5m	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 a/c per hour	N/A	N/A
	2) Upper floors	12 a/c per hour	Exhaust Fan	MR
5.	Fire Extinguishers			
	1) Total numbers	ISI Marked	04 Nos.	MR
	2) Types		ABC, Co2 ,Foam	MR
	3) ISI marking		Yes	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	1 Nos	Provided By mall	MR
	2) Length of hose reel hose	30 m	Provided By mall	MR
	3) Nozzle diameter	5mm	Provided By mall	MR

7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Required	Provided	MR
	2) Location of main panel	Required	Ground Floor	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Battery back up	MR
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	Required	Provided	MR
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	150mm	Provided by mall	MR
	2) Number of hydrants per floor	Required	Provided by mall	MR
	3) Hose box	Required	Provided by mall	MR
12.	Yard Hydrants			
	1) Total number of hydrants	Required	Provided by mall	MR
	2) Hose box	Required	Provided by mall	MR
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	4500LPM	Provided by mall	MR
	b) Head of main pump	88mtr	Provided by mall	MR
	c) Number of main pump	Two	Provided by mall	MR
	d) Jockey pump out put	180 LPM	Provided by mall	MR
	e) Jockey pump head	88Mtr	Provided by mall	MR
	f) Stand by pump output	4500LPM	Provided by mall	MR
	g) Stand by pump head	88mtr	Provided by mall	MR
	h) Autostarting/Manual stopping	Required	Provided (Both)	MR
	2) Terrace level			
	a) Discharge of pump	180 Lpm	Provided by mall	MR
	b) Head of pump	40mtr	Provided by mall	MR
	c) Power supply	Required	Provided by mall	MR
	d) Auto starting of pump	Required	Provided by mall	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	5,00,000ltr	Provided by mall	MR
	a) Draw-off connection	Required	Provided by mall	MR
	b) Fire service inlet	Required	Provided by mall	MR
	c) Access to tank	Required	Provided by mall	MR
	d) Over head tank capacity	30,000ltr	Provided by mall	MR
15.	Exit Signage.	Required	Provided by mall	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided by mall	MR
18.	Refuge Area			
	Total area	N/A	N/A	N/A
	location	N/A	N/A	N/A

2/10


19.	Fire Control Room			
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			

The fire protection system provided in the building were checked and found functional at the time of inspection.

The FSC of the mall has been renewed in the year 2015.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F6/DFS/MS/EH/2012/2607 dated: 19/07/2012, renewal under rules 35 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly DFA is put up please.


30/9/2015

Signature of the inspecting officer

Name :- D.B. Mukherjee.

Designation :- Assistant Divisional Officer.