

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/Banquet/2015/NO2/1818 Dated 08/10/15

FIRE SAFETY CERTIFICATE

Certified that the S.K .Ceremony and Banquet Hall, at 2nd Floor, Aggarwal Fun City Mall ,Plot No. 29-31, CBD Shahdara, Delhi comprised of second floor owned/occupied by M/S S.K .Ceremony and Banquet Hall, was granted FSC by this department vide letter No. F6/DFS/MS/Banquet/2012/1454 dated 23.04.12. The Premises was re-inspected by the officer concerned of this department on 28.05.2015 in the presence of Manager and found that the Banquet hall have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules, 2010 and found that the Banquet hall at second floor is fit for occupancy class "Assembly (Banquet hall)" with effect from 08/10/15..... for a period of three years in accordance with Rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010, subject to conditions printed overleaf.

Issued on.....08/10/15.....at New Delhi by

(Dr. G.C. Misra)

Chief Fire Officer

Ph -011- 23414333

o/c Sh

To

The Manager,

M/S S.K .Ceremony and Banquet Hall

2nd Floor, Aggarwal Fun City Mall ,Plot No. 29-31, CBD Shahdara, Delhi

Copy to-

The Deputy Health Officer,

Shahdara (South) Zone, EDMC, Health Department, Shahdara South Zone,

Karkardooma, Delhi

Conditions

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
6. This NOC may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. Basement shall be used as per BBL

INSPECTION REPORT

1. Name & address of the building : S.K .Ceremony and Banquet Hall, at 2nd Floor, Aggarwal Fun City Mall ,Plot No. 29-31, CBD Shahdara, Delhi
2. Type of Occupancy : Assembly
3. Type of Case : Renewal
4. Details of Previous NOC : F.6/DFS/MS/Banquet/2012/1454 dated 23.04.12
5. Fire Safety directives No : F.6/DFS/MS/2011/2166 dated 06.09.11
6. Date of Inspection : 28.05.2015
7. Name of the Inspecting Officer : ADO Suresh Singh
8. Name of the designation of Officer
- From the building side : Sh.Gorav
9. Year of Construction : 2005
- 10.Applicant's letter No : 22.04.2015

	Minimum Standards on fire prevention and fire safety U/R33	NBC Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	12 Mtrs 4.5 Mtrs. -----	26 Mtrs. 5 Mtrs. -----	MR MR -----
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	03 Nos.	03 Nos.	MR
	• Upper Floor	03 Nos	03 Nos.	MR
	• Basement	03 Nos	03 Nos.	MR
	B. Width of Staircases	1.5 M	1.5 M	MR
	• Upper Floor	1.5 M	1.5 M	MR
	• Basement	1.5 M	1.5 M	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	e. No. of continuous staircases to terrace	2 Nos.	2 Nos.	MR
	g. Width of Corridor	2.5 Mtrs	2.5 Mtrs	MR
	h. Door Size	2.0 Mtr.	1no. of 3.5 Mtr.& 2 nos. of 2.5 Mtr.	MR
3	Compartmentation.	Required	Provided	
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Sealed	MR
	• Fire rating of shaft door	2 hrs.	2 hrs.	MR
	• Water curtain	NA	NA	NA
	• Fire Dampers	Required	Provided	MR
4	Smoke Management System.			
	• Basement	30a/c per hour	provided	MR
	• Upper floor	12 a/c per hour	--do---	MR
5.	Fire Extinguisher			
	• Total numbers	06 no.	06 No.	MR
	• Types	ABC & Co2	ABC & Co2	MR
	• IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	• Total numbers of each floor	4 no.	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	Heat & smoke	Provided	MR
	• Location of main panel	Control Room	1 st basement	MR
	• Location of repeater panel	Security Room	Provided	MR
	• Alternate source of power	Battery & DG Set	Provided	MR

		Required	Provided	MR
10	Automatic Sprinkler System.			
	• basement	Required	Provided in entire basement	MR
	• upper floor	Required	Provided	MR
	• sprinkler above false ceiling	Required	Provided	MR
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	04 nos.	04 nos.	MR
	• Hose Box	04 nos.	04 nos.	MR
12	Yard Hydrants.			
	• Total number of hydrants	3 nos.	3 nos.	MR
	• Hose Box	3 nos.	3 nos.	MR
13	Pumping Arrangements.			
	• Ground Level	Required	Provided	MR
	➤ Discharge of main Pump	2280 LPM	2280 LPM	MR
	➤ Head of Main Pump	60 Mtrs.	60 mtrs	MR
	➤ Number of main pumps	1 nos.	1 nos.	MR
	➤ Jockey pump out put	450 LPM	450 LPM	MR
	➤ Jockey pump head	60 Mtrs.	60 mtrs.	MR
	➤ Standby pump out put	2280 LPM	2280 LPM	MR
	➤ Standby pump Head	60 Mtrs	60 Mtrs.	MR
	➤ Auto Starting /Manual stopping	Auto	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace Level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the Pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	2,00,000 Ltrs.	2,00,000 Ltrs.	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	25000 Ltrs.	25000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	Required	provided	MR
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication in lift car	Required	Provided	MR
	• Firemen's grounding switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	Standby power supply	Required	1000 KVA	MR
18	Refuge Area.	NA	NA	NA
	• Total area	NA	NA	NA
	• Location	NA	NA	NA
19	Fire Control Room			
	• Detector system panel	Required	Provided	MR
	• Flow switch panel	Required	----do----	MR
	• PA system panel	Required	----do-----	MR
	• Batter backup	Required	----do----	MR
	• Building Floor Plans	Required	----do---	MR
20	Special Fire Protection systems for protection of special Risks, if any:	NA	NA	NA

N/10

During the course of inspection it was observed that the premises is located at 2nd Floor. This Banquet hall is a part of the Aggarwal Fun City Mall which has been already issued the FSC by this department vide letter no. F.6/DFS/MS/2012/1455 dated 23.04.2012 other observation are as above in inspection report.

The fire protection systems provided in the building were test^{ed} checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules the FSC issued vide letter no. F6/DFS/MS/Banquet/2012/1454 dated 23.04.12 renewal under the Rule 35 of the Delhi Fire Service Rules 2010 is recommended.


2.6.15

Signature of the Inspecting Officer

Name Suresh Singh

Designation ADO (Shah)