

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/2015 /school/wz/1870

Dated: 19/10/2015

FIRE SAFETY CERTIFICATE

Certified that Kendriya Vidyalaya Sector 25, at old building of K.V Sector- 8, Rohini, Delhi comprised of Ground Floor (Temp hutments) owned/occupied by Kendriya Vidyalaya Sector 25, Rohini, Delhi was issued fire safety certificate by this department vide letter no. F6/MS/DFS/2012/School/1881 dated 24/05/2012. The premises was re-inspected by the officer concerned of this department on 14/08/2015 in the presence of Sh. R. B. Singh and found that the building have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010, and premise is fit for class Educational Buildings with effect from 19/10/2015 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rule, 2010.

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 19/10/15 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250

Copy to:

1. Kendriya Vidyalaya Sector 25, at old building of K.V Sector- 8, Rohini, Delhi
2. The Director of Education, GNCT of Delhi Old Secretariat, Delhi-110054

INSPECTION REPORT

1. Name & address of the building : Kendriya Vidyalaya (Sector- 25) At Sector – 8 Rohini, Delhi
2. Type of Occupancy : Educational (Ground Floor (Temp hutment))
3. Type of Case : Renewal
4. Details of previous NOC : F6/MS/DFS/2012/School/1881 dated 24/05/2012
5. Fire Safety directives letter No :
6. Date of inspection : 14/08//2015
7. Name of the Inspecting Officers : ADO (RN) Sh. Rajesh Kumar
8. Name and designation of officers from the building side : Sh. R. B. Singh. /Principal
9. Year of Construction : 2006
10. Applicant's letter No. : F.F.Safety/KVRS25/15-16/10 dated 13/07/2015

Plot Area- 1400 Sq.mtr. Covered Area-1100 Sq.mtr. No of Student- 540 Class Room-17

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Education Requirement / NBC Part IV	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	M/R
	• Gate width	Accessible	Accessible	M/R
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases	--	--	--
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	.		
	e. Width of Corridor	NA	NA	NA
	f. Door Size	Old case	Old case	Old case
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A

All

	<ul style="list-style-type: none"> Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements 	30 a/c per hour	N/A	N/A
	<ul style="list-style-type: none"> Upper floors 	12 a/c per hour	N/A	N/A
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	05	07	M/R
			06 ABC & 01 Co2	M/R
		ISI marked	Yes	M/R
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	30 m 5 mm	N/A	N/A
			N/A	N/A
			N/A	N/A
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A

12/11

13	Pumping Arrangements.	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N/A	N/A	N/A
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	N/A	N/A	N/A
15	Exit Signage.	N/A	N/A	N/A
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
19	Fire Control Room			

mu

M/10

Kendriya Vidyalaya (Sector- 25) At Sector – 8 Rohini, Delhi

	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

Note: - General requirements for schools as per Director of Education circular dated

1. Escape route **Clear**.....
2. LPG cylinders in laboratories **Not in use**.....
3. Electric wiring **Concealed**.....
4. MCB and ELCB at Electric circuit ... **Provided**.....
5. Electric meter board **Not below stair case**.....
6. Basement use as per BBL 1983 **N/A**.....
7. Emergency telephone no. board **Displayed**.....
8. Generator set **Nil**.....

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. : **F6/MS/DFS/2012/School/1881 dated 24/05/2012** is recommended for renewal under rule 35 of the Delhi Fire Service rules 2010.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name S.S. Tuli

Name Rajesh Kumar

Ru
01/09/15

Designation DO/14/ND

Designation ADO (RN)