

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F6/DFS/MS/2015/CNG/W2/1862

Dated: 19/10/2015

FIRE SAFETY CERTIFICATE

Certified that the CNG Filling Station (IGL) at PSP Sector- 28, Rohini, Delhi comprised of Ground + One Upper Floor owned / occupied by Indraprastha Gas Limited was granted NOC by this department vide letter no F6/DFS/MS/CNG/2011/3190 dated 25/11/2011. The premise was re-inspected by officer concerned of this department on 03/09/2015 in the presence of Sh. Khatri (Manager IGL) and found that the premises have deemed complied with fire prevention & fire safety requirement in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and the building / premises is fit for occupancy CNG Filling Station Group 'J' with effect from 19/10/2015 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 subject to conditions printed below.

Following fire safety directives must be adhered to:-

- 1) All the fire safety arrangement provided their in shall be maintained in good working conditions at all time.
- 2) Any loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
- 3) The trained fire fighting staff should be available round the clock.
- 4) Any deviation, with regards to construction etc shall be verified b y the concerned building sanctioning agency.
- 5) This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- 6) The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
- 7) **The conditions as mentioned in letter no F-5/ (3-A) DFS/CNG/BP/2010/268 dated 09/09/2010 shall be followed strickly.**
- 8) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. This is available on www.dfs.delhigovt.nic.in

Issued on...19/10/15...at New Delhi by.


(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250

Copy to:-

1. Chief General Manager (project), Indraprastha Gas Limited, IGL Bhawan, Plot no-4, Community Centre, R.K. Puram, Sect-9, New Delhi-110022.
2. The Addl. Commissioner of Police (Lic), 1st Floor, Police Station, Defense Colony, Delhi for information...

INSPECTION REPORT

Ground + First Floor

1. Name & address of the building : CNG Filling Station (IGL) at PSP Sector 28, Rohini, Delhi
2. Type of Occupancy : CNG Filling Station **Group 'J'**
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/CNG/2011/3190 dated 25/11/2011
5. Fire Safety directives letter No : -----
6. Date of inspection : 17/09/2015
7. Name of the Inspecting Officers : DO (NW)
8. Name and designation of officers
from the building side : (Manager IGL)
9. Year of Construction : 2009
10. Applicant's letter No. : IGL/F&S/2015-16/15/40/2 dated 16/06/2015

---	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Required	30m	M.R.
	• Gate width	N.A	N.A	N.A
	• Width of internal road	N.A	N.A	N.A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	R	P	M/R
	• Basements			
	b. Width of staircases			
	• Upper Floors	1.25 mtr	P	M/R
	• Basements			
	c. Protection of exits	—	—	—
	• Fire check door	N.A	N.A	N.A
	• Pressurization	N.A	N.A	N.A
	d. No. of continuous staircases to terrace	N.A	N.A	N.A
	e. Width of Corridor	N.A	N.A	N.A
	f. Door Size	1 mtr	P	M.R.
3	Compartmentation.			
	➤ Fire check door	N.A	N.A	N.A

	<ul style="list-style-type: none"> ➤ Sealing of electrical shafts ➤ Fire Rating of shaft door ➤ Water Curtain ➤ Fire Dampers 	N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
4	Smoke Management System.			
	<ul style="list-style-type: none"> ➤ Basements 	30 a/c per hour	N.A	N.A
	<ul style="list-style-type: none"> ➤ Upper floors 	12 a/c per hour	N.A	N.A
5	Fire Extinguishers			
	<ul style="list-style-type: none"> ➤ Total numbers 	DCP trolley 7.5 kg x 9 CO2 4.5 KG x 4 DCP 10 kg x 15 ISI marked	P	M.R
	<ul style="list-style-type: none"> ➤ Types 		DPC , CO2 type	M.R
	<ul style="list-style-type: none"> ➤ IS marking 		yes	M.R
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor 	N.A	N.A	N.A
	<ul style="list-style-type: none"> • Length of hose reel hose 	30mm	N.A	N.A
	<ul style="list-style-type: none"> • Nozzle diameter 	5mm	N.A	N.A
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> ➤ Type of detectors 	N.A	N.A	N.A
	<ul style="list-style-type: none"> ➤ Location of Main Panel 	N.A	N.A	N.A
	<ul style="list-style-type: none"> ➤ Location of Repeater Panel 	N.A	N.A	N.A
	<ul style="list-style-type: none"> ➤ Alternate source of power 	N.A	N.A	N.A
	<ul style="list-style-type: none"> ➤ Hooters' Location 	N.A	N.A	N.A
8	MOEFA	R	P	M.R
9	Public Address System.	N.A	N.A	N.A
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> ➤ Basement 	N.A	N.A	N.A
	<ul style="list-style-type: none"> ➤ Upper Floor 	N.A	N.A	N.A
	<ul style="list-style-type: none"> ➤ Sprinkler above false ceiling 	N.A	N.A	N.A
11	Internal Hydrants			
	<ul style="list-style-type: none"> ➤ Size of riser/down-comer 	N.A	N.A	N.A
	<ul style="list-style-type: none"> ➤ Number of hydrants per floor 	N.A	N.A	N.A
	<ul style="list-style-type: none"> ➤ Hose Box 	N.A	N.A	N.A
12	Yard Hydrants.			
	<ul style="list-style-type: none"> ➤ Total number of hydrants 	N.A	N.A	N.A
	<ul style="list-style-type: none"> ➤ Hose Box 	N.A	N.A	N.A

13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level 			
	➤ Discharge of main Pump	N.A	N.A	N.A
	➤ Head of Main pump	N.A	N.A	N.A
	➤ Number of main pumps	N.A	N.A	N.A
	➤ Jockey Pump out put	N.A	N.A	N.A
	➤ Jockey pump head	N.A	N.A	N.A
	➤ Standby Pump out put	N.A	N.A	N.A
	➤ Standby Pump Head	N.A	N.A	N.A
	➤ Auto Starting/ Manual stopping	N.A	N.A	N.A
	➤ Pump House Access	N.A	N.A	N.A
	• Terrace level			
	➤ Discharge of pump	N.A	N.A	N.A
	➤ Head of the pump	N.A	N.A	N.A
	➤ Power Supply	N.A	N.A	N.A
	➤ Auto Starting of pump	N.A	N.A	N.A
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	N.A	N.A	N.A
	➤ Draw-off connection	N.A	N.A	N.A
	➤ Fire service inlet	N.A	N.A	N.A
	➤ Access to tank	N.A	N.A	N.A
	• Overhead Tank capacity	N.A	N.A	N.A
15	Exit Signage.	N.A	N.A	N.A
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N.A	N.A	N.A
	• Pressurization of Lift lobby	N.A	N.A	N.A
	• Communication In lift Car	N.A	N.A	N.A
	• Fireman's Grounding Switch	N.A	N.A	N.A
	• Lift Signage	N.A	N.A	N.A
17	Standby power supply	N.A	N.A	N.A
18	Refuge Area.			
	➤ Total Area	N.A	N.A	N.A
	➤ Location	N.A	N.A	N.A
19	Fire Control Room			

	<ul style="list-style-type: none"> • 6Detector System Panel • .Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Fire buckets filed with sand, No smoking boards were found displayed in Hindi & English. No lose electric wiring were seen in premises & CO2 flooding system found provided. 03 cascade at terrace, 02 compressor (KPCC) 1200 SCM & 2400 SCM, Co2 Hooding system (cap. 45 kg x4) fire buckets, gas detector emergency switch value		M.R
21	DCP spray system for cascade	Provided		M/R

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/DFS/MS/CNG/2011/3190 dated 25/11/2011 Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name

Designation

DCP/W2

Signature of the Inspecting Officer

Name

Designation

[Signature]
29/9/15



153104/04