

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001


No.F6/DFS/MS/School/2015/ 52/1879

Dated: 19/10/15

**FIRE SAFETY CERTIFICATE**

Certified that the **Govt. Girls Sr. Sec. School No.3** located at **Sector-4, Ambedkar Nagar, New Delhi-110062**. Comprised of in three blocks one block is ground floor & second & third block is ground + one upper floor. owned/occupied by **GNCT of Delhi**. was issued FSC vide letter no.F6/DFS/MS/School/2012/1007 dated 20/03/12. The school premises was re-inspected by the officer concerned of this department on 3/10/2015 in the presence of Mrs. Sudha kumari and found that the school have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01-03-2011 and that the school building is fit for occupancy class "Educational (School)" with effect from ...19/10/15..... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 19/10/15 at New Delhi by.



**(Dr. G. C. Misra)**  
**Chief Fire Officer**  
Tel: 011-23414333

Dr. G. C. Misra

Copy to:-

The Principal  
Govt. Girls Sr. Sec. School No.3,  
Sector-4, Ambedkar Nagar, New Delhi-110062.

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [ sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

## INSPECTION REPORT

1. Name & address of the building:- Govt. Girls Sr. Sec. School No.3, Sector-4, Ambedkar Nagar, New Delhi-110062.
2. Type of occupancy:- Educational (School)
3. Type of case:- Renewal
4. Details of previous NOC:- F6/DFS/MS/School/2012/1007 Dated 20/03/2012
5. Fire safety directives No.- F.16/Estate/CC/Fire/Safety/2011/3298 to 3398 dated 01/03/11
6. Date of inspection:- 03/10/15
7. Name of the inspecting officer:- D.B.Mukherjee, A.D.O (BCP)
8. Name & designation of officer  
From the building side:- Mrs. Sudesh Kumari (Principal).
9. Year of construction:- Ground + 1 floor (1984) & single storey (2000) & New Block 2014
10. Applicant's letter No:- 1406 dated 08/09/2015
11. Composition of building :- School is in three blocks one block is ground floor & second & third block is ground + one upper floor.

S. No	Minimum Standards on fire Prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to Building</b>	Required	Provided	MR
	1) Road width	Required	Approachable	MR
	2) Gate width	Required	5 mtr.	MR
	3) Width of internal road	N/A	N/A	N/A
2.	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	A. Number of staircases			
	1. Upper floors	5nos	A block 2nos B block 3nos	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	Required	A block 1.50 mtr.each B block 1.79m, 1.79m, 1.72m	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits	N/A	N/A	N/A
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	Required	2 Nos.	MR
	E. Width of corridor	Required	2.10m	MR
	F. Door size	Required	1 mtr.	MR
3.	<b>Compartmentation</b>			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	<b>Smoke Management System</b>			
	1) Basements	30 a/c per hour	N/A	N/A
	2) Upper floors	12 a/c per hour	N/A	N/A

5.	<b>Fire Extinguishers</b>			
	1) Total numbers			
	2) Types			
	3) ISI marking	ISI Marked	20 Nos. Provided	MR
			ABC	MR
			Yes	MR
6.	<b>First-Aid Hose Reel</b>			
	1) Total number of each floor	N/A		
	2) Length of hose reel hose	30 m	N/A	N/A
	3) Nozzle diameter	5 mm	N/A	N/A
			N/A	N/A
7.	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	<b>MOEFA</b>	N/A	N/A	N/A
9.	<b>Public Address System</b>	Required	N/A	N/A
10.	<b>Automatic Sprinkler System</b>		Provided	MR
	1) Basement	N/A		
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
			N/A	N/A
11.	<b>Internal Hydrants</b>			
	1) Size of riser/down-comer	N/A		
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
			N/A	N/A
12.	<b>Yard Hydrants</b>			
	1) Total number of hydrants	N/A		
	2) Hose box	N/A	N/A	N/A
			N/A	N/A
13.	<b>Pumping Arrangement</b>			
	1) Ground level	N/A		
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level	N/A	N/A	N/A
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
			N/A	N/A
14.	<b>Captive Water Storage for Fire Fighting</b>			
	1) Under ground tank capacity	N/A		
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	N/A	N/A	N/A
			N/A	N/A
15.	<b>Exit Signage.</b>	Required	Provided	MR

218

16.	<b>Provision of Lifts.</b>	N/A	N/A	N/A
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	<b>Stand by Power Supply</b>	N/A	N/A	N/A
18.	<b>Refuge Area</b>	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	<b>Fire Control Room</b>	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	<b>Special Fire Protection System for Protection of special Risk, if any:</b>		N/A	N/A

The fire protection system provided in the building were checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety required as per the directives of Education department vide circular No.F.16/Estate/CC/Fire/safety/2011/3298-3398 dated 01/03/2011, it is recommended to renew the fire safety certificate under rule 35 of the Delhi Fire Service Rule 2010.

Accordingly DFA is put up for perusal and sign. pl.

*[Handwritten signature]*  
12/10/15

Signature of the inspecting officer

Name: - D.B.Mukherjee.

Designation:- Assistant Divisional Officer (BCP)

*[Handwritten mark]*