

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001.**

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593

No. *F6/DFS(MS)/EH/2015/S2/1882*

Dated: *19/10/15*

FIRE SAFETY CERTIFICATE

Certified that the **Pind Balluchi Restaurant & Bar** located at SS-2, 2nd Floor, Plot No. 15-16, MLU, Sector-6, Dwarka, New Delhi-110075. The building is comprised of ground floor plus three upper floors but the restaurant is running at second floor only owned/occupied by An Elegant Hospitality. The Restaurant was re-inspected by the officers concerned of this department on 01.09.2015 in the presence of Sh. Ramesh Dalal and found that An Elegant Hospitality have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the restaurant premises (**at second floor only**) is fit for occupancy class Group D assembly building w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....*19/10/15*..... at New Delhi.



(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph:- 011-23414333

Copy to:-

1. The Deputy Health Officer,
South Delhi Municipal Corporation,
Public Health Department, Najafgarh Zone, New Delhi.
(Ref. No. DHO/NGZ/2014/4328 dated 07.08.2015)
2. Sh. Ramesh Dalal
B-805, Dhawaladhar Appts., Plot No-15,
Sec-05, Dwarka, New Delhi-110075.

O/C/S

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/ occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Pind Balluchi Restaurant & Bar, SS-2, 2nd Floor, Plot No-15-16, MLU, Sector-6, Dwarka, New Delhi-110075.
2. Type of Occupancy : Assembly (Restaurant)
3. Type of Case : Fresh
4. Details of Previous NOC : NA
5. Fire Safety directives letter No : F.6/DFS/MS/BP/99/486 dated 08.07.1999
6. Date of inspection : 01/09/2015
7. Name of Inspecting Officer : D.O S.K. Tomar & A.D.O S.P. Bhardwaj
8. Name and designation of officers
From the building side : Sh. Ramesh Dalal
9. Year of Construction : Before 2009
10. Applicant's letter No. : Nil dated 09.09.2015, DHO/NGZ/2014/4328 dt.07.08.15

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible -- NA	18 mtr 200, 115 cms NA	MR MR (02 Exits) NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	One NA	One NA	MR No Basement
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	125 cms NA	125 cms NA	MR No Basement
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	NA NA	NA NA	NA NA
	d. No. of continuous staircases to terrace			
		---	One	MR
	e. Width of Corridor			
		---	-	-
	f. Door Size	2.0 Mtr.	Provided	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 ACPH 12 ACPH	NA Natural Ventilation	No Basement MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	04 ABC ISI marked	Provided Provided Provided	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	One 30 m 5 mm	Provided Provided Provided	MR MR MR

7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power 	NA NA NA NA NA	Smoke NA NA NA NA	MR NA NA NA NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Second Floor Sprinkler above false ceiling 	NA Required NA	NA Provided NA	No Basement MR NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	100 MM One One	100 MM One One	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	NA NA	NA NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	NA NA NA NA NA NA NA NA NA NA 450 LPM 30 M Required NA	NA NA NA NA NA NA NA NA NA NA 450, 180 LPM 30 M Each Provided NA	NA NA NA NA NA NA NA NA NA NA MR (02 Pumps) MR MR NA
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NA NA NA NA 10000 ltr	NA NA NA NA 10000 ltr.	NA NA NA NA MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA

17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view the above substantial compliance of the minimum standards on fire prevention and fire safety measures required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service rules 2010 is recommended.


14/1/15

Signature of Inspecting Officer

Name:- S.K. Tomar

Designation:- Divisional Officer

Signature of Inspecting Officer

Name:- S.P. Bhardwaj

Designation:- Asstt. Divisional Officer