

No. F6/DFS/MS/2015

LPG / ND2 / 1889


Dated

19/10/15

FIRE SAFETY CERTIFICATE

Certified that the M/S Usha Gas Service Site No. 4, Rajghat Power House New Delhi comprised of single story building was granted NOC by this department vide letter No. F6/DFS/MS/LPG/86/674 dated 06.06.86 the premises was re-inspection by the officer concerned of this department on 10.10.15 in the presence of Ms. Shweta Vaid and found that said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of class **Hazardous (Group J)** with effect from ~~19/10/15~~ for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the condition under rule 38 of Delhi Fire Service Rules, 2010.

Issued on 19/10/15 at New Delhi by.


(Dr. G. C. Misra)
Chief Fire Officer
Delhi Fire Service
Ph -011-23414333

- Copy to:- (1) Usha Gas Service,
Site No. 4, Rajghat Power House New Delhi..
(2) The Chief Area Manager,
Indian Oil Corporation Ltd.,
6th floor, Surya Kiran Building 19, K.G. Marg, New Delhi.
(3) Administrative Officer (Factory Lic.), North Delhi Municipal Corporation, Factory
Licensing Department, New Delhi.

Condition for the validity of fire safety certificate

1. "No smoking" sign board should be displayed in such a manner as to be easily readable by all persons.
2. No trade susceptible to cause ignition by generating heat, mechanical / electric spark should be allowed within the premises and its vicinity.
3. No combustible material and /or other articles shall be permitted to be stored in the safety space around the godown.
4. No cooking or naked light shall be permitted in safety zone.
5. The Chowkidar hut shall not infringe the safety zone.
6. The employee working at the godown must be taught the correct method of operation and maintenance of the extinguishers.
7. Overhead electric cable not passing across the licensed premises.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director DFS Form 'J'(sub rule (1) of rule 37) along with copy of this Certificate, six months prior to its expiry.
9. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.

-21-5

INSPECTION REPORT

- 1. Name & address of the building:- Usha Gas Service Site No. 4, Rajghat Power House New Delhi.
- 2. Type of occupancy:- Gas Godown (Hazardous) Ground floor.
- 3. Type of case:- Renewal
- 4. Details of previous NOC:- No.F6/DFS/MS/86/LPG/674 dated 06/06/86
- 5. Fire safety directives No.- N/A
- 6. Date of inspection:- 10/10/15
- 7. Name of the inspecting officer:- D.O. Gurmukh Singh.
- 8. Name & designation of officer
From the building side:- Mrs. Shweta Vaid
- 9. Year of construction:-
- 10. Applicant's letter No:- Nil- dated 30.09.15

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Existing	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr.	15 mtr.	MR
	2) Gate width	Accessible	Accessible Directly	MR
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors (mezz.)	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	N/A	N/A	N/A
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	03 Nos.	03 Nos.	MR
	2) Types	ABC, CO ₂	ABC, CO ₂	MR
	3) ISI marking	Required	Provided	MR


h

6.	First-Aid Hose Reel			
	1) Total number at each floor	N/A	N/A	N/A
	2) Length of hose reel hose	N/A	N/A	N/A
	3) Nozzle diameter	N/A	N/A	N/A
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A

	d) Over head tank capacity	N/A	N/A	N/A
15.	No Smoking Signage. (English & Hindi)	Required	Provided in English & Hindi	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:	Fire buckets filled with sand	Provided	MR

The fire protection system provided in the godown were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No.F6/DFS/MS/86/LPG/674 dated 06/06/86, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended



Dy CPO (NDZ)

Gurmukh Singh
Divisional Officer