

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No.F6/MS/DFS/School/2015/ 32/1913

Dated: 26/10/15

FIRE SAFETY CERTIFICATE

Certified that the Aroma Public School, located at Jonapur, New Delhi - 110047. comprised of in two blocks A block is ground plus one & half upper floor & B block is comprised of basement, ground plus one upper floor. both of the blocks are interconnected with each other at ground to terrace Own/Occupied by Aroma Public School. The premises was inspected by the officer concerned of this department on 01/10/2015 in the presence of Mrs. Anita Arora and found that the said premises have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Educational Building (School)** with effect from 26/10/15-----for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued 26/10/15-----at New Delhi by.


(Dr. G. C. Misra)

Chief Fire Officer

Tel: 011-23414333

०२ १५

Copy to: -

The Principal
Aroma Public School,
Jonapur, New Delhi -110047.

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The basement shall be used as per the provisions of BBL.
6. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in

N/4

INSPECTION REPORT

1. Name & address of the building:- Aroma Public School, Jonapur, New Delhi-110047,
2. Type of occupancy:- Educational (School)
3. Type of case: - New
4. Details of previous NOC: - Nil
5. Fire safety directives No.- Nil
6. Date of inspection:- 1/10/2015
7. Name of the inspecting officer:- D.B.Mukherjee, A.D.O.(BCP)
8. Name & designation of officer From the building side: - Mrs. Anita Arora
9. Year of construction:- 1996 & 2011
10. Applicant's letter No:- APS/93/1147 dated 14/09/2015
11. Composition of building :- School is in two blocks.A block is ground plus one & half upper floor & B block is comprised of basement, ground plus one upper floor.both of the blocks are interconnected with each other at ground to terrace.

| Sl. No | Minimum Standards on fire Prevention and fire safety U/R 33 | BBL/NBC Requirement | Provided at site | Remarks MR/NMR |
|-----------|---|---------------------|--------------------------------|----------------|
| 1. | Access to Building | | | |
| | 1) Road width | Required | Provided | MR |
| | 2) Gate width | Required | 2.5mtr | MR |
| | 3)Width of internal road | N/A | N/A | N/A |
| 2. | Number, Width Type & Arrangement of Exits | | | |
| | A. Number of staircases | | | |
| | 1. Upper floors | 02nos | Provided 02no | MR |
| | 2. Basements | 02nos | Provided 02no | MR |
| | B. Width of staircase | | | |
| | 1. Upper floors | 1.50m | A-block 1.26m B-block 1.27m | MR |
| | 2. Basements | 1.50m | 1.15mtr & 1.13mtr | MR |
| | C. Protection of exits | | | |
| | 1. Fire check door | N/A | N/A | N/A |
| | 2. Pressurization | N/A | N/A | N/A |
| | D. No. of continuous staircase to terrace | 01 no | 02 nos. | MR |
| | E. Width of corridor | Required | 1.15m | MR |
| | F. Door size | Required | 1mtr | MR |
| 3. | Compartmentation | | | |
| | 1) Fire check door | N/A | N/A | N/A |
| | 2) Sealing of electrical shafts | N/A | N/A | N/A |
| | 3) Fire rating of shaft door | N/A | N/A | N/A |
| | 4) Water curtain | N/A | N/A | N/A |
| | 5) Fire Dampers | N/A | N/A | N/A |
| 4. | Smoke Management System | | | |
| | 1) Basements | 30 a/c per hour | Natural | MR |
| | 2) Upper floors | 12 a/c per hour | N/A | N/A |
| 5. | Fire Extinguishers | | | |
| | 1) Total numbers | ISI Marked | 06 Nos | MR |
| | 2) Types | | ABC, Co2 | MR |
| | 3) ISI marking | | Yes | MR |
| 6. | First-Aid Hose Reel | | | |

E

| | | | | |
|------------|---|-----------|----------------------|-----|
| | 1) Total number of each floor | Required | 1 nos at each floors | MR |
| | 2) Length of hose reel hose | 30m | Provided | MR |
| | 3) Nozzle diameter | 5mm | Provided | MR |
| 7. | Automatic Fire Detection & Alarming System | | | |
| | 1) Type of detectors | N/A | N/A | N/A |
| | 2) Location of main panel | N/A | N/A | N/A |
| | 3) Location of repeater panel | N/A | N/A | N/A |
| | 4) Alternate source of power | N/A | N/A | N/A |
| | 5) Hooter's Location | | | N/A |
| 8. | MOEFA | N/A | N/A | N/A |
| 9. | Public Address System | N/A | N/A | N/A |
| 10. | Automatic Sprinkler System | | | |
| | 1) Basement | N/A | N/A | N/A |
| | 2) Upper floors | N/A | N/A | N/A |
| 11. | Internal Hydrants | | | |
| | 1) Size of riser/down-comer | N/A | N/A | N/A |
| | 2) Number of hydrants per floor | N/A | N/A | N/A |
| | 3) Hose box | N/A | N/A | N/A |
| 12. | Yard Hydrants | | | |
| | 1) Total number of hydrants | N/A | N/A | N/A |
| | 2) Hose box | N/A | N/A | N/A |
| 13. | Pumping Arrangement | | | |
| | 1) Ground level | N/A | N/A | N/A |
| | a) Discharge of main pump | N/A | N/A | N/A |
| | b) Head of main pump | N/A | N/A | N/A |
| | c) Number of main pump | N/A | N/A | N/A |
| | d) Jockey pump out put | N/A | N/A | N/A |
| | e) Jockey pump head | N/A | N/A | N/A |
| | f) Stand by pump output | N/A | N/A | N/A |
| | g) Stand by pump head | N/A | N/A | N/A |
| | h) Auto starting/Manual stopping | N/A | N/A | N/A |
| | 2) Terrace level | | | |
| | a) Discharge of pump | 450Lpm | 450 LPM | MR |
| | b) Head of pump | 35mtr | 35mtr | MR |
| | c) Power supply | Required | Provided | MR |
| | d) Auto starting of pump | Required | Provided | MR |
| 14. | Captive Water Storage for Fire Fighting | | | |
| | 1) Under ground tank capacity | N/A | N/A | N/A |
| | a) Draw-off connection | N/A | N/A | N/A |
| | b) Fire service inlet | N/A | N/A | N/A |
| | c) Access to tank | N/A | N/A | N/A |
| | d) Over head tank capacity | 10,000Ltr | Provided | MR |
| 15. | Exit Signage. | Required | Provided | MR |
| 16. | Provision of Lifts. | | | |
| | a) Pressurization of lift shaft | N/A | N/A | N/A |
| | b) Pressurization of lift lobby | N/A | N/A | N/A |
| | c) Communication in lift car | N/A | N/A | N/A |
| | d) Fireman's switch | N/A | N/A | N/A |
| | e) Lift signage | N/A | N/A | N/A |
| 17. | Stand by Power Supply | N/A | N/A | N/A |
| 18. | Refuge Area | N/A | N/A | N/A |

✓

2/16

| | | | | |
|-----|---|-----|-----|-----|
| 18. | Refuge Area | | | |
| | Total area location | N/A | N/A | N/A |
| 19. | Fire Control Room | N/A | N/A | N/A |
| | a) Detector system panel | N/A | N/A | N/A |
| | b) Flow switch panel | N/A | N/A | N/A |
| | c) PA system panel | N/A | N/A | N/A |
| | d) Battery backup | N/A | N/A | N/A |
| | e) Building floor plan | N/A | N/A | N/A |
| 20. | Special Fire Protection System for Protection of special Risk, if any: | | | N/A |

The fire protection system provided in the building were tested and found functional at the time of inspection.

The shortcoming given by the department vide letter noF6/MS/DFS/School/2015/916 dated 08/05/15 have been rectified.

In view of the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under rules 35 of the Delhi Fire Service Rules 2010, issuance of fire safety certificate is recommended

Accordingly DFA is prepared and put up for perusal, approval and signature pl.

[Handwritten Signature]
12/10/15

Signature of the inspecting officer
Name: - D.B.Mukherjee.
Designation:- Assistant Divisional Officer (BCP)