

No.F 6/DFS/ms/2015/w2/1948

Dated 30/10/15

FIRE SAFETY CERTIFICATE

Certified that the M/s. Cherish Restaurant C-3/8 Plot No. 8, Ground Floor only, Block C-3, Ashok Vihar, Ph-II, Delhi. The building is comprised of B+Stilt+G+03 upper floors have complied with the fire prevention and fire safety in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 15.09.2015 in the presence of Mr. Saurab Bansal and that the building/premises is fit for occupancy Assembly with effect from 30/10/15... for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire service rule, 2010.


Following fire safety directives must be adhered to:-

- 1) All the means of escape shall be kept free of all type of obstruction all the time.
- 2) All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
- 3) All the fire fighting equipment shall be maintained in perfect working condition all the time and lapse rendering non-functional of fire safety measures, management shall be responsible.
- 4) Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
- 5) Basement shall be used only as per NBC part-IV.
- 6) This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
- 8) "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37], along with a copy of this Certificate, six months prior to its expiry".

Issued on 30/10/15 at New Delhi by

  
(Santokh Singh)  
Chief Fire Officer  
Delhi Fire Service  
Tel . -011-23424250

Copy to:

1. M/s Cherish Restaurant C-3/8 Plot no. 8, Ground floor Block C-3, Ashok Vihar Ph-II, Delhi.
  2. Dy. Health Officer Civil Lines Zone, 16 Rajpur Road Delhi-54.
- 

FF to III floor Gust House all ready issued FSC vide Letter No.  
F6/DFS/MS2015/School WZ/1517/Dated 20/8/15

### INSPECTION REPORT

1. Name & address of the building : M/s Cherish Restaurant C-3/8 Plot no. 8,  
Ground floor Block C-3, Ashok Vihar Ph-II,  
Delhi
2. Type of Occupancy : Assembly
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives letter No. : Nil
6. Date of inspection : 26-09-2015 *dh*
7. Name of the Inspecting Officers : Sunil Chawdhary DO (M.N.)
8. Name and designation of officers  
From the building side : Mr. Saurab Bansal
9. Year of Construction :
10. Applicant's letter No. : DHO//CLZ/2015/1329 dated 01/09/2015

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	09 m	Provided	M/R
	• Gate width	4.5 mtr	Provided	M/R
	• Width of internal road	N.A.	N.A.	N.A.
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	2	2	M.R.
	• Basement	2	2	M.R.
	b. Width of staircases			
	• Upper Floors	1 x 2 mtr, 1x1 mts. NA	1 x 2 mtr 1x1.8 mts.	M.R
	• Basement	N.A	1.8 & 2 mtr	N.A
	c. Protection of exits			
	• Fire check door	N.R.	N.R.	N.R.
	• Pressurization	N.R.	N.R.	N.R.
	d. No. of continuous staircases to terrace	N.A	02	N.A
	e. Width of Corridor	1.5 mtr	Halls only	M.R.
	f. Door size	2 mtr each	Provided	M.R.
3.	<b>Compartmentation.</b>			
	• Fire check door	N.R.	N.R.	N.R.
	• Sealing of electrical shafts	N.R.	N.R.	N.R.
	• Fire Rating of shaft door	N.R.	N.R.	N.R.
	• Water Curtain	N.R.	N.R.	N.R.
	• Fire Dampers	N.R.	N.R.	N.R.
4.	<b>Smoke Management System.</b>			

N/2

	<ul style="list-style-type: none"> <li>Basements</li> </ul>	Required	Provided	M.R.
	<ul style="list-style-type: none"> <li>Upper floors</li> </ul>	Required	Provided	M.R.
<b>5.</b>	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> </ul>	06	08	M.R
	<ul style="list-style-type: none"> <li>Types</li> </ul>	ABC, CO <sub>2</sub> type	Provided	M.R
	<ul style="list-style-type: none"> <li>IS marking</li> </ul>	ISI marked	Provided	M.R
<b>6.</b>	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>	01	Provided	M.R
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	30 m required	Provided	M.R
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	5 mm	Provided	M.R
<b>7.</b>	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> <li>Hooter's Location</li> </ul>	N.R.	N.R.	N.R.
<b>8.</b>	<b>MOEFA</b>	Required	Provided	M.R
<b>9.</b>	<b>Public Address System</b>	Required	Provided	M.R
<b>10.</b>	<b>Automatic Sprinkler system</b>			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	N.A.	P	N.A.
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	N.R.	N.R.	N.R.
<b>11.</b>	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	N.R.	N.R.	N.R.
<b>12.</b>	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	N.R.	N.R.	N.R.
<b>13.</b>	<b>Pumping Arrangements.</b>			
	<b>Ground Level</b>			
	➤ Discharge of main pump	N.A.	N.A.	N.A.
	➤ Head of Main pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey Pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.

	<ul style="list-style-type: none"> <li>Types</li> <li>IS marking</li> </ul>	ABC, CO <sub>2</sub> type ISI marked	Provided	M.R.
<b>6.</b>	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>	01	Provided	M.R.
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	30 m required	Provided	M.R.
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	5 mm	Provided	M.R.
<b>7.</b>	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> <li>Hooter's Location</li> </ul>	N.R.	N.R.	N.R.
<b>8.</b>	<b>MOEFA</b>	Required	Provided	M.R.
<b>9.</b>	<b>Public Address System</b>	Required	Provided	M.R.
<b>10.</b>	<b>Automatic Sprinkler system</b>			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	N.A.	P	N.A.
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	N.R.	N.R.	N.R.
<b>11.</b>	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	N.R.	N.R.	N.R.
<b>12.</b>	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	N.R.	N.R.	N.R.
<b>13.</b>	<b>Pumping Arrangements.</b>			
	<b>Ground Level</b>			
	➤ Discharge of main pump	N.A.	N.A.	N.A.
	➤ Head of Main pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey Pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting/Manual stopping	N.A.	N.A.	N.A.
	➤ Pump Hose Access	N.A.	N.A.	N.A.
	<b>Terrace level</b>			
	➤ Discharge of pump	900 LPM	Provided	M.R.
		40 m	Provided	M.R.

N/S

	➤ Head of the pump	required	Provided	M.R.
	➤ Power supply	required	Provided	M.R.
	➤ Auto Starting of pump			
<b>14.</b>	<b>Captive Water Storage for fire fighting</b>			
	<b>Underground tank capacity</b>	N.R.	N.R.	N.R.
	➤ Draw -off connection	N.R.	N.R.	N.R.
	➤ Fire service inlet	N.R.	N.R.	N.R.
	➤ Access to tank	N.R.	N.R.	N.R.
	➤ Overhead Tank Capacity	10,000 ltrs	20,000 ltrs	M.R.
<b>15</b>	<b>Exit Signage.</b>	required	Provided	M.R.
<b>16.</b>	<b>Provision of Lifts</b>			
	• Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	• Pressurization of Lift lobby	N.A.	N.A.	N.A.
	• Communication In lift Car	N.A.	N.A.	N.A.
	• Fireman's Grounding Switch	N.A.	N.A.	N.A.
	• Lift Signage	N.A.	N.A.	N.A.
<b>17.</b>	<b>Standby power supply</b>	Required	Provided	M.R
<b>18.</b>	<b>Refuge Area</b>			
	➤ Total Area	N.R	N.R	N.R
	➤ Location	N.R	N.R	N.R
<b>19.</b>	<b>Fire Control Room</b>			
	➤ Detector System Panel	N.R	N.R	N.R
	➤ Flow Switch Panel	N.R	N.R	N.R
	➤ PA system Panel	N.R	N.R	N.R
	➤ Batter backup	N.R	N.R	N.R
	➤ Building Floor plans	N.R	N.R	N.R
<b>20.</b>	Special Fire Protection Systems for Protection of special Risks, if any:	N.R	N.R	N.R

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/.

Note the Gust House located on F.F. , IInd & IIIrd floor has already been issued FSC by department vide letter No. F6/DFS/MS2015/School WZ/1517/Dated 20/8/15