

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/ DFS/ MS/SZ/2015/ 1941

Dated: 29/10/15

FIRE SAFETY CERTIFICATE

Certified that the Savemax, DMRC Property Development Area, located at Ground Floor, Kalkaji Mandir Metro Station Kalkaji, New Delhi-110019 comprised of ground and 01 upper floor (Savemax Departmental Store at Ground Floor & First Floor is Vacant) owned/occupied by a unit of Black Clothing Pvt Ltd. was granted FSC by this department vide letter no F6/DFS/MS/2012/3841 Dated 17/10/12 . The premises was re-inspected by the officer concerned of this department on 13/10/2015 in the presence of Mr. S.K.Chugh and found that the said building/premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Group – F, Mercantile Building** with effect from 29/10/15 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued 29/10/15 at New Delhi by,


(Dr. G. C. Misra)
Chief Fire Officer
Tel: 011-23414333

Copy to: -

Mr.S.K.Chugh
A-261, Defence Colony
New Delhi-110024

g/c d/p
29/10/15

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of NBC
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building:-DMRC, Property Development Area, Under Kalkaji Metro Station, Kalkaji NewDelhi-19

2. Type of occupancy:-Group-F Mercantile Building

3. Type of case: -Renewal.

4. Details of previous NOC:-No.F6/ DFS/ MS/ /2012/3841 Dated:17/10/2012

5. Fire safety directives No.- Nil

6. Date of inspection:-13/10/2015

7. Name of the inspecting officer:- D.B.Mukherjee,A.D.O.(BCP)

8. Name & designation of officer From the building side: -Mr.S.K.Chugh

9. Year of construction:- 2009

10. Applicant's letter No:-Nil, Dated 06/08/2015,

The building is comprised of ground and 01 upper floors. departmental store is running at ground floor and first floor is vacant.

Sl. No	Minimum Standards on fire Prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1. Access to Building				
	1) Road width	12mtr.	Provided	MR
	2) Gate width	06mtr.	Provided	MR
	3) Width of internal road	06m	Provided	MR
2. Number, Width Type & Arrangement of Exits				
A. Number of staircases				
	1. Upper floors	02	Provided	MR
	2. Basements	N/A	N/A	N/A
B. Width of staircase				
	1. Upper floors	1.50 m	1.50m & 1.80 m	MR
	2. Basements	N/A	N/A	N/A
C. Protection of exits				
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	2m	Provided	MR
3. Compartmentation				
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4. Smoke Management System				
	1) Basements	30 a/c per hour	N/A	N/A
	2) Upper floors	12 a/c per hour	Exhaust Fans	MR
5. Fire Extinguishers				
	1) Total numbers	ISI Marked	25nos.	MR
	2) Types		ABC, Co2	MR
	3) ISI marking		Yes	MR

6.	First-Aid Hose Reel			
	1) Total number on each floor	01	Provided	MR
	2) Length of hose reel hose	30 m	Yes	MR
	3) Nozzle diameter	5 mm	Yes	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Required	Provided Smoke Type	MR
	2) Location of main panel	Required	Provided at GF	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	Every place	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	Required	Provided	MR
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 mm.	Provided	MR
	2) Number of hydrants per floor	04 at GF and 01 at FF	Provided	MR
	3) Hose box	04 at GF and 01 at FF	Provided	MR
12.	Yard Hydrants			
	1) Total number of hydrants	Required	Provided 02 nos.	MR
	2) Hose box	Required	Provided	MR
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	900 lpm	Provided 1680 lpm	MR
	b) Head of main pump	40 m	Provided 50m	MR
	c) Number of main pump	01	Provided 02 nos	MR
	d) Jockey pump out put	180 lpm	Provided	MR
	e) Jockey pump head	40m	Provided	MR
	f) Stand by pump output	Required	1680 lpm	MR
	g) Stand by pump head	Required	50m	MR
	h) Auto starting/Manual stopping	Required	Provided	MR
	Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	25,000ltrs.	Provided 1,00,000ltrs.	MR
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	N/A	N/A	N/A
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A

N/R

17.	Stand by Power Supply	Required	Provided DG Set	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room			
	a) Detector system panel	Required	Provided	MR
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	Required	Provided	MR
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:	N/A	N/A	N/A

The fire protection system provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/ DFS/ MS/ /2012/3841 Dated 17/10/2012 renewal under rules 35 of the Delhi Fire Service Rules 2010 is recommended

Accordingly DFA is put up for perusal and signature please.

D.B. Mukherjee
15/10/2015

Signature of the inspecting officer
Name: - D.B.Mukherjee.
Designation:- A D O (BCP)