

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001


No. F6/DFS/MS/School/w15/M02/1930

Dated: 28/10/15

FIRE SAFETY CERTIFICATE

Certified that the Mother Marry Public School, 292-B, Main Road, Mandawali, Delhi-92., comprising of ground plus four upper floors, owned/occupied by Mother Marry Public School have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 verified by the officer concerned of this department on 18.09.2015 in the presence of Mr. Surendra Verma (Principal) of the school and found that the school building is fit for occupancy class B 'Educational Building' for GF+FF+SF+TF+FF with effect from 28.10.15... for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on28.10.15..... at New Delhi by



(G.C. Misra)
Chief Fire Officer
Ph.011-23414333

o/g R/S

To,
The Principal
Mother Marry Public School,
292-B, Main Road, Mandawali,
Delhi-110092.

Copy to:-
The Director of Education, EDMC
Udyog Sadan, Plot No. 419, 1st floor
FIE, Patparganj Industrial Area, Delhi-92.

- CONDITIONS -

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form'J'[sub rule(1) of rule 37] along with a copy of this certificate,six months prior to its expiry"

1. Name & address of the building : Mother Marry Public School, 292-B, Main Road, Mandawali, Delhi-92.
2. Building is comprised of : G+4 upper floor
3. Type of Occupancy : Educational
4. Type of Case : New
5. Details of Previous NOC letter : Nil
6. Fire Safety direction letter No : Delhi Fire Service Act 2007 and Rules 2010
7. Date of Inspection : 18/09/2015
8. Name of the Inspecting officers : ADO R.K. Yadav
9. Name and designation of Officer from the building side : Mr. Surendra Verma (Principal)
10. Year of Construction : 2001
11. Applicant's letter No : Letter No. MMPS/2015/A(2), dated- 31.08.2015

Sr. No.	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building.			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	06 mtr.	06 mtr.	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	01 Nos.	02 No.	MR
		N/A	N/A.	N/A
	B. Width of Staircases			
	<ul style="list-style-type: none"> • Upper Floor 	1.5 mtr.	1.5 mtr., (1.05 mtr. up to second floor & 1.2 mtr., from second floor to terrace)	MR *
	<ul style="list-style-type: none"> • Basement 	N/A	N/A	N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A	N/A	N/A
		N/A	N/A	N/A
	d. No. of continuous staircases to terrace	01 No.	01 No.	MR
	e. Width of Corridor	1.5 mtr.	1.5 mtr.	MR
	f. Door Size	01 mtr.	01 mtr.	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basement • Upper floor 	N/A	N/A	N/A
		N/A	N/A	N/A
5	Fire Extinguishers.			
	<ul style="list-style-type: none"> • Total numbers • Types • ISI marking 	10 nos.	10 nos.	MR
		ABC /CO ₂	ABC /CO ₂	MR
		ISI marked	ISI marked	MR

6	First-aid-Hose Reels.			
	Total numbers on each floor	01 No.	Provided	MR
	• Length of hose reel hose	30 mtr.	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	01 no.	Provided	MR
	• Hose Box	01 no.	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	• Discharge of main Pump	N/A	N/A	N/A
	• Head of Main Pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump Head	N/A	N/A	N/A
	• Auto Starting /Manual stopping	N/A	N/A	N/A
	• Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	• Discharge of pump	900 Lpm.	Provided	MR
	• Head of the Pump	40 M	Provided	MR
	• Power supply	Required	Provided	MR
	• Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	25,000 Ltr.	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the Delhi Fire Service Act 2007 and Rules 2010, it is recommended to grant Fire Safety Certificate.

Signature of the Inspecting Officer

Name : R.K.Yadav

Designation: ADO

R.K. Yadav
24/9/16

DO(ED)

Submitted for approval please.