

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001


No. F6/DFS/MS/Ind./2015/West/ 1956

Dated: 30 / 10 /2015

FIRE SAFETY CERTIFICATE

Certified that the Building at Plot No. J-32, Udyog Nagar, Industrial Area, Main Rohtak Road, New Delhi-110041, comprised of Basement, Ground Floor, Mezzanine Floor, First Floor only owned / occupied by **Vardhman Industries**, has already been issued Fire Safety Certificate vide letter No.F6/DFS/MS/89/BP/998 dated 05.06.1989. The premises / Building was re-inspected by the officer concerned of Fire Service on 05.10.2015 in the presence of **Sh. Ashok Puri** and found that building / premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building / premises is fit for occupancy class **Industrial** with effect from 30 / 10 /2015 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued on 30/10/15 **at New Delhi by.**


(SANTOKH SINGH)
CHIEF FIRE OFFICER,
PHONE NO. 011-23414250.

Copy to :-

1. Authorized Signatory, Vardhman Industries, Plot No. J-32, Udyog Nagar, Industrial Area, Main Rohtak Road, New Delhi-110041.
2. Executive Eng. (Bldg.), NDMC, Sec-5, Rohini, Delhi-110085, with a request to verify unauthorized construction if any.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc. shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

B, G.F, Mes. H.O. & F.F

1. Name & address of the building: **Plot No. J-32, Udyog Nagar, Industrial Area, Main Rohtak Road, New Delhi-110041.**
2. Type of Occupancy : Industrial (Class-G)
3. Type of Case : Renewal ✓
4. Details of previous NOC : No.F5(J)/DFS/92/555 dated 03.11.1992
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/85/200 dated 26.03.1985
6. Date of inspection : 05/10/2015
7. Name of the Inspecting Officer : A. K.-Jaiswal
8. Name and designation of Officer
from the building side : Sh. Ashok Puri
9. Year of Construction : 1992
10. Applicant's letter No. : -Nil

| S No | Minimum standards on fire prevention and fire safety U/R 33 | BBL Requirements | Provided at site | Remarks MR/NMR |
|------|---|------------------------|------------------|----------------|
| 1. | Access of building | | | |
| | • Road width | 06 mtr | Provided | MR |
| | • Gate width | 4.5 mtr | Provided | MR |
| | • Width of internal road | 3 mtr | Provided | MR |
| 2. | Number, width, Type & Arrangements of exits | | | |
| | a. Number of staircases | | | |
| | • Upper floors | 2 | 2 | MR |
| | • Basements | 2 | 2 | MR |
| | b. Width of staircases | | | |
| | • Upper floors | 1.20 mtr. | Provided | MR |
| | • Basements | 1.20 mtr. | Provided | MR |
| | c. Protection of exits | | | |
| | • Fire check door | Required | Provided | MR |
| | • Pressurization | N/A | N/A | N/A |
| | d. No of continuous staircase to terrace | As per sanctioned plan | 1 | MR |
| | e. Width Of Corridor | NR (Halls only) | NR(Halls only) | NR |
| | f. Door Size | 1.00mtr | Provided | MR |
| 3. | Compartmentation | | | |
| | • Fire check door | Required | Provided | MR |
| | • Sealing of electrical shafts | Required | Provided | MR |
| | • Fire Rating of shaft door | NR | NR | NR |
| | • Water Curtain | NR | NR | NR |
| | • Fire Dampers | NR | NR | NR |
| 4. | Smoke managements System | | | |
| | • Basements | Exhaust Fan | Provided | MR |
| | • Upper floors | NR | NR | NR |
| 5. | Fire Extinguishers | | | |
| | • Total numbers | 06 | 10 | MR |
| | • Types | ISI marked | Provided | MR |

| | | | | |
|-----|---|---------------------------------|-------------|-------|
| | <ul style="list-style-type: none"> Total numbers on each floor | 1 | Provided | MR |
| | <ul style="list-style-type: none"> Length of hose reel hose | 30Mtr. | Provided | MR |
| | <ul style="list-style-type: none"> Nozzle diameter | 5mm. | Provided | MR |
| 7. | Automatic fire detection and alarming system | | | |
| | <ul style="list-style-type: none"> Type of detector | NR | NR | NR |
| | <ul style="list-style-type: none"> Location of Main Panel | NR | NR | NR |
| | <ul style="list-style-type: none"> Location of Repeater | NR | NR | NR |
| | <ul style="list-style-type: none"> Panel | NR | NR | NR |
| | <ul style="list-style-type: none"> Alternate source of power | NR | NR | NR |
| | <ul style="list-style-type: none"> Hooters' Location | NR | NR | NR |
| 8. | MOEFA | NR | NR | NR |
| 9. | Public Address System | NR | NR | NR |
| 10. | Automatic Sprinkler System | | | |
| | <ul style="list-style-type: none"> Basements | NR | NR | NR |
| | <ul style="list-style-type: none"> Upper Floor | NR | NR | NR |
| | <ul style="list-style-type: none"> Sprinkler above false ceiling | NR | NR | NR |
| 11. | Internal Hydrants | | | |
| | <ul style="list-style-type: none"> Size of riser/down-comer | NR | NR | NR |
| | <ul style="list-style-type: none"> Number of hydrants per floor | NR | NR | NR |
| | <ul style="list-style-type: none"> Hose Box | NR | NR | NR |
| 12. | Yard Hydrants | | | |
| | <ul style="list-style-type: none"> Total number of hydrants | NR | NR | NR |
| | <ul style="list-style-type: none"> Hose Box | NR | NR | NR |
| 13. | Pumping Arrangements | | | |
| | <ul style="list-style-type: none"> Ground Level | | | |
| | <ul style="list-style-type: none"> Discharge of main pump | NR | NR | NR |
| | ➤ Head of main pump | NR | NR | NR |
| | ➤ Number of main pumps | NR | NR | NR |
| | ➤ Jockey pump out put | NR | NR | NR |
| | ➤ Jockey pump head | NR | NR | NR |
| | ➤ Standby Pump out put | NR | NR | NR |
| | ➤ Standby Pump Head | NR | NR | NR |
| | ➤ Auto Starting/Manual stopping | NR | NR | NR |
| | ➤ Pump House Access | NR | NR | NR |
| | <ul style="list-style-type: none"> Terrace level | | | |
| | ➤ Discharge of pump | Not mentioned in recommendation | 900Lit/min. | MR |
| | ➤ Head of the pump | Not mentioned in recommendation | 40 mtr. | MR |
| | ➤ Power supply | Required | Provided | MR |
| | ➤ Auto starting of pump | Not mentioned in recommendation | Provided | MR |
| 14. | Captive water Storage for fire fighting | | | |
| | <ul style="list-style-type: none"> Underground tank capacity | 50,000 lts. | Provided | M/R ✓ |
| | ➤ Draw of connection | Required | Provided | M/R |
| | ➤ Fire service inlet | Required | Provided | M/R |

N/12

| | | | | |
|-----|--|----------|------------|-----|
| 15 | Exit Signage | Required | Provided | M/R |
| 16. | Provision of Lifts | | | |
| | ➤ Pressurization of Lift Shaft | N/A | N/A | N/A |
| | ➤ Pressurization of lift lobby | N/A | N/A | N/A |
| | ➤ Communication in lift Car | N/A | N/A | N/A |
| | ➤ Fireman's Grounding Switch | N/A | N/A | N/A |
| | ➤ Lift Signage | N/A | N/A | N/A |
| 17. | Standby power supply | NR | 100 K.V.A. | MR |
| 18. | Refuge Area | NR | NR | |
| | ➤ Total area | NR | NR | NR |
| | ➤ Location | NR | NR | NR |
| 19. | Fire control room | | | |
| | ➤ Detector system panel | NR | NR | NR |
| | ➤ Flow Switch Panel | NR | NR | NR |
| | ➤ PA System Panel | NR | NR | NR |
| | ➤ Battery backup | NR | NR | NR |
| | ➤ Building Floor Plans | NR | NR | NR |
| 20. | Special Fire Protection Systems for Protection of special Risks, if any; | NR | NR | NR |

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. MCB and Conduit Metal Wiring has also been provided.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. No.F5(J)/DFS/92/555 dated 03.11.1992 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Note:- Encroachment of left & rear set back area should be checked by the competent authority viz MCD.