

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/2015/ND2/1959

Dated: 02/11/15

FIRE SAFETY CERTIFICATE

Certified that the Industrial Building at Plot no.381,FIE,Patparganj, Delhi-92, owned/occupied by M/s Vijay Arora , comprising of basement, ground plus two upper floors was issued NOC vide letter no. F.5/(J)/DFS/2006/80 dated 23/02/2006.The Industrial building (Printing Press) was inspected by the officer concerned of this department on 10.08.15 & 30.09.15 in the presence of Sh.Vikas Arora (Manager) and found that the Industrial building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 and that B+GF+FF+SF of the building is fit for occupancy Group "Industrial Building" with effect from ..02/11/15... for a period of three years, subject to conditions printed overleaf.

Issued on02/11/15..... at New Delhi by



(Dr.G.C.Misra)
Chief Fire Officer
Ph.011-23414333

To,
Sh.Vijay Arora
Plot no.381,FIE Patparganj, Delhi-92



CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation,ventilation,structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. Basement shall be used as per BBL.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form'J'[sub rule(1) of rule 37] along with a copy of this certificate,six months prior to its expiry"

1. Name & address of the building : Plot No. -381, FIE, Patparganj Ind. area, Delhi -92.
2. Building Comprised of : B+G+2 upper floors
3. Type of Occupancy : Industrial Building
4. Type of Case : **Renewal**
5. Details of Previous NOC : F.5/(J)/DFS/2006/80 dated 23/02/2006
6. Fire Safety directives No : Nil
7. Date of Inspection : 10.08.2015 & 30.09.15
8. Name of the Inspecting Officer : ADO Suresh Singh
9. Name of the designation of Officer
From the building side : Sh.Vikas Arora (Manager)
10. Year of Construction : 2002
11. Applicant's letter No. : Nil dated 26.06.15

	Minimum Standards on fire prevention and fire safety U/R33	Existing	Provided at Site	Remarks
1	Access to building			MR/NMR
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	12 Mtrs	13 Mtrs.	MR
		4.5Mtrs.	4.5 Mtrs.	MR
		N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	2 nos.	2 nos.	MR
		2 nos.	2 nos.	MR
	B. Width of Staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	1.25 M	1.25 M & 70 CM	MR
		1.25 M	1.25 M & 70 CM	MR
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A	N/A	N/A
		N/A	N/A	N/A
	e. No. of continuous staircases to terrace	1 nos.	1 no.	MR
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	1.0 M	1.0 M	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basement • Upper floor 	Required	Provided	MR
		N/A	N/A	N/A
5.	Fire Extinguisher			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	08 nos.	10 nos.	MR
		ABC & Co2	ABC & Co2	MR
		ISI marked	ISI marked	MR

6	First-aid-Hose Reels.			
	<ul style="list-style-type: none"> Total numbers of each floor 	01 no.	01 no.	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m	30 m	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	5 mm	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location of main panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location of repeater panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Alternate source of power 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hooters's location 	N/A	N/A	N/A
8	MOEFA	N/A	Provided	MR
9	Public address System.	N/A	Provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement 	Required	Provided	MR
	<ul style="list-style-type: none"> upper floor 	N/A	N/A	N/A
	<ul style="list-style-type: none"> sprinkler above false ceiling 	N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> size of riser/down-comer 	N/A	100 mm	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	N/A	1 no.	MR
	<ul style="list-style-type: none"> Hose Box 	N/A	1 no.	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hose Box 	N/A	N/A	N/A
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Head of Main Pump 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Number of main pumps 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Jockey pump out put 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Jockey pump head 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Standby pump out put 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Standby pump Head 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Auto Starting /Manual stopping 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Pump House Access 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Terrace Level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump 	450 LPM	900 LPM	MR
	<ul style="list-style-type: none"> ➤ Head of the Pump 	35 Mtrs.	38 mtrs.	MR
	<ul style="list-style-type: none"> ➤ Power supply 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Auto Starting of pump 	N/A	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	<ul style="list-style-type: none"> Underground tank capacity 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Draw-off connection 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Fire service inlet 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Access to tank 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Overhead Tank capacity 	10,000 Ltrs.	10,000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules .The NOC issued vide letter no. F.5/(J)/DFS/2006/80 dated 23/02/2006 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended for fire safety certificate.



Singh
12/10/15

Signature of the Inspecting Officer

Name:-Suresh Singh

Designation:-ADO(Shah.)

DO(ED)

Submitted for approval please.

Wish