

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/Hospital/2015/1402/1958

Dated: 02/11/15

FIRE SAFETY CERTIFICATE

Certified that the Ram Lal Kundan Lal Orthopaedic Hospital at Plot No.8, Ganesh Nagar, Patparganj Road, Delhi-92, owned/occupied by M/s Ram Lal Kundan Lal Orthopaedic Hospital, comprised of basement, ground plus four upper floor was granted fire safety certificate vide letter no. F6/MS/DFS/Hospital/2012/1910 dated 25.05.12. The Hospital building was inspected by the officers concerned of this department on 14.10.15 in the presence of Sh. Pankaj Kapur (Administrator) and found that the Hospital building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 and that B+GF+FF+SF+TF+Fourth floor of the building is fit for occupancy Group C "Institutional Building" with effect from 02/11/15.... for a period of three years, subject to conditions printed overleaf.

Issued on02/11/15..... at New Delhi by



(Dr. G.C. Misra)
Chief Fire Officer
011-23414333

To,
Sh. Pankaj Kapur
(Administrator)
Ram Lal Kundan Lal Orthopaedic Hospital
Plot No.8, Ganesh Nagar, Patparganj Road,
Delhi-92



CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized if any.
6. Basements shall be used as per BBL.
7. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

1. Name & address of the building: Ram Lal Kundan Lal Orthopaedic Hospital at Plot No.8, Pandav Nagar, Patparganj Road, Delhi -110092.
2. Building is comprised : basement, Ground + 4, upper floors.
3. Type of Occupancy : Institutional
4. Type of Case : **Renewal**
5. Details of Previous NOC letter : F.6/MS/DFS/Hospital/2012/1910 Dated 25.05.12
6. Fire Safety direction letter No : DFP&FS Act 1986 & Rules there under (12 Bare Min. Requiredments)
7. Date of Inspection : 14/10/15
8. Name of the Inspecting officers : DO Virendra Singh & R.K.Yadav
9. Name and designation of Officer:
from the building side : Sh.Pankaj Kapur (Administrator)
10. Year of Construction : 1994
11. Applicant's letter: : 10/09.15

S.NO.	Minimum Standards on fire prevention and fire safety U/R33	Requirement (12 bare Min.)	Provided at Site	Remarks MR/NMR
1	Access to building	06 Mtrs.	15 Mtrs.	MR
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	N/A	N/A	N/A
		N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	2 nos.	2 nos.	MR
	<ul style="list-style-type: none"> Upper Floor Basement 	2 nos.	2 nos.+Ramp	MR
	B. Width of Staircases	1.40 M& 80 CM	1.40 M& 80 CM	MR
	<ul style="list-style-type: none"> Upper Floor Basement 	1.30 M	1.30 M each	MR
	c. Protection of exits	Required	Provided	MR
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	1no.	1 no.	MR
	g. Width of Corridor	1.5 Mtrs.	2 Mtrs.	MR
	h. Door Size	1.0 Mtr.	1.0 Mtr.	MR
3	Compartmentation.	Required	Provided	MR
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire rating of shaft door Water curtain Fire Dampers 	Required	sealed	MR
		Required	Provided	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
4	Smoke Management System.	Required	Provided	MR
	<ul style="list-style-type: none"> Basement Upper floor 	N/A	N/A	N/A
5.	Fire Extinguisher	11 Nos.	20 Nos.	MR
	<ul style="list-style-type: none"> Total numbers Types IS marking 	ABC & Co2	ABC & Co2	MR
		ISI marked	ISI marked	MR

6	First-aid-Hose Reels.			
	<ul style="list-style-type: none"> Total numbers of each floor Length of hose reel hose Nozzle diameter 	01 no.	01 no.	MR
		30 m	30 m	MR
		5 mm	5 mm	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of main panel Location of repeater panel Alternate source of power 	Heat & smoke	Provided	MR
		Reception	Provided	MR
		N/A	N/A	N/A
		Required	Provided	MR
	<ul style="list-style-type: none"> Hooters's location 	Near Staircases	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System.	Required	Provided	MR
	<ul style="list-style-type: none"> Basement 	Required	Provided	MR
	<ul style="list-style-type: none"> upper floor 	N/A	N/A	N/A
	<ul style="list-style-type: none"> sprinkler above false ceiling 	N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> size of riser/down-comer 	100 mm	100 mm	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	01 No.	01No.	MR
	<ul style="list-style-type: none"> Hose Box 	01 No.	01 No.	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hose Box 	N/A	N/A	N/A
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	450 LPM	450LPM	MR
	<ul style="list-style-type: none"> ➤ Head of Main Pump 	40 M	40 M	MR
	<ul style="list-style-type: none"> ➤ Number of main pumps 	1 No.	1 No.	MR
	<ul style="list-style-type: none"> ➤ Jockey pump out put 	N/A	180 LPM	MR
	<ul style="list-style-type: none"> ➤ Jockey pump head 	N/A	40 M	MR
	<ul style="list-style-type: none"> ➤ Standby pump out put 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Standby pump Head 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Auto Starting /Manual stopping 	Auto	Provided	MR
	<ul style="list-style-type: none"> ➤ Pump House Access 	Required	Provided	MR
	<ul style="list-style-type: none"> Terrace Level 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Discharge of pump 	450 LPM	450LPM	MR
	<ul style="list-style-type: none"> ➤ Head of the Pump 	40 M	40 M	MR
	<ul style="list-style-type: none"> ➤ Power supply 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Auto Starting of pump 	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	<ul style="list-style-type: none"> Underground tank capacity 	50 ,000 Ltrs.	50,000 Ltrs.	MR
	<ul style="list-style-type: none"> ➤ Draw-off connection 	N/A	Provided	MR
	<ul style="list-style-type: none"> ➤ Fire service inlet 	N/A	Provided	MR
	<ul style="list-style-type: none"> ➤ Access to tank 	N/A	Provided	MR
	<ul style="list-style-type: none"> Overhead Tank capacity 	5,000 Ltrs.	5,000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft 	N/A	Provided	MR
	<ul style="list-style-type: none"> Pressurization of Lift lobby 	N/A	Provided	MR
	<ul style="list-style-type: none"> Communication in lift car 	N/A	Provided	MR
	<ul style="list-style-type: none"> Firemen's grounding switch 	Required	Provided	MR
	<ul style="list-style-type: none"> Lift Signage 	Required	Provided	MR

N/17

17	Standby power supply	Required	Provided	MR
18	Refuge Area.	Required	Provided	MR
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
	• Detector system panel	Required	Provided	MR
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
N/A	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The fire safety certificate issued vide letter no. :F.6/MS/DFS/Hospital/2012/1910 Dated 25.05.12 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

R. K. Yadav
26/10/2016

Signature of the Inspecting Officer

Name:-R.K.Yadav

Designation :-ADO(LN)

DO(ED)

Submitted for approval please.

