

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**

No.F6/DFS/MS/GH/2015/ N02/1979

Dated : 09/11/15

**FIRE SAFETY CERTIFICATE**

Certified that the **Chopra International Guest House 4060, Gali Kaseruwalan, Pahar Ganj, New Delhi** comprised of Ground + 5 Upper Floors (Ground floor reception + office + lobby, 1<sup>st</sup> floor to 3<sup>rd</sup> floor 06 guest rooms at each floors, 4<sup>th</sup> floor 03 rooms used at residence, 5<sup>th</sup> floor found sealed total 18 guest rooms) was granted FSC by this department vide letter No.F6/MS/DFS/GH/2012/3997 dated 25/10/2012. The premise was re-inspected by the officer concerned of this department on 20/10/15 in the presence of **Sh. Sahail (Manager)** and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Residential Group A-1 for 18 guest rooms only as above** with effect from 09/11/15 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 09/11/15 at New Delhi by.

  
(DR. G.C.Misra)  
Chief Fire Officer  
Delhi Fire Service  
Ph: - 011-23414333

- Copy to: (1) The Joint Commissioner of Police (Lic.), 1<sup>st</sup> Floor,  
Police Station, Defence Colony, New Delhi.  
(2) The Licensee,  
Chopra International Guest House,  
4060, Gali Kaseruwalan, Pahar Ganj, New Delhi.

**Conditions:-**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

-N/7-

### INSPECTION REPORT

1. Name & address of the building:- Chopra International Guest House 4060, Gali Kaseruwalan, Pahar Ganj, New Delhi.
2. Type of occupancy:- Residential Group A-1 Ground + 5 Upper Floors.(18 guest rooms)
3. Type of case:- Renewal
4. Details of previous FSC:- No. F6/MS/DFS/GH/2012/3997 dated 25/10/2012.
5. Fire safety directives No.- N/A
6. Date of inspection:- 20/10/15
7. Name of the inspecting officer:- D.O. Gurmukh Singh
8. Name & designation of officer  
From the building side:- Mr. Sahail (Manager)
9. Year of construction:- 2009
10. Applicant's letter No:- 1725/Joint C.P./ Lic. (H) dated 15/09/15  
Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement (PSS Area)	Provided at site PSS	Remarks MR/NMR
1.	Access to Building			
	1) Road width	N/A	6 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	01 No.	01 No.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	80 cms.	1.30 mtr.	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1 mtr.	1 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 ACPH	N/A	N/A
	2) Upper floors	12 ACPH	Natural	MR
5.	Fire Extinguishers			
	1) Total numbers	12 Nos.	12 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR

h.

	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	2,500 ltrs.	2,500 ltrs.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the guest house were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No.F6/DFS/MS/GH/2012/3997 dated 25/10/2012, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended

*Gurmukh Singh*  
GTA/15

Gurmukh Singh  
Divisional Officer

Dy. C.F.O. (NDZ)

FIRE SAFETY