

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/school/2015/ND2/1991

Dated: 04/11/15

FIRE SAFETY CERTIFICATE

Certified that the D.A.V. Public School at Pocket-C, LIG, DDA Flats, East of Loni Road, Delhi-110093, comprised of ground plus two upper floors owned/occupied by D.A.V. Public School was granted FSC vide letter No.-F.6/DFS/MS/2011/2052 dated 19/08/2011. The school building was re-inspected by the officer concerned of this department on 05/10/2015 in the presence of Mrs. Sameeksha Sharma, Principal of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and that the building GF+FF+SF is fit for occupancy class B "Educational Building" with effect from 04.11.15..... for a period of **three** years, subject to conditions printed overleaf.

Issued on04.11.15..... at New Delhi by



(Dr. G.C. Misra)
Chief Fire Officer
Ph.011-23414333

O/c
by

To,
The Manager,
D.A.V. Public School,
Pocket-C, LIG, DDA Flats,
East of Loni Road, Delhi-110093

Copy to:-
The Dy. Director of Education,
North-East, B-Block,
Yamuna Vihar, Delhi-110053

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry

1. Name & address of the building : D.A.V. Public School,
Pocket-C, LIG DDA Flats,
East of Loni Road, Delhi-110093
2. Building is comprised of : **Ground plus two upper floors**
3. Type of Occupancy : Educational
4. Type of Case : **Renewal**
5. Details of Previous FSC letter : F.6/DFS/MS/2011/2052 dated-19/08/2011
6. Fire Safety direction letter No : NBC Part-IV
7. Date of Inspection : 05/10/2015
8. Name of the Inspecting officers : ADO Vijay Bahadur
9. Name and designation of Officer
from the building side : Mrs. Sameeksha Sharma (Principal)
10. Year of Construction : 2001
11. Applicant's letter No : No.-DAVPS/Loni Road/2015/125, Dated- 23/09/2015

| Sr. No. | Minimum Standards on Fire Prevention and Fire Safety U/R33 | NBC Part-IV Requirement | Provided at Site | Remarks MR/NMR |
|---------|--|-------------------------|----------------------|----------------|
| 01 | Access to Building. | | | |
| | • Road width | 06 mtr. | 06 mtr. | MR |
| | • Gate width | 4.50 mtr. | 05 mtr. | MR |
| | • Width of internal road | N/A | N/A | N/A |
| 02 | Number, Width, Type and Arrangement of Exits. | | | |
| | a. Number of Staircases | | | |
| | • Upper floor | 02 Nos. | 02 Nos. | MR |
| | • Basement | N/A | N/A | N/A |
| | b. Width of Staircases | | | |
| | • Upper floor | 1.50 mtr. | 1.50 mtr. each | MR |
| | • Basement | N/A | N/A | N/A |
| | c. Protection of exits | | | |
| | • Fire check door | N/A | N/A | N/A |
| | • Pressurization | N/A | N/A | N/A |
| | d. No. of Continuous Staircases to Terrace | 01 Nos. | 02 Nos. | MR |
| | e. Width of Corridor | 1.50 mtr. | 1.70 mtr | MR |
| | f. Door Size | 01 mtr. | 1.10 mtr. | MR |
| 03 | Compartmentation. | | | |
| | • Fire check door | N/A | N/A | N/A |
| | • Sealing of electrical shafts | N/A | N/A | N/A |
| | • Fire rating of shaft door | N/A | N/A | N/A |
| | • Water curtain | N/A | N/A | N/A |
| | • Fire dampers | N/A | N/A | N/A |
| 04 | Smoke Management System. | | | |
| | • Basement | N/A | N/A | N/A |
| | • Upper floor | N/A | N/A | N/A |
| 05. | Fire Extinguishers. | | | |
| | • Total numbers | 12 nos. | 20 nos. | MR |
| | • Types | ABC /CO ₂ | ABC /CO ₂ | MR |
| | • IS marking | ISI marked | ISI marked | MR |

| | | | | |
|----|---|-------------|-------------|-----|
| 06 | First-Aid-Hose Reels. | | | |
| | Total numbers on each floor | 01 No. | 01 No. | MR |
| | • Length of hose reel hose | 30 mtr. | 30 mtr. | MR |
| | • Nozzle diameter | 05 mm | 05 mm | MR |
| 07 | Automatic Fire Detection and Alarming System. | | | |
| | • Type of detectors | N/A | N/A | N/A |
| | • Location of main panel | N/A | N/A | N/A |
| | • Location of repeater panel | N/A | N/A | N/A |
| | • Alternate source of power | N/A | N/A | N/A |
| | • Hooter's location | N/A | N/A | N/A |
| 08 | MOEFA | N/A | N/A | N/A |
| 09 | Public Address System. | N/A | N/A | N/A |
| 10 | Automatic Sprinkler System. | | | |
| | • Basement | N/A | N/A | N/A |
| | • upper floor | N/A | N/A | N/A |
| | • sprinkler above false ceiling | N/A | N/A | N/A |
| 11 | Internal Hydrants | | | |
| | • size of riser/down-corer | N/A | N/A | N/A |
| | • Number of hydrants per floor | N/A | N/A | N/A |
| | • Hose box | N/A | N/A | N/A |
| 12 | Yard Hydrants. | | | |
| | • Total number of hydrants | N/A | N/A | N/A |
| | • Hose Box | N/A | N/A | N/A |
| 13 | Pumping Arrangements. | | | |
| | ➤ Ground Level | | | |
| | • Discharge of main pump | N/A | N/A | N/A |
| | • Head of Main pump | N/A | N/A | N/A |
| | • Number of main pumps | N/A | N/A | N/A |
| | • Jockey pump out put | N/A | N/A | N/A |
| | • Jockey pump head | N/A | N/A | N/A |
| | • Standby pump out put | N/A | N/A | N/A |
| | • Standby pump head | N/A | N/A | N/A |
| | • Auto Starting /Manual stopping | N/A | N/A | N/A |
| | • Pump house access | N/A | N/A | N/A |
| | ➤ Terrace Level | | | |
| | • Discharge of pump | 450 Lpm. | 450 Lpm. | MR |
| | • Head of the pump | 40 M | 40 M | MR |
| | • Power supply | Required | Provided | MR |
| | • Auto Starting of pump | Required | Provided | MR |
| 14 | Captive Water Storage for Fire Fighting. | | | |
| | • Underground tank capacity | N/A | N/A | N/A |
| | • Draw-off connection | N/A | N/A | N/A |
| | • Fire service inlet | N/A | N/A | N/A |
| | • Access to tank | N/A | N/A | N/A |
| | • Overhead tank capacity | 10,000 Ltr. | 10,000 Ltr. | MR |
| 15 | Exit Signage. | Required | Provided | MR |
| 16 | Provision of Lifts. | | | |
| | • Pressurization of lift shaft | N/A | N/A | N/A |
| | • Pressurization of lift lobby | N/A | N/A | N/A |
| | • Communication in lift car | N/A | N/A | N/A |
| | • Firemen's grounding switch | N/A | N/A | N/A |

N/8

| | | | | |
|----|--|-----|-----|-----|
| 17 | Standby Power Supply | N/A | N/A | N/A |
| 18 | Refuge Area. | | | |
| | • Total area | N/A | N/A | N/A |
| | • Location | N/A | N/A | N/A |
| 19 | Fire Control Room | | | |
| | • Detector system panel | N/A | N/A | N/A |
| | • Flow switch panel | N/A | N/A | N/A |
| | • PA system panel | N/A | N/A | N/A |
| | • Battery backup | N/A | N/A | N/A |
| | • Building floor plans | N/A | N/A | N/A |
| 20 | Special Fire Protection Systems for Protection of Special Risks, if any: | N/A | N/A | N/A |

The fire protection systems provided in the building were tested/checked at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety as required under the rules, the Fire Safety Certificate issued vide letter no-F.6/DFS/MS/2011/2052 Dated-19/08/2011 renewal under rule 35 of the Delhi Fire Service Rule 2010, is recommended.


20/8/15

Signature of the Inspecting Officer
Name- Vijay Bahadur
Designation- A.D.O