

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F6/DFS/MS/School/2015/52/1992

Dated: 05/11/15

FIRE SAFETY CERTIFICATE

Certified that the Dropati Davi Memorial Education Society located at Ground plus two upper floors Plot no. NS-2, R Block, Pitam Pura Delhi in a building comprised of Basement + Ground + 02 Upper Floors was issued FSC vide Letter No. F6/MS/DFS/2012/537 Dated 17-02-2012. The premises was re inspected by the officer concerned of this department on 20-10-2015 in the presence of Sh S K Jain (Director) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance NBC and that the premises (Ground + 02 upper floors Except Basement) is fit for occupancy class "Educational" Group B with effect from 05/11/15 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 05/11/15 at New Delhi by.

  
(Santokh Singh)  
Chief Fire Officer  
Delhi Fire Service  
Tel . 011-23424250

Copy to: The Principal, Dropati Davi Memorial Education Society Plot no. NS-2, RP Block, Pitam Pura Delhi

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. Basement shall not be used for any purpose without getting clearance from this department.

INSPECTION REPORT

1. Name & address of the building: **Dropati Davi Memorial Education Society** located at **Plot no. NS-2,R Block,Pitam Pura Delhi**
2. Type of Occupancy : **Educational at Ground + two upper floors in a building comprised of Basement + Ground + 2 Upper Floor(Basement Sealed & not be used for any purpose)**
3. Type of Case : Renewal
4. Details of previous NOC : **F6/MS/DFS/2012/537 Dated 17-02-2012**
5. Fire Safety directives Letter No. : **F -6/DFS/MS/2011/BP/335 dated 18-02-2011**
6. Date of inspection : **20-10-2015**
7. Name of the Inspecting Officer : **Udaivir Singh,ADO (WP)**
8. Name and designation of Officer  
from the building side : **Sh. SK Jain (Director)**
9. Year of Construction : **2012**
10. Applicant's letter No. : **nil Dated nil**

No of students-350 class rooms-14 Plot area - 753m <sup>2</sup> covered area = <b>253 m<sup>2</sup></b> Upper Floors - 251m <sup>2</sup>
---

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 mtrs	23.5 mtrs	MR
	• Gate width	4.5m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	2	01 Provided	NA
	b. Width of staircases			
	• Upper floors	1x1.5m&1x1.25m	Provided	MR
	• Basements	1.5mtrs	1x1.5m	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1x1.5m&1x1.25m	Provided	MR
	e. Width Of Corridor	1.5m	Old case	MR
	f. Door Size	100cm	Provided	MR

3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	Required	Not Provided	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	10 nos. ABC & CO <sub>2</sub> ISI marked	Provided	MR
	• Types		Provided	MR
	• IS marking		Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	1	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down-comer	Required	Provided	MR
	• Number of hydrants per floor	1	Provided	MR
	• Hose Box	1	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA

umping Arrangements:

<ul style="list-style-type: none"> <li>• Ground Level</li> <li>• Discharge of main pump</li> <li>➤ Head of main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Staring/Manual stopping</li> <li>➤ Pump House Access</li> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power supply</li> <li>➤ Auto starting of pump</li> </ul>	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	1X450 lpm	Provided	MR
	40Mtr	Provided	MR
	Required	Provided	MR
	Required	Provided	MR
	14. Captive water Storage for firefighting:		
<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	NA	NA	NA
	NA	NA	NA
	NA	Provided	NA
	NA	NA	NA
	10,000Ltr	Provided 10,000litres	MR
15. Exit Signage	Required	Provided	MR
16. Provision of Lifts			
<ul style="list-style-type: none"> <li>➤ Pressurization of Lift Shaft</li> <li>➤ Pressurization of lift lobby</li> <li>➤ Communication in lift Car</li> <li>➤ Fireman's Grounding Switch</li> <li>➤ Lift Signage</li> </ul>	NA	NA	NA
	NA	NA	NA
	Required	Provided	MR
	Required	Provided	MR
	Required	Provided	MR
17. Standby power supply	NA	NA	NA
18. Refuge Area			
<ul style="list-style-type: none"> <li>➤ Total area</li> <li>➤ Location</li> </ul>	NA	NA	NA
	NA	NA	NA
19. Fire control room			
<ul style="list-style-type: none"> <li>➤ Detector system panel</li> <li>➤ Flow Switch Panel</li> <li>➤ PA System Panel</li> <li>➤ Battery backup</li> <li>➤ Building Floor Plans</li> </ul>	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA

20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
-----	--	----	----	----

Note:-General requirements for schools as per Director of Education circular dated 01/03/2011.

1. Escape route .....Clear.....
2. LPG cylinders in laboratories NA
3. Electric wiring ...Conduit Wiring..... MCB and ELCB .....  
Electric circuit .....
4. Electric meter board .....Not under the staircase.....
5. Basement use as per BBL 1983 ... NA
6. Emergency telephone no. board ...Displayed.....
7. Generator set .....NA.....

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. **F6/MS/DFS/2012/537 Dated 17-02-2012** renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Note.; Earlier FSC was issued for all floors (Basement + Ground + two Upper Floors) Now School management submit undertaking to seal the basement. Hence FSC is recommended for upper floors without basement.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Uday Vir Singh

Name

Designation

ASO/WP

Designation

