

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.

F6/DFS/MS/2012/2817 2012/2817 1972

Dated:

03/11/15

FIRE SAFETY CERTIFICATE

Certified that the **Prabhu Dayal Public School** located at **Dakshni Block A, Shalimar Bagh, Delhi - 110034** comprised of Ground + 02 Upper Floors was issued FSC vide Letter No. F6/DFS/MS/2012/2817 Dated 31/07/2012. The premises was re inspected by the officer concerned of this department on 12-10-2015 in the presence of Mr. Latesh Jain and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance NBC part-IV/DOE Circular 262-362 Dated 17-01-2005 and that the premises is fit for occupancy class "Educational" Group B with effect from 03/11/15 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 03/11/15..... at New Delhi by.



(Santokh Singh)

Chief Fire Officer

PH 011-23414250

Copy to:

The Principal, Prabhu Dayal Public School, Dakshni Block A, Shalimar Bagh, Delhi - 110034
Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. All the exit shall be kept free from any obstruction.

INSPECTION REPORT

1. Name & address of the building: Prabhu Dayal Public School, Dakshni Block A, Shalimar Bagh, Delhi – 110034.
Type of Occupancy : Educational (Ground + 2 Upper Floor)
2. Type of Case : Renewal
3. Details of previous NOC : F6/DFS/MS/ School/2012/2817 Dated 31/07/2012
4. Fire Safety directives Letter No. : Nil dated
5. Date of inspection : 12/10/2015
6. Name of the Inspecting Officer : ADO (WP)
7. Name and designation of Officer
from the building side : Mr. Latesh Jain
8. Year of Construction : 1987
9. Applicant's letter No. : 767 Dated . 01-10 -2015

Total Area = 600 m²
 Covered Area = 2200m²
 Class rooms = 54
 No. of students = 1394

S No	Minimum standards on fire prevention and fire safety U/R 33	Cir 262-362 dated 17/01/2005	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	Accessible	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	03	05	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	150cm	Old Case	MR(Being old case)
	c. Basements			
	d. Protection of exits	NA	NA	NA
	• Fire check door			
	• Pressurization	NA	NA	NA
	e. No of continuous staircase to terrace	NA	NA	NA
	f. Width Of Corridor	NA	NA	NA
	g. Door Size	1mtrs	110 cm provided	MR

All the class room having < 45 students. Jb

N/15

3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	20 nos.	30 Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	02	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down comer	100mm	Provided	MR
	• Number of hydrants per floor	02	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA

13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ No. of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		900 lpm 180 lpm	2x450 Lpm&1x180lpm	MR ✓
		40Mtr	40 Mtr	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		10000Ltr	Provided	MR
15	Exit Signage	Required	Provided	MR ✓
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	Provided ✓	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA

N/17

20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
-----	--	----	----	----

Note:-General requirements for schools as per Director of Education circular dated 01/03/2011.

1. Escape routeClear.....
2. LPG cylinders in laboratories ; NA
3. Electric wiring ...canceled Wiring..... MCB and ELCB
.....
Electric circuit
4. Electric meter boardunder the staircase in metal box.....
5. Basement use as per BBL 1983 ... NA
6. Emergency telephone no. boardDisplayed...
7. Generator set Provided out side the building

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/2012/2817 Dated 31/07/2012 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Uday Vir Singh

Name

Designation

AD/WP

Designation

D/W

