

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001


NO. F6/DFS/MS/School/2015/School/52/1982

Dated: 04/11/15

FIRE SAFETY CERTIFICATE

Certified that M/S The Heritage School, D-2, Vasant Kunj, New Delhi-110070, comprised of basement, ground plus three upper floors, owned/occupied by The Heritage School, was granted No Objection Certificate by this department vide letter No.F6/DFS/MS/School/2012/3829, dated 17.10.2012. The premises was re-inspected by the officer concerned of this department on 23-10-2015 in the presence of the Sh. Firoz, Assistant Manager of the school and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules 2010 and that the building is fit for occupancy class 'Educational' with effect from <sup>04/11/15</sup> for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules,2010.

Issued on <sup>04/11/15</sup> at New Delhi by



(Dr.G.C.Misra)

Chief Fire Officer

T.No.011-23414333



Copy to:-1. Director of Education, Old Secretariat, Civil Lines, Delhi-54.

2 .Principal, The Heritage School, D-2, Vasant Kunj, New Delhi-110070.

**Conditions for the validity of fire safety certificate are as under:-**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. The employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All fire fighting equipments shall be maintained in perfect working condition all time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate, six month prior to its expiry.



N 119

## INSPECTION REPORT

1	Name & address of the building	M/S The Heritage School, D-2, Vasant Kunj, New Delhi-110070.		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	New Case/Renewal		
4	Details of previous NOC	No.F6/DFS/MS/School/2012/3829, Dated 17.10.2012.		
5	Fire safety directives letter No	No.F6/DFS/MS/BP/98/2172, Dated 27.10.98 & F6/DFS/BP/2014/05, dated 07.01.2014.		
6	Date of inspection	23.10.2015.		
7	Name of the inspecting Officers :	A.D.O. Vedpal.		
8	Name and designation of officers from the building side	Mr. Firoz Assistant Manager of the school.		
9	Building Comprised of	B+G+3.		
9	Year of construction	1999 & 2014.		
10	Applicant's letter No.	No,THSD-VK/FIRE/2015-16/001, Dated 14.10.2015.		

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per NBC	Provided at site	Remarks MR / NMR
--------	---	------------------------	------------------	------------------

<b>1</b>	<b>Access to building</b>			
	1) Road width	6m	6m	MR
	2) Gate width	Required	5m Provided	MR
	3) Width of internal road	N/A		N/A

<b>2</b>	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	03Nos.	03Nos.	MR
	2. basements	03Nos.	03Nos.+1 Ramp	MR
	<b>b. Width of staircase</b>			
	1. Upper floors	1.5m(Each)	1.7, 1.7 & 1.5m	MR
	2. basements	1.5m(Each)	1.7, 1.7. & 1.5m (Ramp=5m)	MR
	<b>c. Protection of exits</b>			
	1. Fire check door	Required	Provided in basement only.	MR
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	Required	02nos.	MR
	<b>e. Width of corridor</b>	N/A	N/A	N/A
	<b>f. Door size</b>	1 Mtr	Provided	MR

<b>3</b>	<b>Compartmentation.</b>			
	1. Fire check door	Required	Provided in basement only.	MR
	2. Sealing of electrical shafts	Required	Provided	MR
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A

<b>4</b>	<b>Smoke Management system.</b>			
	basement	30 a/c per hour	Provided	MR
	Upper Floors	12 a/c per hour	N/A	N/A

<b>5</b>	<b>Fire Extinguishers</b>			
	total numbers	24nos.	45nos.	MR
	Types		ABC & Water CO2	MR
	ISI marking		ISI Mark	MR

<b>6</b>	<b>First-Aid Hose Reels.</b>			
	total numbers on each floor	03nos.	03nos	MR
	Length of Hose reel hose	30 m	30m	MR
	Nozzle Diameter	5 mm	5mm	MR

<b>7</b>	<b>Automatic fire detection and alarming system</b>			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Control panel	N/A	N/A	N/A




8	MOEFA	Required	Provided	
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			MR
	basement	Required	Provided	
	upper floors	N/A	N/A	MR
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			N/A
	Size of riser/down-corner	N/A	N/A	
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			N/A
	total number of hydrants	N/A	N/A	
	hose box	N/A	N/A	N/A
13	Pumping arrangements			N/A
	1. Ground level	Required	Provided	
	a. Discharge of main Pump	900LPM	900LPM	MR
	b. Head of main pump	60m	60m	MR
	c. Number of main pumps	01no.	01no.	MR
	d. jockey pump out put	180LPM	180LPM	MR
	e. jockey pump head	60m	60m	MR
	f. Standby Pump output	N/A	N/A	MR
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	Required	Provided	N/A
	pump house access	Required	Provided	MR
	2. Terrace level			MR
	a. Discharge of pump	450LPM.	450LPM	MR
	b. head of the pump	40 mtr	40m	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	50000Liters	50000Liters	MR
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	Required	Provided	MR
	c. Access to tank	Required	Provided.	MR
	Over head tank Capacity	20000 Ltr.	20000Liters	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			MR
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			N/A
	total area		Not Required	
	location	N/A	N/A	N/A
		N/A	N/A	N/A

N/116

19	<b>Fire control room</b>			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	<b>Special Fire Protection systems for protection of special risks, if any: N/A</b>			

The fire protection systems provided in the building were test checked randomly and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the NOC issued vide letter No.F.6/DFS/MS/School/2012/3829, dated 17.10.2012 renewal under rule 35 of the Delhi Fire Service Rule 2010 is recommended.

Accordingly DFA is put up for your approval and signature please.

 26/10/15

Signature of the inspecting officer

Name: Vedpal

Designation : ADO

