

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI- 110001

No. F6/DFS/MS/School/2015/ND2/2012

Dated: 06/11/15

FIRE SAFETY CERTIFICATE

Certified that the AVB Adarsh Vidya Bhawan at F-277-278, Laxmi Nagar, Delhi-92, owned/occupied by AVB Adarsh Vidya Bhawan, comprised of ground plus two upper floors was granted fire safety certificate vide letter no. F6/DFS/MS/School/2012/3322 dated 12/09/12. The School building was inspected by the officer concerned of this department on 14/10/15 in the presence of Pankaj Verma (AO) and found that the school building has been deemed to comply with the fire prevention and fire safety requirements in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of condition under rule 38 and that the GF+FS+SF of building is fit for occupancy Group B "Educational Building" with effect from ...06/11/15... for a period of three years, subject to conditions printed overleaf.

Issued on ..... 06/11/15 ..... at New Delhi by



(Dr. G.C. Misra)  
Chief Fire Officer  
Ph. 011-23414333

To,  
The Headmistress  
AVB Adarsh Vidya Bhawan  
F-277-278, Laxmi Nagar, Delhi-92.

Copy to:-  
The Dy. Director of Education (E.D.M.C),  
Udyog Sadan, Plot No. 419,  
FIE, Patpargang, Delhi-110092.

Copy to

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation,ventilation,structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form'J'[sub rule(1) of rule 37] along with a copy of this certificate,six months prior to its expiry"

N/7

1. Name & address of the building : AVB Adarsh Vidya Bhawan at F-277-278, Laxmi Nagar, Delhi -92.
2. Building is comprised of : G+2 Upper floor
3. Type of Occupancy : Educational
4. Type of Case : **Renewal**
5. Details of Previous FSC : F.6/DFS/ MS/School/2012/3322 Dated 12/09/12
6. Fire Safety Circular No. : Delhi Fire Service Act, 2007 and Rules 2010.
7. Date of Inspection : 14.10.15
8. Name of the Inspecting officers : DO Virendra Singh
9. Name and designation of Officer from the building side : Sh.Pankaj Verma (AO).
10. Year of Construction : 2010
11. Applicant's letter No : Dated 25/08/2015

NO.	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remark
1	Access to building			
	• Road width	06 Mtrs.	05 Mtrs.	Old Accepted
	• Gate width	N/A	N/A	N/A
	➤ Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	02 Nos.	2 Nos.	MR
	• Basement	N/A	N/A	N/A
	b. Width of Staircases			
	• Upper Floor	1.2 M	1.2 M each	Old Accepted
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	02 No.	02 No.	MR
		1.5 M	1.7 M	MR
	e. Width of Corridor	1.0 Mtrs	1.0 M	MR
	f. Door Size			
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	10 Nos.	10 Nos.	MR
	• Types	ABC & Co2	ABC & Co2	MR
	• IS marking	ISI marked	ISI marked	MR

N/S

6	First-aid-Hose Reels.			
	Total numbers of each floor	01 No.	01 No.	MR
	• Length of hose reel hose	30 M	30 M	MR
	• Nozzle diameter	5 MM	5 MM	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.	N/A	N/A	N/A
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the Pump	40 M	40 M	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Auto	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 Ltrs.	10,000 Ltrs.	MR


N/9

15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.	N/A	N/A	N/A
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	N/A	N/A	N/A
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire safety arrangements provided in the building were tested/ checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire Safety measures as required under the rules. The fire safety certificate issued vide letter no.F.6/DFS/MS/School/2012/3322 dated 12/09/12 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Submitted please.

  
 30/10/15  
 Signature of the Inspecting Officer  
 Name: Virendra Singh