

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

E-mail:- cfohq.dlfire@nic.in

No.F.6/DFS/MS/School/2015/ 52/1984

Fax: - 011-23412593

Dated: 04/11/15

FIRE SAFETY CERTIFICATE

Certified that the building of **Sarvodaya Kanya Vidyalaya No.-2**, C-Block, Janakpuri, New Delhi-110058, is comprised of three blocks namely Main Block, New Block and Red Block. Each block is having ground plus one upper floor. Only ground floor is being used in Red Block. The owned/occupied by the school management was inspected by the officer concerned of this department on 16.10.2015 in the presence of Smt. Usha Dhariwal (H.O.S) and found that the school management have complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the school building/ premises (**Main Block, New Block and ground floor of Red Block**) is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed as under.

Issued on.....04/11/15.....at New Delhi.

(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to:-

1. The Principal,
Sarvodaya Kanya Vidyalaya No.-2,
C-Block, Janakpuri, New Delhi-110058.
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi - 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

Comprised of three blocks namely Main Block, New Block & Red Block. Each block is having Ground plus one upper floor But only ground floor is being used in Red block.
(Sarvodaya Kanya Vidyalaya No.-2, C-Block, Janakpuri, New Delhi-110058.)

INSPECTION REPORT

1. Name & address of the building : Sarvodaya Kanya Vidyalaya No.-2, C-Block, Janakpuri, New Delhi-58.
2. Type of Occupancy : Educational
3. Type of Case : New *(Main block is old case)*
4. Details of Previous NOC : N/A *(Main block : FG/DFS/MS/2011/School/3505 dt 14/12/11)*
5. Fire Safety directives letter No : N/A
6. Date of inspection : 16.10.2015
7. Name of Inspecting Officer : A.D.O. Sandeep Duggal
8. Name and designation of officers
From the building side : Smt. Usha Dhariwal (H.O.S)
9. Year of Construction : 1976, 2013 & 2000
10. Applicant's letter No. : Letter No. Nil dated 16.10.2015

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Circular dt. 01.03.2011	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<p>Accessible</p> <p>—</p> <p>—</p>	<p>12 mtrs.</p> <p>04 mtrs.</p> <p>—</p>	<p>M/R</p> <p>—</p> <p>—</p>
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors 	03 No's in MBlk, 02 No's in NBlk	03 No's in MBlk, 04 No's in NBlk	M/R
	<ul style="list-style-type: none"> • Basements 	N/A	N/A	No basement
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor 	—	135, 148 & 134 cms in MBlk, 150 X 3 & 148cms in N Blk	M/R (as per letter of Principal only ground floor is used in red block)
	<ul style="list-style-type: none"> • Basements 	N/A	N/A	No basement
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A	N/A	N/A
		N/A	N/A	N/A
	d. No. of continuous staircases to terrace			
		1.5 mtrs.	2.10 mtrs in M Blk & 1.90 mtrs in N Blk	M/R
	e. Width of Corridor			
		—	106 X 2 in M Blk, 116 & 97 in N Blk & 97 & 106 cms in Red Blk	M/R
	f. Door Size			
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A

Saw

2/17

Comprised of three blocks namely Main Block, New Block & Red Block. Each block is having Ground plus one upper floor But only ground floor is being used in Red block.
(Sarvodaya Kanya Vidyalaya No.-2, C-Block, Janakpuri, New Delhi-110058.)

	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	• Basements	N/A	N/A	No basement
	• Upper floors	N/A	Natural Ventilation	M/R
5.	Fire Extinguishers			
	• Total numbers	35 no's ABC/CO2 type ISI marked	40 no's Provided	M/R
	• Types		Provided	M/R
	• IS marking		ISI marked	M/R
6.	First-Aid Hose Reels			
	• Total numbers on each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
7.	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	Provided	N/A
10.	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Ground Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A

Comprised of three blocks namely Main Block, New Block & Red Block. Each block is having Ground plus one upper floor But only ground floor is being used in Red block.
(Sarvodaya Kanya Vidyalaya No.-2, C-Block, Janakpuri, New Delhi-110058.)

	<ul style="list-style-type: none"> ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/Manual Stopping 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
15.	Exit Signage	N/A	N/A	N/A
		N/A	N/A	N/A
16.	Provision of Lifts.			(No Lift)
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
		N/A	N/A	N/A
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

N/9

Comprised of three blocks namely Main Block, New Block & Red Block. Each block is having Ground plus one upper floor But only ground floor is being used in Red block.
(Sarvodaya Kanya Vidyalaya No.-2, C-Block, Janakpuri, New Delhi-110058.)

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the above substantial compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Note:- As per letter submitted by the Principal of school placed at (C-9). Red block is comprised of Ground plus one upper floor but only ground floor is in use.

Sandeep
21/10/15

Signature of Inspecting Officer

Name:- Sandeep Duggal

Designation:- Asstt. Divisional Officer

Signature of Inspecting Officer

Name

Designation

Divisional Officer (South West)

B. Kumar
21/11/15

