

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No. F6/DFS/MS/EH/2015/52/2024

Dated: 09/11/15

FIRE SAFETY CERTIFICATE

Certified that M/S Beeryani Restaurant (A Unit of NTS Hospitality Pvt. Ltd. located at Ground and Mezzanine Floor, M-44, M-Block Market, Greater Kailash-II, New Delhi-48, comprised of Basement (Vacant), Ground, Mezzanine, plus two upper floors (Restaurant at ground and mezzanine floors only), was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/EH/2012/2606, dated 19-07-12. The premises was re-inspected by the officer concerned of this department on 21-10-2015 in the presence of Sh. Nishant Sinha, Owner and found that the said eating house building (Ground plus mezzanine floor only) have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Group-D Assembly Building(Eating House) with effect from 09/11/2015 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 09/11/2015 at New Delhi by.



(Dr.G.C.Misra)

Chief Fire Officer

T.No.011-23414333

To:- 1. M/S Beeryani Restaurant (A Unit of NTS Hospitality Pvt. Ltd. located at Ground and Mezzanine Floor, M-44, M-Block Market, Greater Kailash-II, New Delhi-48. o/c

2. Dy. Health Officer, SDMC, South Zone, Green Park, New Delhi.

Conditions for the validity of fire safety certificate are under:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate in form J, six month prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	M/S Beeryani Restaurant (A Unit of NTS Hospitality Pvt. Ltd. located at Ground and Mezzanine Floor, M-44, M-Block Market, Greater Kailash-II, New Delhi-48.		
2	Building comprised of	Basement (Storage), Ground, Mezzanine plus two upper floors. Restaurant is at <u>ground plus mezzanine floor only</u> . Rest of the floors are others properties.		
2	Type of Occupancy	Assembly building "D" Restaurant		
3	Type of case	Renewal		
4	Details of previous NOC	F6/MS/DFS/EH/2012/2606 dt 19.07.2012.		
5	Fire safety directives letter No	Nil		
6	Date of inspection	21.10.2015.		
7	Name of the inspecting Officers	: ADO Vedpal		
8	Name and designation of officers from the building side	Mr. Nishant Sinha, Owner.		
9	Year of construction	2000		
10	Applicant's letter No.	No.DHO/SZ/2015/D/1855, Dated 08.10.2015.		
S. NO.	Minimum Standards on fire prevention and fire safety U/R	NBC Requirement	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	Required	10 Mtr Provided	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	2 Nos	02 Nos.	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.25 Mtr	1.58m & 92cm	MR (Old Case)
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	Required	01no.	MR
	e. Width of corridor	N/A	N/A	MR
	f. Door size	Required	2.2m, 1m & 65cm	MR(old case)
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	30 a/c per hour	N/A	N/A
	upper floors	12 a/c per hour	Exhust Fans	MR
5	Fire Extinguishers			
	total numbers		06 Nos	MR
	Types		ABC, Co2, Foam	MR
	ISI marking	ISI	Yes	MR
6	First-Aid Hose Reels.			
	total numbers on each floor	1 nos.	01no.	MR
	length of Hose reel hose	30 m	30m	MR


7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	N/A (Area less than 200 sq. meters)	N/A	N/A
	upper floors	Required	Provided	MR
	sprinkler above false ceiling	N/A	N/A	MR
11	Internal Hydrants			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	MR
	b. Head of main pump	N/A	N/A	MR
	c. Number of main pumps	N/A	N/A	MR
	d. jockey pump out put	N/A	N/A	MR
	e. jockey pump head	N/A	N/A	MR
	f. Standby Pump output	N/A	N/A	MR
	g. Stanby Pump head	N/A	N/A	MR
	h. Auto Starting/Manual stopping	N/A	N/A	MR
	pump house access	N/A	N/A	MR
	2. Terrace level			
	a. Discharge of pump	450 & 180 LPM	450 & 180 LPM	MR
	b. head of the pump	40 mtr	40 mtr	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	5,000 ltr	10000Liters	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR

N/A

18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any:			

The fire protection systems provided in the building were test checked randomly and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the SFC issued vide letter No.F.6/DFS/MS/School/2012/2606, dated 19.07.2012 renewal under rule 35 of the Delhi Fire Service Rule 2010 is recommended.

Accordingly DFA is put up for your approval and signature please.

 20/10/15

Signature of the inspecting officer

Name Vedpal

Designation : Assistant Divisional Officer

 20/10/15