

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F.6/DFS/MS/2015 / *school/w2/2032*

Dated: *10/11/2015* /2015

**FIRE SAFETY CERTIFICATE**

Certified that **Rana Public School, Shahibabad Daulatpur, Delhi-110042** comprised of **Ground + One upper floor** owned/occupied by **Rana Public School** has already been issued fire safety certificate **Letter No. F.6/MS/DFS/HQ/06/2950 Dated: 04/10/2006.** The premises was re-inspected by the officer from this department on dated **15/10/2015** in the presence of **Sh. R. S. Rana (Manager)** and observed that now building is comprise of **Two blocks, ground + one upper floor interconnected.** All the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deem complied with the requirements of **Letter No 262-362 dated 17/01/2005** issued by Director of Education and the building / premise is fit for occupancy of **Group Class B (Educational)** with effect from **10/11/2015** for a period of **three years**, subject to compliance of the conditions mentioned below:

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on *10/11/15* at New Delhi by

*C*  
*9/11*  
(SANTOKH SINGH)  
Chief Fire Officer  
Ph: 011-23414250  
*ofc*

**Copy to:**

1. The Principal, Rana Public School, Shahibabad Daulatpur, Delhi-110042.
2. The Director of Education, Old Secretariat, Delhi

*Addition of 1 block*

**INSPECTION REPORT**

Two blocks-Gr. + one upper floor  
Interconnected

1. Name & address of the building : Rana Public School, Shahibabad Daulatpur, Delhi-110042
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : Letter No. F.6/MS/DFS/HQ/06/2950 Dated: 04/10/2006
5. Fire Safety directives letter No : Dir of Education. Cir .17/01/2005 & 1.3.11.
6. Date of inspection : 15/10/2015
7. Name of the Inspecting Officers : ADO (BW)
8. Name and designation of officers  
from the building side : Sh. R. S. Rana (Manager)
9. Year of Construction : 1991-2010
10. Applicant's letter No. : RPS/Gen/2015/01 Dated 18/09/2015

Plot area:-400 sq yard Covered area:-800 sq yard No.'s of Student:-150 No.'s of Classrooms:-13

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	Accessible	Accessible	MR
	• Gate width	—	—	—
	• Width of internal road	—	—	—
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	—	—	—
	• Upper Floors	01	02	MR
	• Basements	—	—	—
	b. Width of staircases	—	—	—
	• Upper Floors	1.50 mtr	1.35 mtr & 1.00 mtr	MR
	• Basements	—	—	—
	c. Protection of exits	—	—	—
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	R	P	MR
	g. Width of Corridor	—	—	—
	h. Door Size	1.0 mtr 2 X 2.00 mtr	P 2.50 & 2.00 mtr	MR

3	<b>Compartmentation.</b>	—	—	—
	• Fire check door	—	—	—
	• Sealing of electrical shafts	—	—	—
	• Fire Rating of shaft door	—	—	—
	• Water Curtain	—	—	—
	• Fire Dampers	—	—	—
4	<b>Smoke Management System.</b>			
	• Basements	30 a/c per hour	—	—
	• Upper floors	12 a/c per hour	—	—
5	<b>Fire Extinguishers</b>			
	• Total numbers	5 ABC	13	MR
	• Types	ISI marked	ABC	MR
	• IS marking		Yes	MR
6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	One	P	MR
	• Length of hose reel hose	30 m	P	MR
	• Nozzle diameter	5 mm	P	MR
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	—	—	—
	• Location of Main Panel	—	—	—
	• Location of Repeater Panel	—	—	—
	• Alternate source of power	—	—	—
	• Hooters' Location	—	—	—
8	<b>MOEFA</b>	—	—	—
9	<b>Public Address System.</b>	—	—	—
10	<b>Automatic Sprinkler System.</b>			
	• Basement	—	—	—
	• Upper Floor	—	—	—
	• Sprinkler above false ceiling	—	—	—
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	—	—	—
	• Number of hydrants per floor	—	—	—
	• Hose Box	—	—	—

12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	—	—	—
	• Hose Box	—	—	—
13	<b>Pumping Arrangements.</b>			
	• Ground Level	—	—	—
	➤ Discharge of main Pump	—	—	—
	➤ Head of Main pump	—	—	—
	➤ Number of main pumps	—	—	—
	➤ Jockey Pump out put	—	—	—
	➤ Jockey pump head	—	—	—
	➤ Standby Pump out put	—	—	—
	➤ Standby Pump Head	—	—	—
	➤ Auto Starting/ Manual stopping	—	—	—
	➤ Pump House Access	—	—	—
	• Terrace level	—	—	—
	➤ Discharge of pump	450 LMP	P	MR
	➤ Head of the pump	40 m	P	MR
	➤ Power Supply	—	—	—
	➤ Auto Starting of pump	—	—	—
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	—	—	—
	➤ Draw-off connection	—	—	—
	➤ Fire service inlet	—	—	—
	➤ Access to tank	—	—	—
	• Overhead Tank capacity	2500 ltr	2500 ltr	MR
15	<b>Exit Signage.</b>			
		—	—	—
16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	—	—	—
	• Pressurization of Lift lobby	—	—	—
	• Communication In lift Car	—	—	—
	• Fireman's Grounding Switch	—	—	—
	• Lift Signage	—	—	—
17	<b>Standby power supply</b>			
		—	—	—

18	<b>Refuge Area.</b>			
	➤ Total Area	—	—	—
	➤ Location	—	—	—
19	<b>Fire Control Room</b>			
	• Detector System Panel	—	—	—
	• Flow Switch Panel	—	—	—
	• PA System Panel	—	—	—
	• Batter backup	—	—	—
	• Building Floor Plans	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	—	—

**Note:-**General requirements for school as per Director of Education Circular date 17/01/2005

1. Escape route..... **Clear** .....
2. LPG cylinders in laboratories ..... **No** .....
3. Electric wiring ..... **Concealed & conduit**.....**MCB** .....**Provided**.....  
Electric circuit.....**ELCB provided**.....
4. Electric meter board ..... **Not Below**.....**S/C** .....
5. Basement use as per BBL 1983..... **N/A** .....
6. Emergency telephone no. board... **Displayed** .....
7. Generator set..... **No** .....

The premises was earlier comprised of Ground + One upper floor. One more block comprised of a hall at ground floor and first floor with class room is added and connected to the previous block.

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/MS/DFS/HQ/06/2950 Dated: 04/10/2006. Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Name

Designation

Designation

*Signature*  
19/10/15

*Signature*  
17/10/15  
ADD (BIO)

678/DCB  
23/10/15