

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. FC/OFS/MS/BH/2015/NZ/2000

Date: 6/11/15

FIRE SAFETY CERTIFICATE

Certified that the M/s World Art Dining (a unit of Nimitaya Hospitality LLP) situated at premises No. 1, Main Club Road, Punjabi Bagh, New Delhi at 3rd floor of a premises comprised of B+G+1+2 & 3rd floors owned /occupied by M/s World Art Dinning have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 05.10.2015 in the presence of Mr. Manoj and that the building/premises is fit for occupancy **Assembly** with effect from _____ for a period of three years in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Following fire safety directives must be adhered to:

1. All the means of escape shall be kept free of all types of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire-fighting equipment shall be maintained in perfect working condition all the time and lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, electric installation etc. may be got verified from concerned authorities.
5. Basement shall be used only as per NBC part-IV.
6. This NOC may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhi.govt.nic.in
8. "the owner/occupier shall apply for renewal of this fire safety certificate to the Director in Form-'J' [sub rule (1) of rule 37] along with a copy of this certificate six months prior to its expire."

Issued on 6/11/15 at New Delhi by


(Santokh' Singh)
Chief Fire Officer
Delhi Fire Service
011-23414250

Copy to:

1. M/s World Art Dinning (A Unit of Nimitaya Hospitality LLP) situated at premises No.1, 3rd floor, Main Club road, Punjabi Bagh, New Delhi.
2. Dy. Health Officer West Zone, Vishal Enclave, Rajouri Garden, New Delhi-10027

INSPECTION REPORT

1. Name & address of the building : M/s World Art Dining (a unit of Nimitaya Hospitality LLP) situated at premises No. 1, 3rd Floor, Main Club Road, Punjabi Bagh, New Delhi
2. Type of Occupancy : Assembly
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives letter No. : Nil
6. Date of inspection : 05-10-2015
7. Name of the Inspecting Officers : D.O. M.N.
8. Name and designation of officers
- From the building side : Mr. Manoj
9. Year of Construction : 2005-2006
10. Applicant's letter No. : D-1914/HD/WZ dated 16/9/2015

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	9 m	Provided	M/R
	• Gate width	4.5 mtr	Provided	M/R
	• Width of internal road	As per plan	Provided	M.R.
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	2	2	M.R.
	• Basement	2	2	M.R.
	b. Width of staircases			
	• Upper Floors	1.5 mtr, 1.00mtr	Provided	M/R
	• Basement	1.5 mtr.	1.5 & 2 mtr.	M.R.
	c. Protection of exits			
	• Fire check door	N.R.	N.R.	N.R.
	• Pressurization	N.R.	N.R.	N.R.
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	1.5 mtr	Halls only	M.R.
	f. Door size	2 mtr	Provided	M.R.
3.	Compartmentation.			
	• Fire check door	N.R.	N.R.	N.R.
	• Sealing of electrical shafts	N.R.	N.R.	N.R.
	• Fire Rating of shaft door	N.R.	N.R.	N.R.
	• Water Curtain	N.R.	N.R.	N.R.
	• Fire Dampers	N.R.	N.R.	N.R.
4.	Smoke Management System.			
	• Basements			
	• Upper floors	Required	Provided	M.R.
5.	Fire Extinguishers			

	<ul style="list-style-type: none"> Total numbers Types IS marking 	04 CO ₂ , Water CO ₂ type ISI marked	10 Provided Provided	M.R. M.R. M.R.
6.	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01 30 m required 5 mm	Provided Provided Provided	M.R. M.R. M.R.
7.	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's Location 	Required Required Required Required Required	Provided Provided Provided Provided Provided	M.R. M.R. M.R. M.R. M.R.
8.	MOEFA	Required	Provided	M.R.
9.	Public Address System	N.R.	Provided	M.R.
10.	Automatic Sprinkler system			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	R. N.R. N.R.	P. N.R. N.R.	M.R. N.R. N.R.
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	150 m. m 02 02	Provided Provided Provided	M.R. M.R. M.R.
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N.R. N.R.	N.R. N.R.	N.R. N.R.
13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump	N.A.	N.A.	N.A.
	➤ Head of Main pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey Pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting/Manual stopping	N.A.	N.A.	N.A.
	➤ Pump Hose Access	N.A.	N.A.	N.A.
	Terrace level			
	➤ Discharge of pump	900 LPM	P ✓	M.R.
	➤ Head of the pump	60 mtr	P	M.R.
	➤ Power supply	required	Provided	M.R.

	➤ Fire service inlet	required	Provided	M.R.
	➤ Access to tank	10,000 ltrs	Provided	M.R.
	➤ Overhead Tank Capacity			
15	Exit Signage.	required	Provided	M.R.
16.	Provision of Lifts			
	• Pressurization of Lift Shaft	N.R.	N.R.	N.R.
	• Pressurization of Lift lobby	N.R.	N.R.	N.R.
	• Communication In lift Car	N.R.	N.R.	N.R.
	• Fireman's Grounding Switch	N.R.	N.R.	N.R.
	• Lift Signage	N.R.	N.R.	N.R.
17.	Standby power supply	Required	Provided	M.R.
18.	Refuge Area			
	➤ Total Area	N.R	N.R	N.R
	➤ Location	N.R	N.R	N.R
19.	Fire Control Room			
	➤ Detector System Panel	N.R	N.R	N.R
	➤ Flow Switch Panel	N.R	N.R	N.R
	➤ PA system Panel	N.R	N.R	N.R
	➤ Batter backup	N.R	N.R	N.R
	➤ Building Floor plans	N.R	N.R	N.R
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R	N.R	N.R

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/.

[Handwritten Signature]

Signature of the Inspection Officer

Name : Sunil Chawdhary

Designation DO (W)



Signature of the Inspection Officer

Name Vipin Kantar

Designation Dy. C.F.O