

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

NO. F6/DFS/MS/CNG/2015/SZ/ 2047

Dated: 13/11/15

FIRE SAFETY CERTIFICATE

Certified that the LPG Godown at site No.2, Sector-20, Dwarka, New Delhi-110075, comprised of ground floor only owned/occupied by Super Care Gas Service have complied with the fire prevention and fire safety requirements as per directives issued by this department vide letter no. F6/MS/DFS/LPG/94/600 dated 18.4.1994 and verified by the officers concerned of fire service on 23.9.2015 in presence of Sh. Gajender Singh (Manager) and that the building/ premises is fit for occupancy class "Hazardous" (LPG Storage) with effect from ...13/11/15.... for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on .....13/11/15..... at New Delhi by



(Dr. GC Misra)  
Chief Fire Officer  
Ph.011-23414333

Copy To:

1. Authorized signatory, Super Care gas Service, G-1, Opp: Brahma Aptt. Palam Exten., Sector-7, Dwarka, New Delhi-110075.

1	Name & address of the building	M/S Super Care Gas Service, LPG Godown, Site No.2, Sector-20, Dwarka II, New Delhi.		
2	Type of Occupancy	Hazardous (LPG Storage)		
3	Type of case	New		
4	Details of previous NOC	Nil		
5	Fire safety directives letter No	F6/MS/DFS/LPG/94-600 dated 18.4.1994		
6	Date of inspection	11.9.2015 & 23.9.2015		
7	Name of the inspecting Officers :	ADO S.P Bhardwaj (Dwarka)		
8	Name and designation of officers from the building side	Sh.Gajender (Manager)		
9	Year of construction	1995		
10	Applicant's letter No.	sNil dated 13.8.2015	Ground Floor	Godown
<b>S. NO.</b>	<b>Minimum Standards on fire prevention and fire safety U/R 33</b>	<b>LPG Cilender Rules</b>	<b>Provided at site</b>	<b>Remarks MR / NMR</b>
<b>1</b>	<b>Access to building</b>			
	1) Road width	Accessible	20 Mtrs.	MR
	2) Gate width	Approachable	1.25 Mtrs.	MR
	3) Width of internal road	N/A	N/A	N/A
<b>2</b>	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	N/A	N/A	N/A
	2. basements	N/A	N/A	N/A
	<b>b. Width of staircase</b>			
	1. Upper floors	N/A	N/A	N/A
	2. basements	N/A	N/A	N/A
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	N/A	N/A	N/A
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	N/A	1.25 Mtrs.	MR
<b>3</b>	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
<b>4</b>	<b>Smoke Management system.</b>			
	basement		N/A	N/A
	Ground Floor	12 a/c per hour	Natural Ventilation at Ground / lower level	MR
<b>5</b>	<b>Fire Extinguishers</b>			
	total numbers	2 Nos. + 3 Sand Buckets	2 Nos. + 6 Sand Buckets	MR
	Types	DCP 10 Kgs.	DCP10 Kgs.	MR
	ISI marking	Required	Provided	MR

	total numbers on each floor	N/A	N/A	N/A
	Length of Hose reel hose	N/A	N/A	N/A
	Nozzle Diameter	N/A	N/A	N/A
<b>7</b>	<b>Automatic fire detection and alarming system</b>			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
<b>8</b>	<b>MOEFA</b>	N/A	N/A	N/A
<b>9</b>	<b>Public Address System.</b>	N/A	N/A	N/A
<b>10</b>	<b>Automatic Sprinkler System.</b>			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
<b>11</b>	<b>Internal Hydrants</b>			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	Hose Box	N/A	N/A	N/A
<b>12</b>	<b>Yard Hydrants.</b>			
	Total number of hydrants	N/A	N/A	N/A
	Hose box	N/A	N/A	N/A
<b>13</b>	<b>Pumping arrangements</b>			
	<b>1. Ground level/</b>			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	<b>2. Terrace level</b>			
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
<b>14</b>	<b>Captive water storage for fire fighting</b>			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	N/A	N/A	N/A
<b>15</b>	<b>Exit Signage.</b>	N/A	No smoking Boards	MR
<b>16</b>	<b>Provision of lifts.</b>			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

S/N

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area	N/A	N/A	N/A
	location	N/A	N/A	N/A
19	Fire control room			
	a. Detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems : DCP			

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety requirements under the rule, grant of Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010, is recommended.

Accordingly DFA is put up for approval and signature please.

Signature of the Inspecting Officer

Name

S.P Bhardwaj

Designation

ADO (DWARKA)