

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

Fax: 23412593, E-mail: cfohq.dlfire@nic.in, Tel:- 011-23414333

NO. F6/DFS/MS/2015/ 521 2052

Dated: 13/11/15

FIRE SAFETY CERTIFICATE

Certified that **Multistory Building at CRR I Staff Colony, Maharani Bagh, New Delhi** comprised of ground plus twelve upper floors was granted FSC by this department vide letter No. F.6/DFS/MS/2012/3350 dated 13.09.2012 was re-inspected by the officers concerned of this department on 03-11-2015 in presence of Mr. A.K. Tripathi, group leader (MBSQ/MTCE) of CRR I and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi fire service Rules 2010, and that the building/premises is fit for occupancy **Residential** with effect from 13/11/15 for a period of **5(five)** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 13/11/15 at New Delhi by.



(Dr. G.C. MISRA)
CHIEF FIRE OFFICER

Copy to: -

1. The Coordination Officer, CRR I Staff Colony, Maharani Bagh, New Delhi-110065.

Conditions for the validity of fire safety certificate

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time.
- b. Loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
- c. The trained fire fighting staff should be available round the clock.
- d. Good house keeping shall be ensured.
- e. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Multistory Building at CRRJ Staff Colony, Maharani Bagh, New Delhi
2. Type of Occupancy : Residential
3. Type of Case : Renewal
4. Details of previous NOC : Letter No. F.6/DFS/MS/2012/3350 dated 13.09.2012
5. Fire Safety directives letter No. : Delhi Fire Service Act-2007 & Delhi Fire Service Rules-2010
6. Date of inspection : 03-11-2015
7. Name of the Inspecting Officers : Dharampal Bhardwaj, DO(SZ), M.K Chattopadhyay, ADO (M. Road)
8. Name and designation of officers from the building side : Mr. A.K. Tripathi, group leader (MBSQ/MTCE) of CRRJ
9. Year of Construction : 1974
10. Applicant's letter No. : nil dated 11.09.2015

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	09 mts	Provided	MR
	• Gate width	05 mts	Provided	MR
	• Width of internal road	06 mts	Provided	MR
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-	-	-
	• Upper Floors	02	02	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-	-	-
	• Upper Floors	1.0 mt.	1.0 mt.	MR (being old case)
	• Basements	N/A	N/A	N/A
	c. Protection of exits	-	-	-
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01	01	MR
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	N/A	N/A	N/A
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A



		Required	Provided	MR
	<ul style="list-style-type: none"> Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements 	30 a/c per hour	N/A	N/A
	<ul style="list-style-type: none"> Upper floors 	12 a/c per hour	N/A	N/A
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 	42	Provided	MR
	<ul style="list-style-type: none"> Types 	ABC, CO ₂	Provided	MR
	<ul style="list-style-type: none"> ISI marking 	ISI marked	Provided	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor 	02	Provided	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m	Provided	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location of Main Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location of Repeater Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Alternate source of power 	Required	Provided (D.G. set)	MR
	<ul style="list-style-type: none"> Hooters' Location 	Each floor	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Upper Floor 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	150 mm	Provided	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	02	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	02	Provided	MR
12	Yard Hydrants.			


	• Total number of hydrants	02	Provided	MR
	• Hose Box	02	Provided	MR
13	Pumping Arrangements.			
	• Ground Level	-	-	-
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level	----	----	----
	➤ Discharge of pump	450 LPM	Provided (02)	MR
	➤ Head of the pump	45 mts.	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	1,00,000 Its	Provided	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10,000 Its	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	Required	Provided	MR
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided (DG 110 KVA)	MR


18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	02 ABC type fire extinguishers found provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F.6/DFS/MS/2012/3350 dated 13.09.2012, renewal under the Delhi Fire Service Act-2007 & Rules-2010 is recommended.

Accordingly DFA is put up for signature please.


 DHARAMPAL BHARDWAJ
 DO (SZ)


 M.K.CHATTOPADHYAY
 ADO (M. Road)